



## Fire Marshal Division

October 24, 2018

David Benzo  
221 Technology Park Ln.  
Fuquay-Varina, NC 27526

**Re: Grace Community Church  
2160 Harnett Central Rd.  
Angier, NC 27501**

**Application Number FMFW-1810-0009**

Mr. Benzo,

Thank you for submitting the fire alarm replacement paperwork. The request for change has been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that need to be addressed before a final inspection of the new panel can be given. These items are outlined and described below.

- **Fire Alarm System Upgrade Notes**

**All items in notes are to be completed at the time of final.**

- Provide a record of completion.
- The Fire marshal's office will complete an acceptance test at completion of project.
- Provide a copy of account history after the acceptance test is completed and approve.
- Provide an accurate zone map at the FACP and remote annunciator panel.
- All work/installation shall be compliant with the NCSFC and NFPA 72.
- Clarify highlighted areas and remarks on plans as to where and which devices will be removed/replaced or added at noted locations.
- Call Fire Marshal's office to schedule the fire alarm acceptance test. (910-984-4003)



Thank you again for submitting the fire alarm panel upgrade. Please review and adhere to any notes. These remarks are for the paperwork that was submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal