



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

2/1/2023

**SUBJECT: FMFW1811-0001  
FIRE MARSHAL**

To: Sunland Fire Protection Inc.

Here are the results of all Inspections located at **807 EDWARDS BROTHERS DR:**

Inspection Type: FM ABOVE CEILING  
Scheduled Date/Time: 11/20/2019 AM  
Completed Date/Time: 11/20/2019 AM  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes: DBW

Inspection Type: FM SPRINKLER HYDRO  
Scheduled Date/Time: 11/20/2019 AM  
Completed Date/Time: 11/20/2019 AM  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes: DBW

Inspection Type: FM FINAL  
Scheduled Date/Time: 12/10/2019 AM  
Completed Date/Time: 12/10/2019 AM  
Inspector: Unassigned  
Result: APPROVED W/EXC  
Remarks:  
Notes: Must pour concrete pad outside egress door from H-2 room and ensure fire alarm system is dialing out prior to building CO; DBW

Inspection Type: FM FIRE ALARM  
Scheduled Date/Time: 12/10/2019 AM  
Completed Date/Time: 12/10/2019 AM  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes: See Final Notes





**Harnett County**  
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FM FIXED FIRE SUPPRESSION

Scheduled Date/Time: 12/10/2019 AM

Completed Date/Time: 12/10/2019

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes: See Final Notes

Inspection Type: FM FINAL

Scheduled Date/Time: 2/18/2020 PM

Completed Date/Time: 4/13/2020

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes: