



Fire Marshal Division

P.O. Box 370
Lillington, NC 27546
910-893-7580

Application for Plan Review

Application # FMFW1812-0005

Date Received: 12/17/18 Received By: [Signature]

Name of Project: PJ's Truck Bodies

Physical Address of Project: 1560 George Perry Lee Rd
Dunn NC 28334

Plans Submitted By: Robert Whitley

Project Phone: ()- -

Contact Person/Address: Jeremy Parrish

Contact Phone: 919-894-8495 ()- -

Contractor's Name/Info: Pye Barker Fire & Safety

710 Porter Rd Rocky Mount, NC 27803

Contractor's Phone: 252-985-4545


- Plans that are submitted will be reviewed as quickly as possible with an average time of review between 7-10 working days.
- Status checks may be conducted on plan reviews by visiting the website <http://hteweb.harnett.org/Click2GovBP/Index.jsp> or by calling the Harnett County Central Permitting Office (910-893-4759), or the Harnett County Fire Marshal's Office (910-893-7580).
- Approved plans must be picked up from the Central Permitting Office and all fees paid before any required inspections can be conducted.

Pyro Chem U.L. 1254 AUTO SPRAY PAINT BOOTH FIRE SUPPRESSION SYSTEM



EXHAUST FAN & INCOMING AIR MUST SHUT DOWN ON DISCHARGE OF THE FIRE SUPPRESSION SYSTEM.
THE BUILDING FIRE ALARM MUST BE CONNECTED IF BUILDING IS EQUIPPED WITH A FIRE ALARM SYSTEM.
HEATED BOOTHS GAS SUPPLY MUST SHUT DOWN ON DISCHARGE OF THE FIRE SYSTEM.

Reviewed For Code Compliance By:
D. Banks Wallace
Chief Deputy Fire Marshal
01/03/2019 2:44:29 PM

P
B
F
S



Recirculation Plenum
No Exhaust Duct



P
B
F
S

PERMIT APPLICATION DRAWING

Date: 12/13/18



Pye Barker Fire & Safety
710 Porter Road
Rocky Mount, NC 27803

PJ's Truck Bodies
1560 George Perry Lee Road
Dunn, NC 28334