



1 POWER PLAN
E-4 3/32=1'-0"

- PLAN NOTES:**
- MOUNT RECEPTACLES, DATA OUTLETS, & TV OUTLETS AT 18" AFF U.N.O. MOUNT SWITCHES AT 48" AFF.
 - DO NOT MOUNT OUTLET BOXES BACK TO BACK BETWEEN ADJACENT SUITES. EACH BOX SHALL BE SEPARATED BY AT LEAST 4" HORIZONTALLY. DO NOT LOCATE ADJACENT BOXES ON OPPOSITE SIDES OF SAME STUD.
 - PROVIDE BOXES AND RACEWAY WITH PULLSTRING FOR REMOTE THERMOSTATS. COORDINATE BOX AND RACEWAY LOCATIONS AND SIZES WITH MECHANICAL CONTRACTOR.
 - COORDINATE ALL HEIGHTS OF RECEPTACLES AND DATA OUTLETS WITH ARCHITECTURAL DRAWINGS
 - CLOSELY COORDINATE ALL ELECTRICAL WORK WITH OTHER DISCIPLINES AND OTHER EQUIPMENT THEREOF TO AVOID ANY CONFLICTS.
 - COORDINATE MOUNTING HEIGHTS OF TV CONNECTIONS WITH OWNER/ARCHITECT PRIOR TO ROUGH-IN.

2 PARTIAL ELECTRICAL ROOF PLAN
E-4 1/8"=1'-0"

REVISIONS	
NO.	DATE
1	3/7/19

A RENOVATION FOR:
SHAWTOWN SCHOOL
HARNETT COUNTY
695 SHAWTOWN ROAD
LILLINGTON, NORTH CAROLINA

Project No:
2018-009
Scale:
Date Drawn: 1/29/19
Sheet Title

POWER PLAN