



Fire Marshal Division

April 8, 2019

Karen Parks
95 Dr. McKoy Rd, Suite 2
Buies Creek, NC 27506

Re: Campbell Spring Concert Special Assembly
56 Main Street
Lillington, NC 27546

Application Number FMFW 1904-0002

Mrs. Parks,

Thank you for submitting the plans for the concert. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **Conditions of Special Assembly Permit**
 - Fire Watch must be maintained at all times the smoke detectors are disabled. The fire watch must be performed by the Buies Creek Fire Department.
 - If at any point and time during the concert the fire alarm system activates due to a manual pull station activation or sprinkler activation, the building shall be evacuated. Evacuation shall also commence due to the identification of any hazard found by security or fire watch staff.
 - Campbell's Crowd Control staff must maintain clear exits and aisles at all times.

Thank you again for submitting the plans for the concert. Please review the plans and adhere to any notes and alterations that were made in addition to the original submittal.



These remarks are for the request submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Again, thank you and we look forward to working with you during the construction period!

Sincerely,

Roger Sullivan
Deputy Fire Marshal