

## ES-50X Battery Calculation

### Secondary Power Source Requirements

Device Type	Standby Current (amps)				Secondary Alarm Current (amps)			
	Qty		Current Draw	Total	Qty		Current Draw	Total
Main Circuit Board	1	x	0.141000	= 0.141000	1	x	0.257000	= 0.257000
IPOTS-COM	1	x	0.040000	= 0.040000	1	x	0.041000	= 0.041000
4XTMF	0	x	0.005000	=	0	x	0.011000	=
Conventional Detectors	0	x	0.000000	=	0	x	0.000000	=
EOLR-1	0	x	0.020000	=	0	x	0.020000	=
ANN-80	2	x	0.015000	= 0.030000	2	x	0.040000	= 0.080000
ANN-80-W	0	x	0.015000	=	0	x	0.040000	=
ANN-100	0	x	0.020000	=	0	x	0.025000	=
ANN-LED	0	x	0.028000	=	0	x	0.068000	=
ANN-RLED	0	x	0.028000	=	0	x	0.068000	=
ANN-RLY	0	x	0.015000	=	0	x	0.075000	=
ANN-I/O	0	x	0.035000	=	0	x	0.200000	=
ANN-I/O LED	0	x	0.000000	=	0	x	0.010000	=
ANN-S/PG	0	x	0.045000	=	0	x	0.045000	=
IPDACT-2	0	x	0.093000	=	0	x	0.136000	=
IPDACT-2UD	0	x	0.098000	=	0	x	0.155000	=
CELL-MOD	0	x	0.055000	=	0	x	0.100000	=
CELL-CAB-FL	1	x	0.055000	= 0.055000	1	x	0.100000	= 0.10000
ECC-FFT	0	x	0.120000	=	0	x	0.230000	=
<b>Addressable Devices</b>								
BEAM355	0	x	0.002000	=				
BEAM355S	0	x	0.002000	=				
CP355	0	x	0.000300	=				
SD355	23	x	0.000300	= 0.006900				
SD355T	0	x	0.000300	=				
SD355R	0	x	0.000300	=				
SD355CO	0	x	0.000300	=				
AD355	0	x	0.000300	=				
H355	3	x	0.000300	= 0.000900				
H355R	0	x	0.000300	=				
H355HT	0	x	0.000300	=				
D350P	0	x	0.000300	=				
D350RP	0	x	0.000300	=				
D350PL	0	x	0.000300	=				
D350RPL	0	x	0.000300	=				
D355PL	3	x	0.000300	= 0.00090				
MMF-300	0	x	0.000400	=				

MMF-300-10	0	x	0.003500	=					
MDF-300	0	x	0.000750	=					
MMF-301	0	x	0.000375	=					
MMF-302	0	x	0.000270	=					
MMF-302-6	0	x	0.002000	=					
BG-12LX	7	x	0.000300	=	0.002100				
CMF-300	0	x	0.000390	=					
CMF-300-6	0	x	0.002250	=					
CRF-300	3	x	0.000270	=	0.000810				
CRF-300-6	0	x	0.001450	=					
CDRM-300	0	x	0.001300	=					
I300	0	x	0.000400	=					
ISO-6	0	x	0.002700	=					
B501BH-2	0	x	0.001000	=					
B501BHT-2	0	x	0.001000	=					
B224RB	0	x	0.000500	=					
B224BI	0	x	0.000450	=					
SD365	0	x	0.000300	=					
SD365-IV	0	x	0.000300	=					
SD365T	0	x	0.000300	=					
SD365T-IV	0	x	0.000300	=					
SD365R	0	x	0.000300	=					
SD365R-IV	0	x	0.000300	=					
H365	0	x	0.000300	=					
H365-IV	0	x	0.000300	=					
H365R	0	x	0.000300	=					
H365R-IV	0	x	0.000300	=					
H365HT	0	x	0.000300	=					
H365HT-IV	0	x	0.000300	=					
B501	0	x	0.000000	=					
B501-IV	0	x	0.000000	=					
B300-6	0	x	0.000000	=					
B300-6-IV	0	x	0.000000	=					
TR-300	0	x	0.000000	=					
TR-300-IV	0	x	0.000000	=					
			Maximum alarm draw for all Addressable devices ----->					0.20000	
CMF-300 (Aux. Power)	0	x	0.001700	=		0	x	0.007000	=
CMF-300-6 (Aux. Power)	0	x	0.008000	=		0	x	0.020000	=
MMF-302 (Aux. Power)	0	x	0.012000	=		0	x	0.090000	=
MMF-302-6 (Aux. Power)	0	x	0.050000	=		0	x	0.270000	=
B200SR (Aux. Power)	0	x	0.000500	=		0	x	0.035000	=
B200SR-LF (Aux. Power)	0	x	0.001000	=		0	x	0.125000	=
Miscellaneous Device 1	0	x	0.000000	=		0	x	0.000000	=

Miscellaneous Device 2	0	x	0.000000	=		0	x	0.000000	=	
Miscellaneous Device 3	0	x	0.000000	=		0	x	0.000000	=	
Miscellaneous Device 4	0	x	0.000000	=		0	x	0.000000	=	
Miscellaneous Device 5	0	x	0.000000	=		0	x	0.000000	=	
NAC 1			0.000000	=				1.671000	=	1.671000
NAC 2			0.000000	=				0.000000	=	
Non-Resettable 1			0.000000	=				0.000000	=	
<b>Total Standby Load</b>					<b>0.277610</b>	<b>Total Alarm Load</b>				<b>2.349000</b>



## ES-50X Battery Calculation

Note 1: You are **fully responsible for verifying these calculations.**

Note 2: Use the dropdowns in the **yellow** cells to enter values.

### Calculation in Total Sheet

		<b>Required Standby Time in Hours</b>			
		24 Hours			
<b>Total Standby Current</b>	0.1200 Amps	x	24	=	2.880 AH
		<b>Required Alarm Time in Minutes</b>			
		5 Minutes			
<b>Total Alarm Load</b>	2.3490 Amps	x	0.084	=	0.197 AH
<b>Total Current Load</b>					<b>3.077 AH</b>
Multiply by the Derating Factor		1.2	=	x 1.20	
<b>Total Ampere Hours Required</b>					<b>3.69 AH</b>

<b>Recommended Batteries:</b>	BAT-1270 - 7AH Batteries
-------------------------------	--------------------------

<b>Battery Check</b>
The batteries can be charged by the ES-50X Charger.
The batteries can be housed in the ES-50X Cabinet.

<b>Current Draw Check</b>
NAC#1 current is within the limitations of the circuit.
NAC#2 current is within the limitations of the circuit.
ES-50X current draw: The required output current is within the panel's limitations

## ES-50X Circuit Detail

### NAC 1

Device	Qty	x	Non-Alarm Draw	=	Total	Qty	x	Alarm Draw	=	Total	
SCRL @ 15 Candela	9	x	0.000000	=	0.000000	9	x	0.041000	=	0.369000	
P4R @ 15/75 Candela	6	x	0.000000	=	0.000000	6	x	0.146000	=	0.876000	
PC2RL @ 15 Candela	6	x	0.000000	=	0.000000	6	x	0.071000	=	0.426000	
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
<b>Total Standby Load</b>					<b>0.000000</b>	<b>Total Alarm Load</b>					<b>1.671000</b>

### NAC 2

Device	Qty	x	Non-Alarm Draw	=	Total	Qty	x	Alarm Draw	=	Total	
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
<b>Total Standby Load</b>					<b>0.000000</b>	<b>Total Alarm Load</b>					<b>0.000000</b>