



## Fire Marshal Division

May 10, 2019

**Re: Campbell University School of Engineering Annex II**  
**108 Burt Street**  
**Buies Creek, NC 27506**

**Application Number FMFW1904-0012**

Brett Strickland,

Thank you for submitting the plans for the new building. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **906.1 Fire Extinguishers required.**
  - A minimum 2A10BC classification of fire extinguisher is required on each floor and located so that the maximum travel distance to reach an extinguisher does not exceed 75ft.
  - Fire Extinguishers shall be located in approved cabinets along corridors.
  - All fire extinguishers shall be mounted not higher than 5ft. above the finished floor and in accordance with NFPA 10.
  
- **1006.1 Means of Egress Illumination**
  - The means of egress, including the exit discharge, shall be illuminated at all time the building space is served by the means of egress is occupied.
    - Means of egress consist of three separate and distinct parts: the exit access, the exit and the exit discharge.
  - The means of egress illumination shall not be less than 1 foot-candle at the walking surface.
  
- **Comments**
  - A final fire inspection is required.
  - Schedule all fire inspections through the Fire Marshal's Office.  
(910) 984-4003



Thank you again for submitting the plans for the new building. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal