



LETTER OF TRANSMITTAL

May 8, 2019

To:

Harnett County Building Inspections
108 E. Front Street
Lillington, NC 27546

Attention: Plans Review and Permits

RE:

Star Academy
900 11th Street
Lillington, N.C. 27546

Re: Kitchen Fire Suppression

We are sending you: Attached

Via: UPS

Hand Delivered

Drawings

Prints

Plans

Permit Application

Copies

3

1

Description

Shop Drawing of Kitchen fire suppression system
Application for Plan Review

For Approval

For your use


As requested

Resubmitted for approval

COMMENTS: *****

Please call Cyndy Gilchrist 919-550-2699 for our credit card number for payment of fees as discussed with Ms. Jennifer Brock . Please notify us when approved and work can begin. Our scope of work consists of installation of fire suppression system only. Please forward permit to us. We will notify you when ready for test.

Copy to: File & Installation Dept.

Signed: 

BFPE International
Kevin F. DeCilles



Fire Marshal Division

P.O. Box 370
Lillington, NC 27546
910-893-7580

Application for Plan Review

Application # _____ - _____

Date Received: _____ Received By: _____

Name of Project: STAR ACADEMY

Physical Address of Project: 900 11th ST.
Lillington NC 27546

Plans Submitted By: BFPE INTERNATIONAL

Project Phone: (919)-893-8151

Contact Person/Address: KEVIN DECILLES

For Payment: → Cyndy Gilchrist cgilchrist@bfpe.com

Contact Phone: (919)-350-2699 () - _____

Contractor's Name/Info: BFPE INTERNATIONAL

115 BESTWOOD DR. CLAYTON NC 27520


Contractor's Phone: (919)-350-2699

Plans that are submitted will be reviewed as quickly as possible with an average time of review between 7-10 working days.

Status checks may be conducted on plan reviews by visiting the website <http://htweb.harnett.org/Click2GovBP/Index.jsp> or by calling the Harnett County Central Permitting Office (910-893-4759), or the Harnett County Fire Marshal's Office (910-893-7580).

Approved plans must be picked up from the Central Permitting Office and all fees paid before any required inspections can be conducted.

* PULL STATION IN PATH OF EGRESS
 * APPLIANCES ELECTRIC W/ SHUT OFF
 * MICRO SWITCH FOR SHUT DOWNS & ALARM
 * DETECTORS FIELD DETERMINED




PYRO-CHEM
 PCL-300
 5 FLOW POINTS
 UL 300

STAR ACADEMY
 900 11TH STREET
 LILLINGTON, NC 27546

BFPE INTERNATIONAL NOT TO SCALE
 115 BESTWOOD DRIVE 5/8/19
 CLAYTON, NC 27520 BY: KFD
 PH: 919-550-2699 FAX: 919-550-0719

SIDE A





SIDE B

SIDE A



1H

SIDE B



FLAT TOP RANGE
 12" X 24"

STEAMER