



## Fire Marshal Division

June 6, 2019

Kyle Hydouke  
Erwin Chamber of Commerce  
100 West F Street  
Erwin, NC 28339

**Re: Blue Jean Boogie Event  
100 North 13<sup>th</sup> St.  
Erwin, NC 28339**

**Application Number – FMFW1906-0002**

**Dates Included for Permit Review – June 22, 2019; July 27, 2019**

To Whom It May Concern,

Thank you for submitting the plans for the Blue Jean Boogie Event. The plans have been carefully reviewed by a qualified code enforcement official to examine for full compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **Permits**

- A permit will be issued for the special assembly that will include the event as a whole.
- A permit may be issued for other tent areas if the individual tent exceeds 800 ft<sup>2</sup> or the aggregate area of multiple canopies placed side by side without a fire break clearance of 12' that exceed 1800 ft<sup>2</sup>

- **Fire Extinguishers**

- Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.
- 2A-10B:C fire extinguisher shall be placed at tents/canopies with a travel distance not to exceed 100' from any fire extinguisher



- **2411.6 Outdoor cooking.**
  - Outdoor cooking that produces sparks or grease-laden vapors shall not be performed within 20 feet (6096 mm) from a tent, air-supported, air-inflated or tensioned membrane structure, temporary membrane structure or canopy
  - Cooking is permitted under flame resistant tents meeting NPFA 701 Flame Propagation Standard with a minimum separation of 20' from lot lines, buildings, parked vehicle, other tents and membrane structures.
  
- **2411.5 Cooking tents.**
  - Tents where cooking is performed shall be separated from other tents, air-supported, air-inflated or tensioned membrane structures, temporary membrane structures or canopies by a minimum of 20 feet (6096 mm).
  
- **2415 Generators**
  - Generators and other internal combustion power sources shall be separated from tents, air-supported, air-inflated or tensioned membrane structures, temporary membrane structures or canopies by a minimum of 20 feet (6096 mm) and shall be isolated from contact with the public by fencing, enclosure or other approved means.
  
- **2413.3 Refueling.**
  - Refueling shall be performed in an approved location not less than 20 feet (6096 mm) from tents, air-supported, air-inflated or tensioned membrane structures, temporary membrane structures or canopies.
  
- **2406.4 Combustible materials.**
  - Hay, straw, shavings or similar combustible materials shall not be located within any tent or air-supported structure containing an assembly occupancy, except the materials necessary for the daily feeding and care of animals. Sawdust and shavings utilized for a public performance or exhibit shall not be prohibited provided the sawdust and shavings are kept damp. Combustible materials shall not be permitted under stands or seats at any time. The areas within and adjacent to the tent or air-supported structure, shall be maintained clear of all combustible materials or vegetation that could create a fire hazard within 20 feet (6096 mm) from the structure.



Combustible trash shall be removed at least once a day from the structure during the period the structure is occupied by the public.

- **Permits**

- Final inspection will be conducted the day of the event and the permit will be issued after inspection.

Thank you again for submitting the plans for special event. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal