



Reviewed For Code Compliance By:  
**D. Banks Wallace**  
 Chief Deputy Fire Marshal  
 07/18/2019 1:53:58 PM

**LEGEND**  
 [Symbol] 1-HR FIRE RATED CEILING

**WALL LEGEND: (SEE ARCH. PLANS FOR INFO)**  
 [Symbol] 1-HR FIRE RATED PARTITION  
 [Symbol] 1-HR FIRE RATED SMOKE BARRIER  
 [Symbol] SMOKE PARTITION

**REVISIONS**

**LIGHTHOUSE ENGINEERING**  
 400 W. Morgan Street, Suite 100  
 Raleigh, North Carolina, 27603  
 Tel: 919.833.9751 Fax: 919.833.9754

**NORTH CAROLINA STATE OF AUTHORITY**  
 Lighthouse Engineering, PA  
 No. C-2714

**NORTH CAROLINA PROFESSIONAL SEAL**  
 26886  
 ENGINEER  
 PAUL S. SCOTT  
 08/31/19

**Stogner Architecture, PA**  
 ARCHITECTURE - CONSTRUCTION MANAGEMENT - DESIGN BUILD  
 615 East Broad Avenue, Rockingham, North Carolina, 28379  
 Phone 910-895-6874 Fax 910-895-1111

**GOOD HOPE HOSPITAL**  
 ADDITION and RENOVATIONS  
 410 DENIM DRIVE  
 ERWIN, NORTH CAROLINA

**FIRE ALARM PLAN**

COMM. NO.: 4535  
 DRAWN BY: JRS  
 CHECKED BY: PSS  
 DATE: MAY 6, 2019  
 SHEET NO. FA1.0

**1 FIRE ALARM - FLOOR PLAN**  
 1/8"=1'-0"

**GENERAL NOTES:**

- SMOKE DETECTORS SHALL GENERATE LOCAL ALARM AND NOTIFICATION MESSAGE TO STAFF VIA LOW VOLTAGE COMMUNICATION SYSTEM.
- PRIVATE SIGNALING MODE SHALL BE USED IN THE PATIENT CARE UNITS.
- COORDINATE ALL DEVICE LOCATIONS (INCLUDING CEILING DEVICES) WITH OTHER TRADES TO KEEP CONFLICTS TO A MINIMUM.
- COORDINATE EXACT LAYOUT OF SPRINKLER RISER ROOM 109 WITH SPRINKLER CONTRACTOR.
- COORDINATE QUANTITY AND LOCATION OF ALL TAMPER, FLOW, AND MONITORED POINTS ON GENERATOR WITH SPRINKLER CONTRACTOR.
- VERIFY PULLSTATION LOCATIONS WITH LOCAL FIRE MARSHAL PRIOR TO ROUGH-IN.

**TAGGED NOTES:**

- AIR HANDLER LOCATED ON MECHANICAL PLATFORM ABOVE. SEE MECHANICAL PLANS FOR FURTHER INFORMATION.
- CONFIRM LOCATION AND CONNECTION REQUIREMENTS WITH E.C.

05/21/2019 10:46 AM  
 05/21/2019 10:46 AM