



## Fire Marshal Division

August 2, 2019

**Re: Town of Lillington Summer Concert  
106 W. Front St.  
Lillington, NC 27546**

**Application Number FMFW1907-0005**

To Whom It May Concern,

Thank you for submitting the plans for the summer celebration. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.


- **Permits**
  - A permit will be issued for the special assembly that will include the event as a whole.
  - A permit may be issued for other tent areas if the stage exceeds 400 square feet.
  
- **Fire Extinguishers**
  - Portable fire extinguishers shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.
  - 2A-10B:C fire extinguisher shall be placed at tents/canopies with a travel distance not to exceed 100' from any fire extinguisher
  
- **Permits**
  - Final inspection will be conducted that day of the event and the permit will be issued

Thank you again for submitting the plans for the summer celebration. Please review the plans and adhere to any notes and alterations that were made in addition to the original



drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal