



**ENGINEERING**

Tel 919.647.0000 Fax 919.715.0067

MIKE CAUSEY, INSURANCE COMMISSIONER & STATE FIRE MARSHAL  
BRIAN TAYLOR, CHIEF STATE FIRE MARSHAL

July 26, 2019

Little Diversified Architectural Consulting  
410 Blackwell St. # 10  
Durham, NC 27701

**RE: Harnett County Government Resource and Library  
Lillington, NC – Harnett County**

Preliminary Plans relative to the above project have been reviewed for general compliance with the 2018 North Carolina Building Code with the following comments:

1. Harnett County DSS Addition square footage is less than 20,000 sq. ft, and NCDOI is not required to be reviewed per GS 58-31-40. NCDOI is only required to review city county owned additions/new constructions with 20,000 sq. ft or more.
2. When available, provide sprinkler plans, hydraulic calculations and a current water flow test report. Plans and cover sheets of hydraulic calculations are to be legibly signed, certified and dated by a NICET Level III sprinkler designer.
3. Please provide a written response to the review comments and submit revised signed, sealed plans as necessary.

This project is approved for foundation and shell permits only at this moment. We will await further information from you regarding this project.

Sincerely,

A handwritten signature in black ink that reads "Natalia Santiago, PE".

Natalia Santiago, PE

NS/Imm

CC: Harnett County

**OFFICE OF STATE FIRE MARSHAL**

1202 MAIL SERVICE CENTER | RALEIGH, NC 27699-1202 | [WWW.NCDOI.COM/OSFM](http://WWW.NCDOI.COM/OSFM)