



Fire Marshal Division

August 6, 2019

George Wenrich
127 Hay Street
Fayetteville, NC 28301

**Re: YMCA of Harnett County
107 Carletta Cagle Drive
Cameron, NC 28326**

Application Number FMFW1907-0008

To Whom It May Concern,

Thank you for submitting the plans for the fire alarm plans. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the facility can be given. These items are outlined and described below.

- **Fire Alarm System Upgrade Notes**

All items in notes are to be completed at the time of final.

- Provide a record of completion.
 - The Fire marshal's office will complete an acceptance test at completion of project.
 - Provide a copy of account history after the acceptance test is completed and approve.
 - Provide an accurate zone map at the FACP and remote annunciator panel.
 - All work/installation shall be compliant with the NCSFC and NFPA 72.
 - Call Fire Marshal's office to schedule the fire alarm acceptance test. (910-984-4003)
- **Notes**
 - **All additions to existing systems shall properly communicate to existing fire panel.**
 - **A fire alarm construction permit is required.**



- **Please schedule all inspections through the Fire Marshal's Office.
910-984-4003.**

Thank you again for submitting the plans for the fire alarm plans. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. If you have any questions, please do not hesitate to call this office.

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal