



Harnett County Emergency Services

Office of the Fire Marshal

PO Box 370

Lillington, NC 27546

(910) – 893 – 7580

Date: 9/3/2019 Time: 1:00pm

Occupancy: **Erwin Elementary Demolition**
301 S. 10th St.
Erwin, NC 28339

Removal of Fuel Tank(s)

On the above date and time, a Fuel Tank(s) Removal witnessed at the above location revealed no violations of the N.C. State Fire Code. Upon completion of the engineering report containing the results of soil tests and other applicable data, a copy shall be submitted to this office for review. A bill of lading concerning the final disposition of tanks shall also be submitted.

Contractor Removing Fuel Tank(s): Terracon

Number of Tanks: 5 AGST UGST

#1 Contents	Fuel Oil	Method of Purge	LEL Recorded	0
#2 Contents	Fuel Oil	Method of Purge	LEL Recorded	0
#3 Contents	Fuel Oil	Method of Purge	LEL Recorded	0
#4 Contents	Fuel Oil	Method of Purge	LEL Recorded	0

Notes: Tanks 1 and 2 removed 8/23/19; tanks 3 and 4 removed 8/27/19; tank 5 was not discovered and removed until 9/3/19; Fee still remains for tank 5

Thank you for your cooperation.

D. Banks Wallace
Inspector

The Harnett County Fire Marshal's Division is committed to providing our community with a professional fire and life safety program through comprehensive fire protection plan reviews, informative occupancy inspections, effective fire and life safety code enforcement, and definitive fire origin and cause investigations in order to reduce the loss of life and property of the citizens of Harnett County. We will strive to maintain an unmatched level of professionalism and support to our community.