



Fire Marshal Division

October 10, 2019

Jason Wangelin
Campbell University
PO Box 535
Buies Creek, NC 27506

**Re: Campbell University Tent
17 J Winston Pearce Lane
Lillington, NC 27546**

Application Number FMFW1910-0003

To Whom It May Concern,

Thank you for submitting the plans for the tent. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **Fire Extinguishers**
 - Properly install/hang the required fire extinguishers (2).
 - Fire extinguishers shall have a minimum rating of 2A10:BC
 - Fire extinguishers shall be tagged by a fire extinguisher company.
- **Exits**
 - Exits shall be clearly identified by approved exit signs.
 - The required exits shall be maintained at all times to the public way.
- **Open Flames**
 - No open flame devices are allowed under the tent.
- **Generators**
 - Generators shall be separated from the tent by a minimum of 20 feet.
 - Generators shall be isolated from public contact by approved means.



- **Access**
 - Tent shall be placed to allow approved fire apparatus access in the event of an emergency.

- **Notes**
 - Please contact the Fire Marshal's Office for all fire inspections.
 - The required tent permit will be issued onsite.
 - Contact # **910-893-0742**

Thank you again for submitting the plans for the tent. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal