



## Fire Marshal Division

December 12, 2019

Mark Johnson C & G Builders  
1603 S. Hollybrook Road  
Wendell, NC 27591

**RE: Carlie C's IGA Addition**  
**333 N. Raleigh St.**  
**Angier, NC 27501**

**Re: Application Number – FMFW1911-0004**

To Whom It May Concern,

Thank you for submitting plans for the building addition. The plans have been reviewed by a qualified code enforcement official for compliance with the North Carolina Fire Prevention code and all other fire protection regulations. The following are items that will need to be addressed before a final inspection of this project can be completed. The items are listed and described below.

- **505.1 Physical Address**
  - The physical address of the building shall be posted in a conspicuous place so that it can be seen on approach from the road, access road, and/or parking lot.
  - The numbers used to make up the physical address shall be at least 5 inches in height.
  
- **906.1 Fire Extinguishers**
  - Fire extinguishers shall be placed in approved locations and may be field verified on final inspection. The fire extinguishers provided shall have a minimum rating of 2A 10 B: C.
  - Fire extinguisher shall be installed not to exceed 75' distance of travel.



- **1006.1 / 1006.2 Emergency Illumination**
  - Emergency illumination is required to meet minimum foot candle illumination for all portions of the means of egress, including the exit discharge.
- **1011 Exit Signs**
  - Exit signs shall be installed at all required exits. Exit signs shall meet all provisions of chapter 10.
- **506.1 Knox Box**
  - A Knox box is required to be installed on the building.
  - An application /order form has been attached to the review comments.
    - <https://www.knoxbox.com/commercial-knox-boxes/>
- **907.1.2 Fire Alarm System Shop Drawings**
  - Shop drawings from the licensed installing contractor shall be submitted prior to work beginning.
  - A rough in inspection is required.
  - A final acceptance test is required. (100%)
- **Notes**
  - Please clarify why the 1/3 diagonal distance for a remote exit has not been met.
  - Please note a manual fire alarm system is required by section 907.2.7 of the NC Fire Prevention Code 2018 edition.
  - Please contact the Fire marshal's office to schedule fire final inspection when work is complete, 910-893-0742

Thank you again for your submission of plans for the building addition. These remarks are for the plans that were submitted and its original intent. If you have any questions, please do not hesitate to contact me. We look forward to working with you during the construction period.

Sincerely,



D. Banks Wallace  
Chief Deputy Fire Marshal



**Harnett**  
C O U N T Y  
NORTH CAROLINA



Emergency Services Department

[www.harnett.org](http://www.harnett.org)