



Fire Marshal Division

June 15, 2020

Patterson Group Services, Inc.
Attn: Greg Patterson
229 Carthage St.
Sanford, NC 27330

**Re: Harnett County Government Center
455 McKinney Pkwy.
Lillington, NC 27546**

Re: Application Number – FMFW2006-0003

To Whom It May Concern,

Thank you for submitting the fire alarm plans. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

Fire Alarm System Plan Review Notes:

- **Public and common areas**
 - Visible alarm notification appliances shall be provided in public areas and common areas.
 - Notification devices required in meeting room and conference room.
 - Sound pressures shall comply with 907.6.2.1.1 – 907.6.2.1.2 of the NCFPC, current edition.

All items in plan review notes are to be completed at the time of final.

- Provide coverage for the second floor flex space as covered on the first floor to provide early notification since the space will not be initially occupied.
- Provide a record of completion.



- Provide a signed monitoring agreement.
- Provide a copy of pretest history from the central station.
- The Fire Marshal's office will complete an acceptance test at completion of project. (100%)
- Provide a copy of account history after the acceptance test is completed and approve.
- Provide an accurate zone map at the FACP and remote annunciator panel.
- All work/installation shall be compliant with the NCSFC and NFPA 72.
- Call Fire Marshal's office to schedule the fire alarm acceptance test. (910-893-0742)

Thank you again for submitting fire alarm plans. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office.

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal