



Standby Battery Calculation NFS2-640 Fire Alarm Control Panel

Protected Premises: Harnett County Government Services Center **Date:** 6/12/2020
Address: 302 W Cornelius Harnett Blvd.
City: Lillington **State:** NC **Zip:** 27546

Prepared By: Patterson Group Services **Phone:** (919) 776-2403
City: Sanford **State:** NC

Panel ID: FACP **Location:** Electrical 135

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
CPU2-640 Main Board	1	0.250000	0.250000	0.250000	0.250000
# NACs in use	1	0.035000	0.035000	0.035000	0.035000
KDM-R2 Display (Backlight on)	1	0.100000	0.100000	0.100000	0.100000
ACM-24AT Panel Switches	1	0.016000	0.016000	0.070000	0.070000
FDU-80 LCD Remote Annunciator	3	0.064300	0.192900	0.064300	0.192900
UDACT-2 Communicator	1	0.052000	0.052000	0.087000	0.087000
SLE-CDMA-Fire Starlink Cellular Comm.	1	0.071000	0.071000	0.200000	0.200000
FSP-951 Photoelectric Detector	26	0.000200	0.005200	0.004500	0.117000
FST-951R Thermal Detector-135 w/ ROR	4	0.000200	0.000800	0.004500	0.018000
DNR Duct Detector w/FSP-951R	14	0.000200	0.002800	0.004500	0.063000
RTS151KEY	14	0.000000	0.000000	0.012000	0.168000
FMM-1 Monitor Module	13	0.000375	0.004875	0.005000	0.065000
FRM-1 Relay Module	12	0.000255	0.003060	0.006500	0.078000
NBG-12LX Manual Pull Station	8	0.000375	0.003000	0.005000	0.040000
ISO-X Isolator Module	8	0.000450	0.003600	0.001700	0.013600
NAC #4 Current Draw-Trigger FCPS-24S8	4	0.000000	0.000000	0.020000	0.080000
Total Standby:			0.740	Total Alarm:	1.578

Secondary Load Requirements **21.48** **Amp Hours**

Total Secondary Load from the calculation table below.

Current Draw (Amps)	Time (Hours)	Total (AH)
Secondary Standby Load 0.740	Required Standby Time	
	24	17.77
Secondary Alarm Load 1.578	Required Alarm Time	
	0.084	0.13
Total Secondary Load		17.90
Derating Factor		1.2
Secondary Load Requirements		21.48

Battery Selection **26** **Amp Hours**



Standby Battery Calculation FCPS-24S8 NAC Power Supply

Protected Premises: Harnett County Government Services Center **Date:** 6/12/2020
Address: 302 W Cornelius Harnett Blvd.
City: Lillington **State:** NC **Zip:** 27546

Prepared By: Patterson Group Services **Phone:** (919) 776-2403
City: Sanford **State:** NC

Panel ID: PS1 **Location:** Electrical 135

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
FCPS-24S8 Main Board	1	0.065000	0.065000	0.145000	0.145000
HWL	6	0.000000	0.000000	0.044000	0.264000
P2WL15	3	0.000000	0.000000	0.054000	0.162000
P2WL30	4	0.000000	0.000000	0.074000	0.296000
P2WL75	2	0.000000	0.000000	0.121000	0.242000
P2WL110	8	0.000000	0.000000	0.162000	1.296000
PC2WL15	1	0.000000	0.000000	0.071000	0.071000
PC2WL30	1	0.000000	0.000000	0.090000	0.090000
PC2WL75	3	0.000000	0.000000	0.143000	0.429000
PC2WL115	5	0.000000	0.000000	0.187000	0.935000
		Total Standby:		0.065	Total Alarm: 3.930

Secondary Load Requirements 2.27 Amp Hours

Total Secondary Load from the calculation table below.

Current Draw (Amps)		Time (Hours)	Total (AH)
Secondary Standby Load 0.065		Required Standby Time	
		24	1.56
Secondary Alarm Load 3.930		Required Alarm Time	
		0.084	0.33
Total Secondary Load			1.89
Derating Factor			1.2
Secondary Load Requirements			2.27

Battery Selection 7 Amp Hours



Standby Battery Calculation FCPS-24S8 NAC Power Supply

Protected Premises: Harnett County Government Services Center **Date:** 6/12/2020

Address: 302 W Cornelius Harnett Blvd.

City: Lillington **State:** NC **Zip:** 27546

Prepared By: Patterson Group Services **Phone:** (919) 776-2403

City: Sanford **State:** NC

Panel ID: PS2 **Location:** Jan. 147

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
FCPS-24S8 Main Board	1	0.065000	0.065000	0.145000	0.145000
HWL	3	0.000000	0.000000	0.044000	0.132000
P2WL15	5	0.000000	0.000000	0.054000	0.270000
P2WL30	4	0.000000	0.000000	0.074000	0.296000
P2WL110	5	0.000000	0.000000	0.162000	0.810000
PC2WL15	2	0.000000	0.000000	0.071000	0.142000
PC2WL30	5	0.000000	0.000000	0.090000	0.450000
PC2WL75	1	0.000000	0.000000	0.143000	0.143000
PC2WL115	2	0.000000	0.000000	0.187000	0.374000
SWL15	6	0.000000	0.000000	0.043000	0.258000
		Total Standby:		0.065	Total Alarm: 3.020

Secondary Load Requirements 2.18 **Amp Hours**

Total Secondary Load from the calculation table below.

Current Draw (Amps)		Time (Hours)	Total (AH)
Secondary Standby Load 0.065		Required Standby Time	
		24	1.56
Secondary Alarm Load 3.020		Required Alarm Time	
		0.084	0.25
Total Secondary Load			1.81
Derating Factor			1.2
Secondary Load Requirements			2.18

Battery Selection 7 **Amp Hours**



Standby Battery Calculation FCPS-24S8 NAC Power Supply

Protected Premises: Harnett County Government Services Center **Date:** 6/12/2020
Address: 302 W Cornelius Harnett Blvd.
City: Lillington **State:** NC **Zip:** 27546

Prepared By: Patterson Group Services **Phone:** (919) 776-2403
City: Sanford **State:** NC

Panel ID: PS3 **Location:** Jan. 276

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
FCPS-24S8 Main Board	1	0.065000	0.065000	0.145000	0.145000
HWL	1	0.000000	0.000000	0.044000	0.044000
P2WL15	5	0.000000	0.000000	0.054000	0.270000
P2WL30	4	0.000000	0.000000	0.074000	0.296000
P2WL110	5	0.000000	0.000000	0.162000	0.810000
PC2WL15	2	0.000000	0.000000	0.071000	0.142000
PC2WL30	6	0.000000	0.000000	0.090000	0.540000
PC2WL75	3	0.000000	0.000000	0.143000	0.429000
SWL15	6	0.000000	0.000000	0.043000	0.258000
Total Standby:			0.065	Total Alarm:	2.934

Secondary Load Requirements 2.17 **Amp Hours**

Total Secondary Load from the calculation table below.

Current Draw (Amps)		Time (Hours)	Total (AH)
Secondary Standby Load 0.065		Required Standby Time	
		24	1.56
Secondary Alarm Load 2.934		Required Alarm Time	
		0.084	0.25
Total Secondary Load			1.81
Derating Factor			1.2
Secondary Load Requirements			2.17

Battery Selection 7 **Amp Hours**



Standby Battery Calculation FCPS-24S8 NAC Power Supply

Protected Premises: Harnett County Government Services Center **Date:** 6/12/2020

Address: 302 W Cornelius Harnett Blvd.

City: Lillington **State:** NC **Zip:** 27546

Prepared By: Patterson Group Services **Phone:** (919) 776-2403

City: Sanford **State:** NC

Panel ID: PS4 **Location:** Mech./Elec. 257

System Device	Qty	Standby Current Draw		Alarm Current Draw	
		Draw	Standby	Draw	Alarm
FCPS-24S8 Main Board	1	0.065000	0.065000	0.145000	0.145000
HWL	2	0.000000	0.000000	0.044000	0.088000
P2WL15	5	0.000000	0.000000	0.054000	0.270000
P2WL30	11	0.000000	0.000000	0.074000	0.814000
P2WL110	8	0.000000	0.000000	0.162000	1.296000
PC2WL15	8	0.000000	0.000000	0.071000	0.568000
PC2WL75	2	0.000000	0.000000	0.143000	0.286000
SWL15	1	0.000000	0.000000	0.043000	0.043000
		Total Standby:		0.065	Total Alarm:
					3.510

Secondary Load Requirements 2.23 **Amp Hours**

Total Secondary Load from the calculation table below.

Current Draw (Amps)		Time (Hours)	Total (AH)
Secondary Standby Load 0.065		Required Standby Time	
		24	1.56
Secondary Alarm Load 3.510		Required Alarm Time	
		0.084	0.29
Total Secondary Load			1.85
Derating Factor			1.2
Secondary Load Requirements			2.23

Battery Selection 7 **Amp Hours**

