



Fire Marshal Division

June 30, 2020

Eric Brewington
135 Green Level Drive
Angier, NC 27501

RE: Afterburner Cigar Lounge
506 W. Front St.
Lillington, NC 27546

Application Number – FMFW2006-0006

To Whom It May Concern,

Thank you for submitting the plans for the cigar lounge. The plans have been carefully reviewed by a qualified code enforcement official to examine for full compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the new facility can be given. These items are outlined and described below.

- **Fire Extinguishers**
 - Fire extinguishers shall be placed not to exceed 75' of travel distance.
 - The fire extinguishers provided shall have a minimum rating of 2A 10B: C and shall not be installed higher than 5 feet above the finished floor.
 - In addition to the above extinguishers, a portable fire extinguisher shall be provided within a 30-foot (9144 mm) travel distance of commercial-type cooking equipment. Cooking equipment involving vegetable or animal oils and fats shall be protected by a Class K rated portable extinguisher.

- **Emergency Lighting**
 - All emergency lighting, provided prior to up fit, shall be in proper operating condition at time of final inspection.
 - Any changes made in illumination requirements, due to equipment placement or storage arrangements shall be addressed before final inspection.
 - Emergency lighting is required for exit discharge at all labeled exits.



- **Knox Box**
 - Keys for the front entrance door shall be provided in a knox box for the premises. The knox box shall be installed near the front entrance on the outside of the building.

- **Physical Address (ie: suite Number if Applicable)**
 - The physical address of the building shall be posted in a conspicuous place so that it can be seen on approach from the road, access road, and/or parking lot.
 - The numbers used to make up the physical address shall be at least 6 inches in height.
 - The physical address needs to be posted on the rear of the building also.

- **Notes**
 - Occupant load should be calculated according to the NC 2018 Fire Prevention Code.
 - Please note travel distance from most remote point.
 - Please make a note of intent of use for second level
 - Please note the non-separated mixed use assembly area labeled “Sales and Sampling”

Thank you again for submitting the plans for the cigar lounge. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. These remarks are for the plans that were submitted and its original intent. These remarks do not apply if the original intent changes or what was submitted on the above date changes. If you have any questions, please do not hesitate to call this office

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal