



Fire Marshal Division

October 27, 2020

Cecil Peebles
P. O. Box 490
Lillington, NC 27546

**Re: Dr. Ken Rhea Vet Clinic
101 S. Main St.
Lillington, NC 27546**

Application Number FMFW2010-0005

To Whom It May Concern,

Thank you for submitting the plans for the building alterations. The plans have been carefully reviewed by a qualified code enforcement official to examine for compliance with the North Carolina Fire Prevention Code and all other fire protection regulatory documents. There are some items that were found during the plan review process that need to be addressed before a final inspection of the facility can be given. These items are outlined and described below.

- **Fire Extinguishers**

- Minimum of (1) 2A10:BC fire extinguisher shall be installed not to exceed 75' distance of travel.
- All Fire extinguishers shall be properly mounted and tagged by a fire extinguisher company.

- **Means of Egress Illumination**

- The means of egress, including the exit discharge, shall be illuminated at all time the building space is served by the means of egress is occupied.
 - Means of egress consist of three separate and distinct parts: the exit access, the exit and the exit discharge.
- The means of egress illumination shall not be less than 1 foot-candle at the walking surface.



- **Notes**

- **All additions to existing systems shall properly communicate to existing fire panel.**
- **A fire alarm construction permit is required.**
- **Please schedule all inspections through the Fire Marshal's Office. 910-893-0742.**

Thank you again for submitting the plans for the building alterations. Please review the plans and adhere to any notes and alterations that were made in addition to the original drawings. If you have any questions, please do not hesitate to call this office.

Again, thank you and we look forward to working with you during the construction period!

Sincerely,



D. Banks Wallace
Chief Deputy Fire Marshal