

Note 1: You are **fully responsible for verifying these calculations.**

Note 2: Use the dropdowns in the **yellow** cells to enter values.




ES-50X Battery Calculation

Secondary Power Source Requirements

Device	Standby Current (amps)				Secondary Alarm Current (amps)			
	Qty		Current Draw	Total	Qty		Current Draw	Total
Main Circuit Board	1	x	0.141000	= 0.141000	1	x	0.257000	= 0.257000
IPOTS-COM Communicator	1	x	0.040000	= 0.040000	1	x	0.041000	= 0.04100
4XTMF	0	x	0.005000	=	0	x	0.011000	=
EOLR-1	0	x	0.020000	=	0	x	0.020000	=
CELL-MOD-FL / CELL-CAB	0	x	0.055000	=	0	x	0.100000	=
ANN-BUS Devices								
ANN-SEC Card	0	x	0.003000	=	0	x	0.003000	=
ANN-80(-W)	1	x	0.015000	= 0.015000	1	x	0.040000	= 0.040000
ANN-100	0	x	0.020000	=	0	x	0.025000	=
ANN-(R)LED	0	x	0.028000	=	0	x	0.068000	=
ANN-RLY	0	x	0.015000	=	0	x	0.075000	=
ANN-I/O	0	x	0.035000	=	0	x	0.200000	=
ANN-I/O LED	0	x	0.000000	=	0	x	0.010000	=
ANN-S/PG	0	x	0.045000	=	0	x	0.045000	=
Addressable Devices								
BEAM355	0	x	0.002000	=				
BEAM355S	0	x	0.002000	=				
CP355	0	x	0.000300	=				
SD355CO	0	x	0.000300	=				
SD355	0	x	0.000300	=				
SD365	1	x	0.000300	= 0.000300				
SD355T	0	x	0.000300	=				
SD365T	0	x	0.000300	=				
H355	0	x	0.000300	=				
H365	0	x	0.000300	=				
H355HT	0	x	0.000300	=				
H365HT	0	x	0.000300	=				
H350R	0	x	0.000300	=				
H355R	0	x	0.000300	=				
H365R	0	x	0.000300	=				
D350RPL	0	x	0.000300	=				
D355PL	0	x	0.000300	=				
MMF-300	6	x	0.000400	= 0.002400				
MMF-300-10	0	x	0.003500	=				
MDF-300	0	x	0.000750	=				
MMF-301	0	x	0.000375	=				
MMF-302	0	x	0.000270	=				
MMF-302-6	0	x	0.002000	=				
BG-12LX	4	x	0.000230	= 0.000920				
CMF-300	0	x	0.000390	=				
CMF-300-6	0	x	0.002250	=				


CRF-300	0	x	0.000270	=						
CRF-300-6	0	x	0.001450	=						
CDRM-300	0	x	0.001300	=						
I300	0	x	0.000400	=						
ISO-6	0	x	0.002700	=						
B501BH-2	0	x	0.001000	=						
B501BHT-2	0	x	0.001000	=						
B224RB	0	x	0.000500	=						
B224BI	0	x	0.000450	=						
W-GATE	0	x	0.024000	=						
Maximum alarm draw for all Addressable devices ----->									0.20000	
Resettable Power										
4-Wire Smoke Detectors	0	x	0.000000	=		0	x	0.000000	=	
SWIFT Wireless										
W-GATE	0	x	0.040000	=		0	x	0.040000	=	
Auxiliary Power										
CMF-300 (Aux. Power)	0	x	0.001700	=		0	x	0.007000	=	
CMF-300-6 (Aux. Power)	0	x	0.008000	=		0	x	0.020000	=	
MMF-302 (Aux. Power)	0	x	0.012000	=		0	x	0.090000	=	
MMF-302-6 (Aux. Power)	0	x	0.050000	=		0	x	0.270000	=	
B200SR (Aux. Power)	0	x	0.000500	=		0	x	0.035000	=	
B200SR-LF (Aux. Power)	0	x	0.001000	=		0	x	0.125000	=	
Miscellaneous Devices										
	0	x	0.000000	=		0	x	0.000000	=	
	0	x	0.000000	=		0	x	0.000000	=	
	0	x	0.000000	=		0	x	0.000000	=	
	0	x	0.000000	=		0	x	0.000000	=	
	0	x	0.000000	=		0	x	0.000000	=	
Output Circuits										
NAC/Output #1			0.000000	=				0.532000	= 0.532000	
NAC/Output #2			0.000000	=				0.532000	= 0.532000	
FCPS (remote Sync)	0	x	0.000000	=		0	x	0.021700	=	
Total Standby Load					0.199620	Total Alarm Load				1.602000

		ES-50X Battery Calculation			
Calculation in Total Sheet					
			Required Standby Time in Hours		
			24 Hours		
Total Standby Current	0.1996 Amps	x	24	=	4.791 AH
			Required Alarm Time in Minutes		
			5 Minutes		
Total Alarm Load	1.6020 Amps	x	0.084	=	0.135 AH
Total Current Load					4.925 AH
Multiply by the Derating Factor			1.2	=	x 1.20
Total Ampere Hours Required					5.91 AH

Recommended Batteries:	BAT-1270 - 7AH Batteries
-------------------------------	---------------------------------

Battery Check
The batteries can be charged by the ES-50X Charger.
The batteries can be housed in the ES-50X Cabinet.

Current Draw Check
NAC#1 current is within the limitations of the circuit.
NAC#2 current is within the limitations of the circuit.
ES-50X current draw: The required output current is within the panel's limitations

	ES-50X Circuit Detail										
	NAC/Output #1										
Device	Qty		Non-Alarm Draw	=	Total	Qty		Alarm Draw	=	Total	
SCRL	6	x	0.000000	=	0.000000	6	x	0.041000	=	0.246000	
PC2RL	2	x	0.000000	=	0.000000	2	x	0.143000	=	0.286000	
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
Total Standby Load					0.000000	Total Alarm Load					0.532000

NAC/Output #2											
Device	Qty		Non-Alarm Draw	=	Total	Qty		Alarm Draw	=	Total	
SCRL	6	x	0.000000	=	0.000000	6	x	0.041000	=	0.246000	
PC2RL	2	x	0.000000	=	0.000000	2	x	0.143000	=	0.286000	
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
	0	x	0.000000	=		0	x	0.000000	=		
Total Standby Load					0.000000	Total Alarm Load					0.532000

