

CERTIFICATE OF COMPLIANCE

Certificate Number 20170310-MH9061
Report Reference MH9061-20080528
Issue Date 2017-MARCH-10

Issued to: XERXES CORP
7901 XERXES AVE S
MINNEAPOLIS MN 55431-1253

**This is to certify that
representative samples of**

UNDERGROUND TANKS
SEE ADDENDUM PAGE for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

Standard for Glass-Fiber-Reinforced Plastic Underground
Storage Tanks for Petroleum Products, Alcohols, and
Alcohol-Gasoline Mixtures, UL 1316.
Standard for Reinforced Plastic Underground Tanks for
Flammable and Combustible Liquids, ULC-S615.

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20170310-MH9061
Report Reference MH9061-20080528
Issue Date 2017-MARCH-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product

6, 8, 10 and 12 ft. diameter Series DW-3 fiberglass reinforced plastic secondary containment tanks; 6, 8 and 10 ft. diameter Series DW-3 fiberglass reinforced plastic secondary containment compartment tanks; 6, 8, 10 and 12 ft. diameter Series TW-3 fiberglass reinforced plastic tertiary containment tanks; and 6, 8 and 10 ft. diameter Series TW-3 fiberglass reinforced plastic tertiary containment compartment tanks for petroleum products, for petroleum products and gasohols, or for petroleum products, alcohols and alcohol-gasoline mixtures.

CNL - 10 ft. diameter Series DW-3 fiberglass reinforced plastic secondary containment tanks and 10 ft. diameter Series DW-3 fiberglass reinforced plastic secondary containment compartment tanks petroleum products, oxygenated fuel blends and oxygenates



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

