

Carolina Fire Protection, Inc.
4055 Hodges Chapel Road
P.O. Box 250 (28335)
Dunn, NC 28334
910-892-1700


Job Name : Angier Black River FD New
Building : New Addition
Location : Angier, NC
System : 1
Contract : 21G592
Data File : NEW AREA 8-24-21.wxtmp
Date/Time : 08/24/2021 - 08:57 AM

Water Supply Curve

Carolina Fire Protection, Inc.
Angier Black River FD New

City Water Supply:
C1 - Static Pressure : 58
C2 - Residual Pressure: 29
C2 - Residual Flow : 980

Demand:
D1 - Elevation : 3.465
D2 - System Flow : 308.654
D2 - System Pressure : 37.034
Hose (Demand) : 250
D3 - System Demand : 558.654
Safety Margin : 10.713



Flow Summary - NFPA

Carolina Fire Protection, Inc.
 Angier Black River FD New

Page 4
 Date 8-24-21

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	58.0	29	980.0	47.747	558.65	37.034

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
1A	9.0	5.6	10.82	18.42	0.15	121
2A	9.0	5.6	10.59	18.22	0.15	100
3A	9.0	5.6	10.83	18.43	0.15	121
4A	9.0	5.6	10.57	18.21	0.15	60
5A	9.0	5.6	10.65	18.28	0.15	100
6A	9.0	5.6	10.85	18.45	0.15	75
7A	9.0	5.6	10.75	18.36	0.15	122
8A	9.0	5.6	10.68	18.3	0.15	122
9A	9.0	5.6	9.49	17.25	0.1	140
10A	9.0	5.6	10.21	17.9	0.1	140
11A	9.0	5.6	11.07	18.64	0.1	120
12A	9.0	5.6	9.51	17.27	0.1	140
13A	9.0	5.6	10.24	17.92	0.1	140
14A	9.0	5.6	11.1	18.66	0.1	120
15A	9.0	5.6	9.83	17.56	0.1	80
16A	9.0	5.6	10.43	18.09	0.1	80
17A	9.0	5.6	11.17	18.71	0.1	120
18A	9.0		20.28			
19A	9.0		20.28			
21A	9.0		20.28			
22A	9.0		20.28			
23A	9.0		20.28			
24A	9.0		20.28			
25A	9.0		20.28			
26A	9.0		20.5			
27A	9.0		20.5			
28A	9.0		20.5			
29A	9.0		20.5			
30A	9.0		20.5			
31A	9.0		20.5			
32A	9.0		20.63			
33A	9.0		20.63			
36A	9.0		20.63			
37A	9.0		20.63			
38A	9.0		20.63			
39A	9.0		20.63			
40A	9.0		20.63			
41A	9.0		20.79			
42A	9.0		20.79			
43A	9.0		20.79			
44A	9.0		20.79			
45A	9.0		20.79			

Flow Summary - NFPA

Carolina Fire Protection, Inc.
 Angier Black River FD New

Page 6
 Date 8-24-21

NODE ANALYSIS (cont.)

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
M1	10.0		15.49		
M2	10.0		15.51		
M3	10.0		15.52		
M4	10.0		15.54		
M5	10.0		15.62		
M7	10.0		16.0		
M8	10.0		16.03		
M9	10.0		16.15		
M6	10.0		15.87		
M10	10.0		16.71		
M11	10.0		19.54		
M12	10.0		19.84		
E	10.0		19.97		
M13	10.0		20.07		
M14	10.0		20.2		
M14A	10.0		20.36		
M15	10.0		21.68		
F1	18.0		22.08		
F2	18.0		22.08		
F3	18.0		22.07		
F4	18.0		22.05		
F5	18.0		22.03		
F6	18.0		22.01		
F7	18.0		22.01		
N1	18.0		22.23		
N2	18.0		22.23		
N3	18.0		22.23		
M16	18.0		22.24		
N4	18.0		22.15		
N5	18.0		21.95		
N6	18.0		21.73		
BASR	1.0		35.47	250.0	
TEST	1.0		37.03		

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
Angier Black River FD New

Page 8
Date 8-24-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
10			0.0 17.90						13.724		K Factor = 4.83	
11A to 11	9 10	5.60	18.64	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	11.074 -0.433 4.248		Vel = 6.92	
11			0.0 18.64						14.889		K Factor = 4.83	
12A to 12	9 10	5.60	17.27	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	9.508 -0.433 3.689		Vel = 6.41	
12			0.0 17.27						12.764		K Factor = 4.83	
13A to 13	9 10	5.60	17.92	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	10.239 -0.433 3.950		Vel = 6.65	
13			0.0 17.92						13.756		K Factor = 4.83	
14A to 14	9 10	5.60	18.66	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	11.100 -0.433 4.257		Vel = 6.93	
14			0.0 18.66						14.924		K Factor = 4.83	
15A to 15	9 10	5.60	17.56	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	9.829 -0.433 3.804		Vel = 6.52	
15			0.0 17.56						13.200		K Factor = 4.83	
16A to 16	9 10	5.60	18.09	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	10.432 -0.433 4.019		Vel = 6.72	
16			0.0 18.09						14.018		K Factor = 4.83	
17A to 17	9 10	5.60	18.71	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	11.168 -0.433 4.280		Vel = 6.95	
17			0.0 18.71						15.015		K Factor = 4.83	
18A to 18	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	20.276 -0.433 0.0		Vel = 0	
18			0.0 0.0						19.843		K Factor = 0	
19A to 19	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120	20.276 -0.433 0.0		Vel = 0	
19			0.0 0.0						19.843		K Factor = 0	

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
Angier Black River FD New

Page 10
Date 8-24-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
			0.0						20.067		K Factor = 0	
30			0.0									
31A to 31	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120 0	20.500 -0.433 0.0		Vel = 0	
31			0.0						20.067		K Factor = 0	
31			0.0									
32A to 32	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	3.000 36.200 39.200	120 0	20.634 -0.433 0.0		Vel = 0	
32			0.0						20.201		K Factor = 0	
32			0.0									
33A to 33	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	3.000 36.200 39.200	120 0	20.634 -0.433 0.0		Vel = 0	
33			0.0						20.201		K Factor = 0	
33			0.0									
36A to 36	9 10		0.0	1	T	5.0	3.000 5.000 8.000	120 0	20.634 -0.433 0.0		Vel = 0	
36			0.0						20.201		K Factor = 0	
36			0.0									
37A to 37	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120 0	20.634 -0.433 0.0		Vel = 0	
37			0.0						20.201		K Factor = 0	
37			0.0									
38A to 38	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120 0	20.634 -0.433 0.0		Vel = 0	
38			0.0						20.201		K Factor = 0	
38			0.0									
39A to 39	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120 0	20.634 -0.433 0.0		Vel = 0	
39			0.0						20.201		K Factor = 0	
39			0.0									
40A to 40	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120 0	20.634 -0.433 0.0		Vel = 0	
40			0.0						20.201		K Factor = 0	
40			0.0									
41A to 41	9 10		0.0	1	Vcfi T E	29.2 5.0 2.0	1.000 36.200 37.200	120 0	20.790 -0.433 0.0		Vel = 0	
41			0.0						20.357		K Factor = 0	
41			0.0									

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
Angier Black River FD New

Page 12
Date 8-24-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M1			0.0 18.22						15.493		K Factor = 4.63	
3 to M2	10 10		18.43 18.43	1 1.049	T	5.0	3.500 5.000 8.500	120 0.1118	14.557 0.0 0.950		Vel = 6.84	
M2			0.0 18.43						15.507		K Factor = 4.68	
4 to 5	10 10		18.21 18.21	1 1.049			1.000 1.000	120 0.1100	14.209 0.0 0.110		Vel = 6.76	
5 to M3	10 10		18.28 36.49	1.25 1.38	T	6.0	5.500 6.000 11.500	120 0.1041	14.319 0.0 1.197		Vel = 7.83	
M3			0.0 36.49						15.516		K Factor = 9.26	
6 to M4	10 10		18.45 18.45	1 1.049	T	5.0	3.500 5.000 8.500	120 0.1121	14.585 0.0 0.953		Vel = 6.85	
M4			0.0 18.45						15.538		K Factor = 4.68	
7 to M5	10 10		18.36 18.36	1 1.049	T	5.0	5.500 5.000 10.500	120 0.1111	14.456 0.0 1.167		Vel = 6.82	
M5			0.0 18.36						15.623		K Factor = 4.65	
8 to M5	10 10		18.30 18.3	1 1.049	T	5.0	6.500 5.000 11.500	120 0.1104	14.353 0.0 1.270		Vel = 6.79	
M5			0.0 18.30						15.623		K Factor = 4.63	
9 to 10	10 10		17.25 17.25	1 1.049			10.000 10.000	120 0.0990	12.734 0.0 0.990		Vel = 6.40	
10 to 11	10 10		17.90 35.15	1.25 1.38			12.000 12.000	120 0.0971	13.724 0.0 1.165		Vel = 7.54	
11 to M7	10 10		18.63 53.78	1.5 1.61	T	8.0	3.000 8.000 11.000	120 0.1007	14.889 0.0 1.108		Vel = 8.48	
M7			0.0 53.78						15.997		K Factor = 13.45	
12 to 13	10 10		17.27 17.27	1 1.049			10.000 10.000	120 0.0992	12.764 0.0 0.992		Vel = 6.41	
13 to 14	10 10		17.92 35.19	1.25 1.38			12.000 12.000	120 0.0973	13.756 0.0 1.168		Vel = 7.55	

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
Angier Black River FD New

Page 14
Date 8-24-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
D to C	10 10		0.0 0.0	1 1.049			7.000 7.000	120 0	19.966 0.0 0.0			Vel = 0
C to E	10 10		0.0 0.0	1.5 1.682	E 2T	4.95 19.799	54.000 24.749 78.749	120 0	19.966 0.0 0.0			Vel = 0
E			0.0 0.0						19.966			K Factor = 0
26 to 27	10 10		0.0 0.0	1 1.049			10.000 10.000	120 0	20.067 0.0 0.0			Vel = 0
27 to 28	10 10		0.0 0.0	1.25 1.38			7.500 7.500	120 0	20.067 0.0 0.0			Vel = 0
28 to 29	10 10		0.0 0.0	1.25 1.38			8.667 8.667	120 0	20.067 0.0 0.0			Vel = 0
29 to 30	10 10		0.0 0.0	1.5 1.61			20.500 20.500	120 0	20.067 0.0 0.0			Vel = 0
30 to 31	10 10		0.0 0.0	2 2.067			12.000 12.000	120 0	20.067 0.0 0.0			Vel = 0
31 to M13	10 10		0.0 0.0	2 2.067	T	10.0	8.000 10.000 18.000	120 0	20.067 0.0 0.0			Vel = 0
M13			0.0 0.0						20.067			K Factor = 0
32 to 33	10 10		0.0 0.0	1 1.049			10.000 10.000	120 0	20.201 0.0 0.0			Vel = 0
33 to 36	10 10		0.0 0.0	1.25 1.38			8.000 8.000	120 0	20.201 0.0 0.0			Vel = 0
36 to 37	10 10		0.0 0.0	1.25 1.38			5.333 5.333	120 0	20.201 0.0 0.0			Vel = 0
37 to 38	10 10		0.0 0.0	1.5 1.61			6.333 6.333	120 0	20.201 0.0 0.0			Vel = 0
38 to 39	10 10		0.0 0.0	1.5 1.61			7.000 7.000	120 0	20.201 0.0 0.0			Vel = 0
39 to 40	10 10		0.0 0.0	1.5 1.61			10.000 10.000	120 0	20.201 0.0 0.0			Vel = 0
40 to M14	10 10		0.0 0.0	2 2.067	T	10.0	18.000 10.000 28.000	120 0	20.201 0.0 0.0			Vel = 0

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
Angier Black River FD New

Page 16
Date 8-24-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M10			0.0 161.98						16.710		K Factor = 39.63	
M6 to M10	10 10		146.67	3			40.500	120	15.870 0.0			
M10 to M11	10 10		146.67	3.26			40.500	0.0207	0.840		Vel = 5.64	
M10 to M11	10 10		161.98	3	E	9.408	25.000 9.408	120	16.710 0.0			
M11 to M12	10 10		308.65	3.26			34.408	0.0822	2.828		Vel = 11.86	
M11 to M12	10 10		0.0	4	E	13.167	0.500 13.167	120	19.538 0.0			
M12 to E	10 10		308.65	4.26			13.667	0.0223	0.305		Vel = 6.95	
M12 to E	10 10		0.0	4			5.500	120	19.843 0.0			
E to M13	10 10		308.65	4.26			5.500	0.0224	0.123		Vel = 6.95	
E to M13	10 10		0.0	4			4.500	120	19.966 0.0			
M13 to M14	10 10		308.65	4.26			4.500	0.0224	0.101		Vel = 6.95	
M13 to M14	10 10		0.0	4			6.000	120	20.067 0.0			
M14 to M14A	10 10		308.65	4.26			6.000	0.0223	0.134		Vel = 6.95	
M14 to M14A	10 10		0.0	4			7.000	120	20.201 0.0			
M14A to M15	10 10		308.65	4.26			7.000	0.0223	0.156		Vel = 6.95	
M14A to M15	10 10		0.0	4	E	13.167	46.000 13.167	120	20.357 0.0			
M15 to N7	10 0		308.65	4.26			59.167	0.0223	1.321		Vel = 6.95	
M15 to N7	10 0		0.0	4	3E	39.501	111.000 39.501	120	21.678 4.331			
N7			308.65				150.501	0.0223	3.362		Vel = 6.95	
N7			0.0 308.65						29.371		K Factor = 56.95	
F1 to N1	18 18		10.80	2	2T	24.613	98.000 24.613	120	22.078 0.0			
F1 to N1	18 18		10.8	2.157			122.613	0.0012	0.153		Vel = 0.95	
N1			0.0 10.80						22.231		K Factor = 2.29	
F2 to N2	18 18		10.90	2	2T	24.613	98.000 24.613	120	22.076 0.0			
F2 to N2	18 18		10.9	2.157			122.613	0.0013	0.156		Vel = 0.96	
N2			0.0 10.90						22.232		K Factor = 2.31	
F3 to N3	18 18		11.24	2	2T	24.613	98.000 24.613	120	22.069 0.0			
F3 to N3	18 18		11.24	2.157			122.613	0.0013	0.165		Vel = 0.99	
N3			0.0 11.24						22.234		K Factor = 2.38	
F4 to N4	18 18		8.65	2	2T	24.613	98.000 24.613	120	22.054 0.0			
F4 to N4	18 18		8.65	2.157			122.613	0.0008	0.101		Vel = 0.76	

Final Calculations : Hazen-Williams

Carolina Fire Protection, Inc.
 Angier Black River FD New

Page 18
 Date 8-24-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	***** Notes *****
N4 to N5	18 18		8.65 -267.06	4 4.26			12.000 12.000	120 -0.0171	22.155 0.0 -0.205	Vel = 6.01
N5 to N6	18 18		-7.61 -274.67	4 4.26			12.000 12.000	120 -0.0180	21.950 0.0 -0.216	Vel = 6.18
N6 to N7	18 0		-14.97 -289.64	4 4.26			8.000 8.000	120 -0.0199	21.734 7.796 -0.159	Vel = 6.52
N7			0.0 -289.64						29.371	K Factor = -53.44
M16 to BASR	18 1		308.65 308.65	4 4.26	2E T 2F Zac	26.334 26.334 10.534 0.0	54.000 63.202 117.202	120 0.0223	22.236 10.615 2.617	* * Fixed Loss = 3.252 Vel = 6.95
BASR to TEST	1 1	H250	250.00 558.65	6 6.16	2E T G	40.168 43.037 4.304	100.000 87.509 187.509	140 0.0084	35.468 0.0 1.566	Vel = 6.01
TEST			0.0 558.65						37.034	K Factor = 91.80