

**. . . Fire Protection by Computer Design**

Reliable Fire Protection LLC  
32 Partin Rd.  
Dunn, NC 28334  
Robert Lawley  
NICET Level III #103122

Job Name : DRY HSW 3RD FLR BREEZEWAY- THE GROVES  
Building : 3 BEDROOM NEW RESIDENTIAL  
Location : 1585 E. CORNELIUS HARNETT BOULEVARD  
System : 1  
Contract : 21-208  
Data File : BREEZEWAY - DRY HSW 3RD FLR 5.6K.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - THE GROVE APARTMENTS AT 421 Date - 01-07-22  
 Location - 1585 E. CORNELIUS HARNETT BOULEVARD  
 Building - 3 BEDROOM NEW RESIDENTIAL System No. - 1  
 Contractor - HATCHERS CREEK, LLC Contract No. - 21-208  
 Calculated By - ROBERT LAWLEY Drawing No. - FP1  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height VARIES  
 OCCUPANCY - RESIDENTIAL NFPA 13R 2013

S Type of Calculation: ( )NFPA 13 Residential (X)NFPA 13R ( )NFPA 13D  
 Y Number of Sprinklers Flowing: ( )1 ( )2 ( )4 (X)3  
 S ( )Other  
 T ( )Specific Ruling Made by Date  
 E  
 M Listed Flow at Start Point - 15 Gpm System Type  
 Listed Pres. at Start Point - 7 Psi (X) Wet ( ) Dry  
 D MAXIMUM LISTED SPACING 14 x 14 ( ) Deluge ( ) PreAction  
 E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle  
 S Additional Flow Added - 0 Gpm Make TYCO Model DS-1  
 I Elevation at Highest Outlet - 28.333Feet Size 1/2 K-Factor 5.6  
 G Note:SAFETY MARGIN: 5.25 PSI Temperature Rating 155\*  
 N

Calculation Gpm Required 165.856 Psi Required 53.530 At Test  
 Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:  
 A Date of Test - 07-01-20 Rated Cap. Cap.  
 T Time of Test - 10:00 AM @ Psi Elev.  
 E Static (Psi) - 59 Elev.  
 R Residual (Psi) - 53 Other Well  
 Flow (Gpm) - 1000 Proof Flow Gpm  
 S Elevation - 0

P Location: US 421  
 P  
 L Source of Information: 4D SITE SOLUTIONS, INC.  
 Y


# Water Supply Curve C

Reliable Fire Protection LLC  
DRY HSW 3RD FLR BREEZEWAY- THE GROVES

Page 2  
Date 09-30-21

City Water Supply:  
C1 - Static Pressure : 59  
C2 - Residual Pressure: 53  
C2 - Residual Flow : 1000

Demand:  
D1 - Elevation : 12.271  
D2 - System Flow : 65.856  
D2 - System Pressure : 53.530  
Hose ( Demand ) : 100  
D3 - System Demand : 165.856  
Safety Margin : 5.254




# Flow Diagram

Reliable Fire Protection LLC  
DRY HSW 3RD FLR BREEZEWAY- THE GROVES

Page 3  
Date 09-30-21

---



# Fittings Used Summary

Reliable Fire Protection LLC  
 DRY HSW 3RD FLR BREEZEWAY- THE GROVES

Page 4  
 Date 09-30-21

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'ElI Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zwb	Watts 009	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC  
 DRY HSW 3RD FLR BREEZEWAY- THE GROVES

Page 5  
 Date 09-30-21

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
SW1	28.333	5.6	7.0	na	14.82	0.1	144	7.0
A1	28.333		7.45	na				
SW2	28.333	5.6	7.49	na	15.33	0.1	144	7.0
A2	28.333		7.97	na				
SW3	28.333	5.6	9.31	na	17.09	0.1	144	7.0
A3	28.333		9.9	na				
SW4	28.333	5.6	11.06	na	18.62	0.1	144	7.0
A4	28.333		11.74	na				
T1	29.167		7.52	na				
T2	29.167		8.07	na				
T3	29.167		10.1	na				
T4	29.167		12.05	na				
M4	29.167		12.97	na				
M5	29.167		13.41	na				
M6	29.167		14.06	na				
M7	19.167		18.72	na				
M8	9.167		23.39	na				
M9	9.167		24.0	na				
M10	9.167		25.03	na				
TOR	9.5		27.83	na				
BOR	1.0		35.95	na				
UG1	0.0		53.51	na				
UG3	0.0		53.52	na				
UG2	0.0		53.52	na				
TAP	0.0		53.53	na				
TEST	0.0		53.53	na	100.0			

The maximum velocity is 15.92 and it occurs in the pipe between nodes T3 and M4

# Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC  
 DRY HSW 3RD FLR BREEZEWAY- THE GROVES

Page 6  
 Date 09-30-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
SW1 to A1	28.333 28.333	5.60	14.82 14.82	1 1.049	1T	5.0 0.0 0.0	1.000 5.000 6.000	120 0.0747	7.000 0.0 0.448		Vel = 5.50	
A1 to T1	28.333 29.167		0.0 14.82	1 1.049	1T	5.0 0.0 0.0	0.833 5.000 5.833	120 0.0747	7.448 -0.361 0.436		Vel = 5.50	
T1			0.0 14.82						7.523		K Factor = 5.40	
SW2 to A2	28.333 28.333	5.60	15.33 15.33	1 1.049	1T	5.0 0.0 0.0	1.000 5.000 6.000	120 0.0795	7.490 0.0 0.477		Vel = 5.69	
A2 to T2	28.333 29.167		0.0 15.33	1 1.049	1T	5.0 0.0 0.0	0.833 5.000 5.833	120 0.0795	7.967 -0.361 0.464		Vel = 5.69	
T2			0.0 15.33						8.070		K Factor = 5.40	
SW3 to A3	28.333 28.333	5.60	17.09 17.09	1 1.049	1T	5.0 0.0 0.0	1.000 5.000 6.000	120 0.0973	9.314 0.0 0.584		Vel = 6.34	
A3 to T3	28.333 29.167		0.0 17.09	1 1.049	1T	5.0 0.0 0.0	0.833 5.000 5.833	120 0.0972	9.898 -0.361 0.567		Vel = 6.34	
T3			0.0 17.09						10.104		K Factor = 5.38	
SW4 to A4	28.333 28.333	5.60	18.62 18.62	1 1.049	1T	5.0 0.0 0.0	1.000 5.000 6.000	120 0.1140	11.060 0.0 0.684		Vel = 6.91	
A4 to T4	28.333 29.167		0.0 18.62	1 1.049	1T	5.0 0.0 0.0	0.833 5.000 5.833	120 0.1140	11.744 -0.361 0.665		Vel = 6.91	
T4			0.0 18.62						12.048		K Factor = 5.36	
*												
T1 to T2	29.167 29.167		14.82 14.82	1 1.101		0.0 0.0 0.0	14.000 0.0 14.000	150 0.0391	7.523 0.0 0.547		Vel = 4.99	
T2 to T3	29.167 29.167		15.32 30.14	1 1.101		0.0 0.0 0.0	14.000 0.0 14.000	150 0.1453	8.070 0.0 2.034		Vel = 10.16	
T3 to M4	29.167 29.167		17.09 47.23	1 1.101	1O	5.0 0.0 0.0	3.583 5.000 8.583	150 0.3336	10.104 0.0 2.863		Vel = 15.92	
M4			0.0 47.23						12.967		K Factor = 13.12	
T4 to M4	29.167 29.167		18.62 18.62	1 1.101	1O	5.0 0.0 0.0	10.417 5.000 15.417	150 0.0596	12.048 0.0 0.919		Vel = 6.27	
			0.0									

# Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC  
 DRY HSW 3RD FLR BREEZEWAY- THE GROVES

Page 7  
 Date 09-30-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M4 *			18.62					12.967		K Factor = 5.17	
M4 to M5	29.167 29.167		65.86	2	1O 10.0 0.0	3.375 10.000	150	12.967 0.0			
M5 to M6	29.167 29.167		65.86	2.003	0.0	13.375	0.0335	0.448		Vel = 6.71	
M5 to M6	29.167 29.167		0.0	2	1N 11.0 0.0	8.167 11.000	150	13.415 0.0			
M6 to M7	29.167 19.167		65.86	2.003	0.0	19.167	0.0334	0.641		Vel = 6.71	
M6 to M7	29.167 19.167		0.0	2	0.0	10.000	150	14.056 4.331			
M7 to M8	19.167 9.167		65.86	2.003	0.0	10.000	0.0335	0.335		Vel = 6.71	
M7 to M8	19.167 9.167		0.0	2	0.0	10.000	150	18.722 4.331			
M8 to M9	9.167 9.167		65.86	2.003	0.0	10.000	0.0335	0.335		Vel = 6.71	
M8 to M9	9.167 9.167		0.0	2	1O 10.0 0.0	8.167 10.000	150	23.388 0.0			
M9 to M10	9.167 9.167		65.86	2.003	0.0	18.167	0.0335	0.608		Vel = 6.71	
M9 to M10	9.167 9.167		0.0	2	1O 10.0 0.0	20.833 10.000	150	23.996 0.0			
M10 to TOR	9.167 9.500		65.86	2.003	0.0	30.833	0.0334	1.031		Vel = 6.71	
M10 to TOR	9.167 9.500		0.0	2	4N 44.0 0.0	43.917 44.000	150	25.027 -0.144			
TOR			65.86		0.0	87.917	0.0335	2.942		Vel = 6.71	
TOR *			0.0								
TOR			65.86					27.825		K Factor = 12.49	
TOR to BOR	9.500 1		65.86	2	1Fsp 1N 11.0	10.000 33.039	150	27.825 6.681		** Fixed Loss = 3	
TOR to BOR	9.500 1		65.86	2.003	1B 7.779	43.039	0.0335	1.441		Vel = 6.71	
TOR to BOR	9.500 1		0.0		1S 14.261						
BOR *			65.86					35.947		K Factor = 10.98	
BOR to UG1	1 0		65.86	2	3E 19.447 12.965	91.042 32.412	150	35.947 13.433		** Fixed Loss = 13	
BOR to UG1	1 0		65.86	2.003	1Zwb 0.0	123.454	0.0335	4.131		Vel = 6.71	
UG1 to UG3	0 0		-34.58	8	4F 54.365 6.041	745.000 60.405	150	53.511 0.0			
UG1 to UG3	0 0		31.28	7.98	1G 0.0	805.405	0	0.008		Vel = 0.20	
UG3 to UG2	0 0		0.0	8	1T 52.855 6.041	1.000 58.895	150	53.519 0.0			
UG3 to UG2	0 0		31.28	7.98	1G 0.0	59.895	0	0.001		Vel = 0.20	
UG2 *			0.0								
UG2			31.28					53.520		K Factor = 4.28	
UG1 to UG2	0 0		34.57	8	4F 54.365 12.081	600.000 119.302	150	53.511 0.0			
UG1 to UG2	0 0		34.57	7.98	2G 12.081	119.302	0	0.009		Vel = 0.22	
UG1 to UG2	0 0		0.0		1T 52.855	719.302	0	0.009			




# Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC  
 DRY HSW 3RD FLR BREEZEWAY- THE GROVES

Page 8  
 Date 09-30-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
UG2			34.57					53.520	K Factor = 4.73		
*											
UG2	0		65.86	8	1G	6.041	185.000	150	53.520		
to					1T	52.855	58.895		0.0		
TAP	0		65.86	7.98		0.0	243.895	0	0.010	Vel = 0.42	
TAP	0		0.0	20		0.0	170.000	140	53.530		
to						0.0	0.0		0.0		
TEST	0		65.86	20.57		0.0	170.000	0	0.0	Vel = 0.06	
			100.00							Qa = 100.00	
TEST			165.86					53.530	K Factor = 22.67		



**... Fire Protection by Computer Design**

Reliable Fire Protection LLC  
32 Partin Rd.  
Dunn, NC 28334  
Robert Lawley  
NICET Level III #103122

Job Name : SSP 3RD FLR COMMON AREA - THE GROVES  
Building : 3 BEDROOM NEW RESIDENTIAL  
Location : 1585 E. CORNELIUS HARNETT BOULEVARD  
System : 1  
Contract : 21-208  
Data File : COMMON AREA 3 HEADS - SSP 3RD FLR 5.8K.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - THE GROVE APARTMENTS AT 421 Date - 01-07-22  
Location - 1585 E. CORNELIUS HARNETT BOULEVARD  
Building - 3 BEDROOM NEW RESIDENTIAL System No. - 1  
Contractor - HATCHERS CREEK, LLC Contract No. - 21-208  
Calculated By - ROBERT LAWLEY Drawing No. - FP1  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height VARIES  
OCCUPANCY - RESIDENTIAL NFPA 13R 2013

S Type of Calculation: ( )NFPA 13 Residential (X)NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 ( )4 (X)3  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 20 Gpm System Type  
Listed Pres. at Start Point - 11.6 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 20 x 20 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle  
S Additional Flow Added - 0 Gpm Make TYCO Model LFII  
I Elevation at Highest Outlet - 28.333Feet Size 1/2 K-Factor 5.8  
G Note:SAFETY MARGIN: 7.21 PSI Temperature Rating 155\*  
N

Calculation Gpm Required 157.032 Psi Required 51.599 At Test  
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 07-01-20 Rated Cap. Cap.  
T Time of Test - 10:00 AM @ Psi Elev.  
E Static (Psi) - 59 Elev.  
R Residual (Psi) - 53 Other Well  
Flow (Gpm) - 1000 Proof Flow Gpm  
S Elevation - 0

P Location: US 421

P  
L Source of Information: 4D SITE SOLUTIONS, INC.  
Y


# Water Supply Curve C

Reliable Fire Protection LLC  
SSP 3RD FLR COMMON AREA - THE GROVES

Page 2  
Date 12-16-21

City Water Supply:  
C1 - Static Pressure : 59  
C2 - Residual Pressure: 53  
C2 - Residual Flow : 1000

Demand:  
D1 - Elevation : 12.271  
D2 - System Flow : 57.032  
D2 - System Pressure : 51.599  
Hose ( Demand ) : 100  
D3 - System Demand : 157.032  
Safety Margin : 7.206



# Flow Diagram

Reliable Fire Protection LLC  
SSP 3RD FLR COMMON AREA - THE GROVES

Page 3  
Date 12-16-21

---

18.2  
**P2** ← **2**  
↑  
/  
18.2  
**P3** ← **3**

20  
**P4** ← **4**

18.2  
**2** ← **3** ← **M2**  
37

20  
**4** ← **M3**

37                    57                    57                    57                    57                    57                    27.1  
**M2** ← **M3** ← **M5** ← **M6** ← **M7** ← **M8** ← **M9** ← **M10** ← **M11** ← **TOR** ← **BOR** ← **UG1** ← **UG3** ← **UG2**  
57                    57                    57                    57                    57                    27.1

29.9                    57  
**UG1** ← **UG2** ← **TAP** ← **TEST**  
57

# Fittings Used Summary

Reliable Fire Protection LLC  
SSP 3RD FLR COMMON AREA - THE GROVES

Page 4  
Date 12-16-21

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EI Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zwb	Watts 009	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC  
 SSP 3RD FLR COMMON AREA - THE GROVES

Page 5  
 Date 12-16-21

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
P2	28.333	5.8	9.87	na	18.22	0.05	324	9.6
P3	28.333	5.8	10.52	na	18.81	0.05	324	9.6
P4	28.333	5.8	11.89	na	20.0	0.05	400	11.6
2	29.167		9.96	na				
3	29.167		10.63	na				
4	29.167		12.58	na				
M2	29.167		13.72	na				
M3	29.167		13.83	na				
M5	29.167		14.27	na				
M6	29.167		14.74	na				
M7	19.167		19.32	na				
M8	9.167		24.17	na				
M9	9.167		24.66	na				
M10	9.167		25.15	na				
M11	9.167		25.47	na				
TOR	9.5		27.48	na				
BOR	1.0		34.99	na				
UG1	0.0		51.58	na				
UG3	0.0		51.59	na				
UG2	0.0		51.59	na				
TAP	0.0		51.6	na				
TEST	0.0		51.6	na	100.0			

The maximum velocity is 12.48 and it occurs in the pipe between nodes 3 and M2

# Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC  
 SSP 3RD FLR COMMON AREA - THE GROVES

Page 6  
 Date 12-16-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
P2 to 2	28.333 29.167	5.80	18.22 18.22	1 1.101	1N	7.0 0.0 0.0	0.833 7.000 7.833	150	9.869 -0.361 0.448		Vel = 6.14	
2			0.0 18.22						9.956		K Factor = 5.77	
P3 to 3	28.333 29.167	5.80	18.81 18.81	1 1.101	1N	7.0 0.0 0.0	0.833 7.000 7.833	150	10.519 -0.361 0.476		Vel = 6.34	
3			0.0 18.81						10.634		K Factor = 5.77	
P4 to 4	28.333 29.167	5.80	20.00 20.0	1 1.101	1N 1O	7.0 5.0 0.0	3.375 12.000 15.375	150	11.891 -0.361 1.046		Vel = 6.74	
4			0.0 20.00						12.576		K Factor = 5.64	
* 2 to 3	29.167 29.167		18.22 18.22	1 1.101		0.0 0.0 0.0	11.833 0.0 11.833	150	9.956 0.0 0.678		Vel = 6.14	
3 to M2	29.167 29.167		18.81 37.03	1 1.101	1N	7.0 0.0 0.0	7.500 7.000 14.500	150	10.634 0.0 3.084		Vel = 12.48	
M2			0.0 37.03						13.718		K Factor = 10.00	
* 4 to M3	29.167 29.167		20.00 20.0	1 1.101	1N	7.0 0.0 0.0	11.458 7.000 18.458	150	12.576 0.0 1.255		Vel = 6.74	
M3			0.0 20.00						13.831		K Factor = 5.38	
* M2 to M3	29.167 29.167		37.03 37.03	2 2.003		0.0 0.0 0.0	9.875 0.0 9.875	150	13.718 0.0 0.113		Vel = 3.77	
M3 to M5	29.167 29.167		20.00 57.03	2 2.003	1N	11.0 0.0 0.0	6.083 11.000 17.083	150	13.831 0.0 0.439		Vel = 5.81	
M5			0.0 57.03						14.270		K Factor = 15.10	
* M5 to M6	29.167 29.167		57.03 57.03	2 2.003	1O	10.0 0.0 0.0	8.167 10.000 18.167	150	14.270 0.0 0.465		Vel = 5.81	
M6 to M7	29.167 19.167		0.0 57.03	2 2.003		0.0 0.0 0.0	10.000 0.0 10.000	150	14.735 4.331 0.257		Vel = 5.81	
M7 to M8	19.167 9.167		0.0 57.03	2 2.003	1O	10.0 0.0 0.0	10.000 10.000 20.000	150	19.323 4.331 0.513		Vel = 5.81	




# Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC  
 SSP 3RD FLR COMMON AREA - THE GROVES

Page 7  
 Date 12-16-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M8 to M9	9.167 9.167		0.0 57.03	2 2.003	1N	11.0 0.0	8.167 11.000	150 0.0256	24.167 0.0			
						0.0	19.167		0.491	Vel =	5.81	
M9 to M10	9.167 9.167		0.0 57.03	2 2.003		0.0 0.0	19.000 0.0	150 0.0257	24.658 0.0			
						0.0	19.000		0.488	Vel =	5.81	
M10 to M11	9.167 9.167		0.0 57.03	2 2.003	1N	11.0 0.0	1.833 11.000	150 0.0256	25.146 0.0			
						0.0	12.833		0.329	Vel =	5.81	
M11 to TOR	9.167 9.500		0.0 57.03	2 2.003	4O	40.0 0.0	43.917 40.000	150 0.0256	25.475 -0.144			
						0.0	83.917		2.151	Vel =	5.81	
TOR			0.0 57.03						27.482	K Factor =	10.88	
* TOR to BOR	9.500 1		57.03 57.03	2 2.003	1Fsp 1B 1S	0.0 7.779 14.261	10.000 22.039 32.039	150 0.0257	27.482 6.681 0.822	** Fixed Loss =	3	
						0.0			0.822	Vel =	5.81	
BOR			0.0 57.03						34.985	K Factor =	9.64	
* BOR to UG1	1 0		57.03 57.03	2 2.003	3E 1T 1Zwb	19.447 12.965 0.0	91.042 32.412 123.454	150 0.0256	34.985 13.433 3.166	** Fixed Loss =	13	
						0.0	123.454		3.166	Vel =	5.81	
UG1 to UG3	0 0		-29.94 27.09	8 7.98	4F 1G	54.365 6.041	745.000 60.405	150 0	51.584 0.0			
						0.0	805.405		0.007	Vel =	0.17	
UG3 to UG2	0 0		0.0 27.09	8 7.98	1T 1G	52.855 6.041	1.000 58.895	150 0	51.591 0.0			
						0.0	59.895		0.0	Vel =	0.17	
UG2			0.0 27.09						51.591	K Factor =	3.77	
UG1 to UG2	0 0		29.94 29.94	8 7.98	4F 2G 1T	54.365 12.081 52.855	600.000 119.302 719.302	150 0	51.584 0.0 0.007			
						0.0	719.302		0.007	Vel =	0.19	
UG2			0.0 29.94						51.591	K Factor =	4.17	
* UG2 to TAP	0 0		57.03 57.03	8 7.98	1G 1T	6.041 52.855	185.000 58.895	150 0	51.591 0.0			
						0.0	243.895		0.008	Vel =	0.37	
TAP to TEST	0 0		0.0 57.03	20 20.57		0.0 0.0	170.000 0.0	140 0	51.599 0.0			
						0.0	170.000		0.0	Vel =	0.06	
TEST			100.00 157.03						51.599	Qa =	100.00	
										K Factor =	21.86	



**. . . Fire Protection by Computer Design**

Reliable Fire Protection LLC  
32 Partin Rd.  
Dunn, NC 28334  
Robert Lawley  
NICET Level III #103122

Job Name : SSP 3RD FLR BEDROOM - THE GROVES  
Building : 3 BEDROOM NEW RESIDENTIAL  
Location : 1585 E. CORNELIUS HARNETT BOULEVARD  
System : 1  
Contract : 21-208  
Data File : BEDROOM 1 HEAD - SSP 3RD FLR 5.8K.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - THE GROVE APARTMENTS AT 421 Date - 01-07-22  
Location - 1585 E. CORNELIUS HARNETT BOULEVARD  
Building - 3 BEDROOM NEW RESIDENTIAL System No. - 1  
Contractor - HATCHERS CREEK, LLC Contract No. - 21-208  
Calculated By - ROBERT LAWLEY Drawing No. - FP1  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height VARIES  
OCCUPANCY - RESIDENTIAL NFPA 13R 2013

S Type of Calculation: ( )NFPA 13 Residential (X)NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: (X)1 ( )2 ( )4 ( )  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 20 Gpm System Type  
Listed Pres. at Start Point - 11.6 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 20 x 20 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle  
S Additional Flow Added - 0 Gpm Make TYCO Model LFII  
I Elevation at Highest Outlet - 28.333Feet Size 1/2 K-Factor 5.8  
G Note:SAFETY MARGIN: 14.58 PSI Temperature Rating 155\*  
N

Calculation Gpm Required 120.008 Psi Required 44.299 At Test  
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 07-01-20 Rated Cap. Cap.  
T Time of Test - 10:00 AM @ Psi Elev.  
E Static (Psi) - 59 Elev.  
R Residual (Psi) - 53 Other Well  
Flow (Gpm) - 1000 Proof Flow Gpm  
S Elevation - 0

P Location: US 421  
P  
L Source of Information: 4D SITE SOLUTIONS, INC.  
Y


# Water Supply Curve C

Reliable Fire Protection LLC  
SSP 3RD FLR BEDROOM - THE GROVES

Page 2  
Date 12-16-21

City Water Supply:  
C1 - Static Pressure : 59  
C2 - Residual Pressure: 53  
C2 - Residual Flow : 1000

Demand:  
D1 - Elevation : 12.271  
D2 - System Flow : 20.008  
D2 - System Pressure : 44.299  
Hose ( Demand ) : 100  
D3 - System Demand : 120.008  
Safety Margin : 14.582




# Flow Diagram

Reliable Fire Protection LLC  
SSP 3RD FLR BEDROOM - THE GROVES

Page 3  
Date 12-16-21

---



# Fittings Used Summary

Reliable Fire Protection LLC  
 SSP 3RD FLR BEDROOM - THE GROVES

Page 4  
 Date 12-16-21

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'ElI Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zwb	Watts 009	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Reliable Fire Protection LLC  
 SSP 3RD FLR BEDROOM - THE GROVES

Page 5  
 Date 12-16-21

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
P1	28.333	5.8	11.9	na	20.01	0.05	400	11.9
1	29.167		12.51	na				
M1	29.167		14.4	na				
M2	29.167		14.45	na				
M3	29.167		14.48	na				
M5	29.167		14.54	na				
M6	29.167		14.61	na				
M7	19.167		18.96	na				
M8	9.167		23.3	na				
M9	9.167		23.32	na				
M10	9.167		23.34	na				
M11	9.167		23.39	na				
TOR	9.5		23.57	na				
BOR	1.0		30.41	na				
UG1	0.0		44.3	na				
UG3	0.0		44.3	na				
UG2	0.0		44.3	na				
TAP	0.0		44.3	na				
TEST	0.0		44.3	na	100.0			

The maximum velocity is 6.74 and it occurs in the pipe between nodes P1 and 1

# Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC  
 SSP 3RD FLR BEDROOM - THE GROVES

Page 6  
 Date 12-16-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
P1 to 1	28.333 29.167	5.80	20.01 20.01	1 1.101	1N 7.0 1O 5.0 0.0	2.250 12.000 14.250	150 0.0681	11.900 -0.361 0.970		Vel = 6.74	
1 *			0.0 20.01					12.509		K Factor = 5.66	
1 to M1	29.167 29.167		20.01 20.01	1 1.101	1O 5.0 0.0 0.0	22.833 5.000 27.833	150 0.0681	12.509 0.0 1.895		Vel = 6.74	
M1 *			0.0 20.01					14.404		K Factor = 5.27	
M1 to M2	29.167 29.167		20.01 20.01	2 2.003	0.0 0.0 0.0	11.417 0.0 11.417	150 0.0037	14.404 0.0 0.042		Vel = 2.04	
M2 to M3	29.167 29.167		0.0 20.01	2 2.003	0.0 0.0 0.0	9.875 0.0 9.875	150 0.0037	14.446 0.0 0.037		Vel = 2.04	
M3 to M5	29.167 29.167		0.0 20.01	2 2.003	1O 10.0 0.0 0.0	6.083 10.000 16.083	150 0.0037	14.483 0.0 0.059		Vel = 2.04	
M5 *			0.0 20.01					14.542		K Factor = 5.25	
M5 to M6	29.167 29.167		20.01 20.01	2 2.003	1N 11.0 0.0 0.0	8.167 11.000 19.167	150 0.0037	14.542 0.0 0.071		Vel = 2.04	
M6 to M7	29.167 19.167		-9.13 10.88	2 2.003	0.0 0.0 0.0	10.000 0.0 10.000	150 0.0012	14.613 4.331 0.012		Vel = 1.11	
M7 to M8	19.167 9.167		0.0 10.88	2 2.003	0.0 0.0 0.0	10.000 0.0 10.000	150 0.0012	18.956 4.331 0.012		Vel = 1.11	
M8 to M9	9.167 9.167		0.0 10.88	2 2.003	1O 10.0 0.0 0.0	8.167 10.000 18.167	150 0.0012	23.299 0.0 0.022		Vel = 1.11	
M9 to M10	9.167 9.167		0.0 10.88	2 2.003	0.0 0.0 0.0	19.000 0.0 19.000	150 0.0012	23.321 0.0 0.023		Vel = 1.11	
M10 to M11	9.167 9.167		9.13 20.01	2 2.003	1O 10.0 0.0 0.0	1.833 10.000 11.833	150 0.0036	23.344 0.0 0.043		Vel = 2.04	
M11 to TOR	9.167 9.500		0.0 20.01	2 2.003	4N 44.0 0.0 0.0	43.917 44.000 87.917	150 0.0037	23.387 -0.144 0.325		Vel = 2.04	
TOR *			0.0 20.01					23.568		K Factor = 4.12	



# Final Calculations - Hazen-Williams - 2007

Reliable Fire Protection LLC  
SSP 3RD FLR BEDROOM - THE GROVES

Page 7  
Date 12-16-21

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
M6 to M10	29.167 9.167		9.13	2	2N 1O 22.0 10.0	47.167 32.000 79.167	150	14.613 8.662			
			0.0					0.069	Vel =	0.93	
M10			9.13					23.344	K Factor =	1.89	
*											
TOR to BOR	9.500 1		20.01	2	1Fsp 1N 11.0 7.779 1S 14.261	10.000 33.039 43.039	150	23.568 6.681		** Fixed Loss = 3	
			0.0					0.159	Vel =	2.04	
BOR			20.01					30.408	K Factor =	3.63	
*											
BOR to UG1	1 0		20.01	2	3E 1T 12.965 1Zwb 0.0	19.447 91.042 32.412 123.454	150	30.408 13.433		** Fixed Loss = 13	
			20.01	2.003				0.456	Vel =	2.04	
UG1 to UG3	0 0		-10.51	8	4F 1G 6.041	54.365 745.000 60.405	150	44.297 0.0			
			9.5	7.98				0.001	Vel =	0.06	
UG3 to UG2	0 0		0.0	8	1T 1G 6.041	52.855 1.000 58.895	150	44.298 0.0			
			9.5	7.98				0.0	Vel =	0.06	
UG2			0.0					44.298	K Factor =	1.43	
*											
UG1 to UG2	0 0		10.50	8	4F 2G 12.081 1T 52.855	54.365 600.000 119.302 719.302	150	44.297 0.0			
			10.5	7.98				0.001	Vel =	0.07	
UG2			0.0					44.298	K Factor =	1.58	
*											
UG2 to TAP	0 0		20.01	8	1G 1T 52.855	6.041 185.000 58.895	150	44.298 0.0			
			20.01	7.98				0.001	Vel =	0.13	
TAP to TEST	0 0		0.0	20		0.0 170.000 0.0	140	44.299 0.0			
			20.01	20.57				0.0	Vel =	0.02	
TEST			100.00					44.299	Qa =	100.00	
			120.01						K Factor =	18.03	



# 4D SITE SOLUTIONS, INC

ENGINEERING SURVEYING GPS CONSTRUCTION LAYOUT

## FIRE HYDRANT FLOW TEST

TEST  
DATE

MAIN SIZE

PROJECT

PURPOSE OF TEST

PERSONS PERFORMING TEST

## HYDRANT FLOW DATA

---

FH ID

FH LOCATION

STATIC

RESID

PITOT

TIME

OR SIZE

FLOW

ADDITIONAL OBERSERVATIONS

## CONDITION OF FLOW HYDRANT

---

NUMBER OF OUTLETS

OUTLET SIZES

BODY APPEARANCE

FH SHUT OFF COMPLETELY?

OTHER OBSERVATIONS ON THE HYDRANT