

July 22, 2022

ph: 910-893-7547

fax: 910-893-9371

Christine Cox
Clayton Britt and Sons
P.O. Box 29
Fayetteville, NC 28302

Hugh Surles
Hugh Surles Builders, LLC
126 Brandon Dr.
Lillington, NC 27546

Re: The Grove at 421

Dear Ms. Cox and Mr. Surles:

This department has reviewed the plan you submitted for The Grove at 421 swimming pool to be constructed at 61 Grove Circle in Lillington. This plan review was conducted in accordance with the current North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500).

The plans have been approved with the following comments:

-Per phone conversation with Mr. Surles July 22, 2022, a revision showing the pool fencing completely surrounding the pool in such a manner as to eliminate any possible footholds from the pool house as well as the clubhouse shall be submitted. This revision will also eliminate any doors or windows from occupied buildings such as the clubhouse from entering directly onto the pool deck.

-As discussed in same conversation, all chemical feeder pumps will be installed such that if main circulation pump power is interrupted the feeder pumps will cease operation.

-Fencing must maintain a minimum of 48" even with the addition of landscape products such as mulching.

-Pump room will be fitted by builder per plans submitted by Clayton Britt and Sons.

-Please contact the Environmental Health office prior to covering sumps so a visual inspection of the sump can be made.

This approval is valid for one year from the date of this letter and applies only to the pool and related appurtenances. If construction is not initiated within one year from the date of approval, the approval shall expire and plans must be re-submitted.

Under the current provisions of the North Carolina Rules Governing Public Swimming Pools (15A NCAC 18A .2500), the pool shall be constructed by swimming pool contractors licensed by the North Carolina Licensing Board for General Contractors.


Prior to issuance of the operation permit, the owner shall submit to this department a statement signed by a registered design professional stating that construction is complete and in accordance with approved plans and specifications and approved modifications.

Observation of construction and a final inspection for design compliance by the certifying registered design professional or his representative are required for this statement.

Please notify me prior to placement of concrete so an inspection can be made of the pool piping. Upon completion of construction, the owner must apply to this department for an operation permit. A final inspection must be made and an operation permit must be issued before bathers can use the pool.

If you have any questions regarding this matter or if I can provide any additional assistance, please call me at 910-893-7547

Sincerely,

A handwritten signature in cursive script that reads "C. Pierce, REHS". The signature is written in black ink and is positioned above the printed name and title.

Cindy Pierce, REHS
Environmental Health Specialist