



# Harnett County Emergency Services

Office of the Fire Marshal

PO Box 370

Lillington, NC 27546

(910) – 893 – 7580

Date:

Time:

Occupancy: 8380 North Carolina 55 Angier, NC

## Fuel Tank(s) Installation

On the above date and time, a Fuel Tank(s) Installation witnessed at the above location revealed no violations of the N.C. State Fire Code. Piping and Dispenser Tests will need to be conducted by our office once the fuel piping has been installed. Please call our office to schedule these appointments.

### Contractor Installing Fuel Tank(s):

Number of Tanks: 4

AGST

UGST

#1 Contents Premium Vol 12,000 gallons UL# N/A Mfg Xerxes **Air/Vacuum**

#2 Contents Non Ethanol Vol 8,000 gallons UL# N/A Mfg Xerxes **Air/Vacuum**

#3 Contents Regular Vol 20,000 gallons UL# N/A Mfg Xerxes **Air/Vacuum**

#4 Contents Diesel Vol 12,000 gallons UL# N/A Mfg Xerxes **Air/Vacuum**

**Notes:** UL# is unknown until the tanks get delivered.  
12k Premium/8k Non Ethanol are a compartment tank.

Thank you for your cooperation.

Inspector

The Harnett County Fire Marshal's Division is committed to providing our community with a professional fire and life safety program through comprehensive fire protection plan reviews, informative occupancy inspections, effective fire and life safety code enforcement, and definitive fire origin and cause investigations in order to reduce the loss of life and property of the citizens of Harnett County. We will strive to maintain an unmatched level of professionalism and support to our community.