



Permit Reviews

Harnett County

Permit Number: FMFW2311-4517

Description: **installing (2) above ground tanks**

Applied: **11/28/2023**

Approved:

Site Address: **1365 SADLER RD**

Issued:

Finalized:

City, State Zip Code: **DUNN, NC 28334**

Status: **RECEIVED**

Applicant: **Carolina Conduit Systems**

Parent Permit:

Owner: **KGR ENTERPRISES LLC**

Parent Project:

Contractor: **Carolina Conduit Systems**

Details:

LIST OF REVIEWS

SENT DATE	RETURNED DATE	DUE DATE	TYPE	CONTACT	STATUS	REMARKS
Review Group: AUTO						
11/28/2023	12/13/2023	12/12/2023	FIRE MARSHAL	Roger Sullivan	DISAPPROVED	see notes

Notes:

- Provide listing for the tanks, must meet NFPA listing requirements for aboveground tanks.
- Provide dimensions of secondary containment area.
- Provide site plan to scale showing distances to property lines, buildings, public ways and spacing between other tanks.