



# Harnett County Emergency Services

Office of the Fire Marshal

PO Box 370

Lillington, NC 27546

(910) - 893 - 7580

Date: 6-10-24

Time:

Occupancy: BENNETT HALLING  
216 RANDY CT. FUQUAY MARINA 27526

## Fuel Tank(s) Installation

On the above date and time, a Fuel Tank(s) Installation witnessed at the above location revealed no violations of the N.C. State Fire Code. Piping and Dispenser Tests will need to be conducted by our office once the fuel piping has been installed. Please call our office to schedule these appointments.

Contractor Installing Fuel Tank(s): PETROLEUM SOLUTIONS INC. • N.C. LIC. 53952

Number of Tanks:

AGST

UGST

#1 Contents

Vol 12,000 UL#  
GALLON

Mfg  
REE DEE

Air/Vacuum DOUBLE WALL  
UL-142 | SKID

#2 Contents

Vol

UL#

Mfg

Air/Vacuum

#3 Contents

Vol

UL#

Mfg

Air/Vacuum

#4 Contents

Vol

UL#

Mfg

Air/Vacuum

Notes:

Thank you for your cooperation.

Inspector

The Harnett County Fire Marshal's Division is committed to providing our community with a professional fire and life safety program through comprehensive fire protection plan reviews, informative occupancy inspections, effective fire and life safety code enforcement, and definitive fire origin and cause investigations in order to reduce the loss of life and property of the citizens of Harnett County. We will strive to maintain an unmatched level of professionalism and support to our community.