

# **JUNIPER VILLAGE BUILDING 100**

---

1208 North Main Steet  
Lillington, North Carolina

## **Hydraulic Calculations**

Wayne Automatic Fire Sprinklers Job Number: 1020001



**Wayne Automatic Fire Sprinklers, Inc.**  
4370 Motorsport Drive, Concord NC 28027 - 8977

LOCATION: JUNIPER VILLAGE APTS  
PARKER LANE & NORTH MAIN ST

DATE: 3-20-24

TEST MADE BY: P JAMES

TIME: 8:30 AM

REPRESENTATIVE OF: LILLINGTON FIRE DEPT.

WITNESS: JAMES Jammy Re

STATE PURPOSE OF TEST:

CONSUMPTION RATE DURING TEST:

IF PUMPS AFFECT TEST, INDICATE PUMPS OPERATING:

TEST #225  
FLOW #224 A1 A2 A3 A4

Size Nozzle: 2.5"

Pilot Reading: 40 psi

Discharge Coefficient: .9 Total GPM

GPM: 1060

STATIC P 80 psi RESIDUAL B 68 psi

PROJECTED RESULTS: At 20 psi Residual gpm, or At psi Residual gpm

REMARKS:

LOCATION MAP: Show line sizes and distance to next cross connected line. Show valves and Hydrant branch size. Indicate North. Show flowing hydrants - Label A1, A2, A3, A4. Show location of Static and Residual - Label B.

Indicate B. Hydrant: Sprinkler: Other (Identify):



## Hydraulic Calculations

Wayne Automatic  
Fire Sprinklers, Inc.  
4370 Motorsport Drive  
Concord, NC 28027  
704-782-3032

Job Name : Juniper Village- Building 100 - 3rd Floor - Unit C2 - Common - DA 1.1  
Sheet Number : FP1.2  
Location : Building 100  
Design Area : Design Area 1.1  
Contract : 102001  
Data File : Building 100- 3rd Floor - Unit C2 - Common DA 1.1.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Juniper Villiage  
**Location:** Building 100  
**Drawing no:** FP1.2  
**Date:** 4-5-2024

**Design**

**Remote area number:** Design Area 1.1  
**Remote area location:** Building 100 - 3rd Floor - Unit C2 Common Area  
**Occupancy classification:** NFPA 13R  
**Density:** .05 - Gpm/SqFt  
**Area of application:** 4 Sprinklers - SqFt  
**Coverage per sprinkler:** 256 - SqFt  
**Type of sprinklers calculated:** Reliable Mod. F1 Res 44 Residential HSW  
**No. of sprinklers calculated:** 4  
**In-rack demand:** - GPM  
**Hose streams:** - GPM  
**Total water required (including hose streams):** 151.8 - GPM @ 67.2 - Psi  
**Type of system:** Wet Residential NFPA 13R  
**Volume of dry or preaction system:** - Gal

**Water supply information**

**Date:** 3-20-2024  
**Location:** North Main Street (Hydrant 224)  
**Source:** Lillington Fire Department

**Name of contractor:** Wayne Automatic Fire Sprinklers  
**Address:** 4370 Motorsport Drive / Concord, NC  
**Phone number:** 407-877-5514  
**Name of designer:** Donald Hawkins  
**Authority having jurisdiction:** Town of Lillington

**Notes: (Include peaking information for gridded systems here.)**

- (1) The Finished Floor Elevation is 169'. For clarity the Finished Floor elevation on the hydraulic calculations is shown as 0'-0"
- (2) A domestic demand of 86 was added at node point DD1 as required by NFPA 13R Section 9.6.


# Water Supply Curve C

Wayne Automatic  
Juniper Village- Building 100 - 3rd Floor - Unit C2 - Common - DA 1.1

Page 2  
Date 4-5-2024

City Water Supply:  
C1 - Static Pressure : 80  
C2 - Residual Pressure: 68  
C2 - Residual Flow : 1060

Demand:  
D1 - Elevation : 14.076  
D2 - System Flow : 151.794  
D2 - System Pressure : 67.240  
Hose ( Demand ) :  
D3 - System Demand : 151.794  
Safety Margin : 12.431



# Fittings Used Summary

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Unit C2 - Common - DA 1.1

Page 3  
 Date 4-5-2024

## Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 Tee Branch	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
U*	CPVC 90' Elbow Tyco	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
V*	CPVC Tee Branch Tyco	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Unit C2 - Common - DA 1.1

Page 4  
 Date 4-5-2024

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
J1	27.5	4.4	13.47	na	16.15	0.05	256	13.3
J2	27.5	4.4	15.45	na	17.29	0.05	256	13.3
J3	27.5	4.4	13.73	na	16.3	0.05	256	13.3
J4	27.5	4.4	13.3	na	16.05	0.05	256	13.3
11	19.25		18.77	na				
15	19.25		20.39	na				
32	19.25		21.93	na				
12	19.25		20.98	na				
16	19.25		22.4	na				
13	19.25		19.06	na				
14	19.25		18.58	na				
25	19.25		19.23	na				
26	19.25		20.56	na				
22	19.25		25.02	na				
27	19.25		25.02	na				
28	19.25		30.71	na				
200	19.25		41.02	na				
202	19.25		34.1	na				
203	19.25		34.28	na				
201	19.25		37.8	na				
101	9.25		45.81	na				
100	9.25		46.99	na				
102	9.25		48.0	na				
TR	1.0		53.63	na				
BR	-3.0		55.86	na				
UG1	-3.0		55.87	na				
BFD1	2.0		53.75	na				
BFS1	2.0		63.72	na	86.0			
DD1	-3.0		65.94	na				
M1	-3.0		66.29	na				
M2	-3.0		66.29	na				
M3	-3.0		66.28	na				
M4	-3.0		66.29	na				
M5	-3.0		66.29	na				
CC1	-10.0		69.34	na				
CC2	-10.0		69.34	na				
TEST	-5.0		67.24	na				

The maximum velocity is 17.88 and it occurs in the pipe between nodes 16 and 202

# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Unit C2 - Common - DA 1.1

Page 5  
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
J1 to 11	16.15 16.15	0.874 150.0 0.1411	U	4.0 0.0 0.0	8.250 4.000 12.250	13.473 3.573 1.728			K Factor = 4.40 Vel = 8.64	
	0.0 16.15						18.774		K Factor = 3.73	
J2 to 12	17.29 17.29	0.874 150.0 0.1601	U	4.0 0.0 0.0	8.250 4.000 12.250	15.448 3.573 1.961			K Factor = 4.40 Vel = 9.25	
	0.0 17.29						20.982		K Factor = 3.77	
J3 to 13	16.30 16.3	0.874 150.0 0.1435	U	4.0 0.0 0.0	8.250 4.000 12.250	13.729 3.573 1.758			K Factor = 4.40 Vel = 8.72	
	0.0 16.30						19.060		K Factor = 3.73	
J4 to 14	16.05 16.05	0.874 150.0 0.1393	U	4.0 0.0 0.0	8.250 4.000 12.250	13.300 3.573 1.707			K Factor = 4.40 Vel = 8.58	
	0.0 16.05						18.580		K Factor = 3.72	
11 to 15	16.15 16.15	0.874 150.0 0.1411	V	3.0 0.0 0.0	8.420 3.000 11.420	18.774 0.0 1.611			Vel = 8.64	
15 to 32	0.0 16.15	0.874 150.0 0.1410		0.0 0.0 0.0	10.920 0.0 10.920	20.385 0.0 1.540			Vel = 8.64	
32 to 16	0.0 16.15	0.874 150.0 0.1411		0.0 0.0 0.0	3.330 0.0 3.330	21.925 0.0 0.470			Vel = 8.64	
	0.0 16.15						22.395		K Factor = 3.41	
12 to 16	17.29 17.29	0.874 150.0 0.1600	U V	4.0 3.0 0.0	1.830 7.000 8.830	20.982 0.0 1.413			Vel = 9.25	
16 to 202	16.15 33.44	0.874 150.0 0.5423	V	3.0 0.0 0.0	18.580 3.000 21.580	22.395 0.0 11.702			Vel = 17.88	
	0.0 33.44						34.097		K Factor = 5.73	
13 to 26	16.30 16.3	0.874 150.0 0.1435	U V	4.0 3.0 0.0	3.420 7.000 10.420	19.060 0.0 1.495			Vel = 8.72	
	0.0 16.30						20.555		K Factor = 3.60	
14 to 25	16.05 16.05	0.874 150.0 0.1394	V	3.0 0.0 0.0	1.670 3.000 4.670	18.580 0.0 0.651			Vel = 8.58	



# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Unit C2 - Common - DA 1.1

Page 6  
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
25	0.0	0.874	V	3.0	6.500	19.231				
to		150.0		0.0	3.000	0.0				
26	16.05	0.1394		0.0	9.500	1.324		Vel = 8.58		
26	16.30	0.874		0.0	8.750	20.555				
to		150.0		0.0	0.0	0.0				
27	32.35	0.5098		0.0	8.750	4.461		Vel = 17.30		
	0.0									
	32.35					25.016		K Factor = 6.47		
22	0.0	0.874	U	4.0	10.750	25.016				
to		150.0	2V	6.0	10.000	0.0				
27	0.0	0.0		0.0	20.750	0.0		Vel = 0		
27	32.35	0.874		0.0	11.170	25.016				
to		150.0		0.0	0.0	0.0				
28	32.35	0.5099		0.0	11.170	5.696		Vel = 17.30		
28	0.0	0.874	V	3.0	4.000	30.712				
to		150.0		0.0	3.000	0.0				
203	32.35	0.5099		0.0	7.000	3.569		Vel = 17.30		
	0.0									
	32.35					34.281		K Factor = 5.53		
200	-25.79	1.101		0.0	63.580	41.024				
to		150.0		0.0	0.0	0.0				
202	-25.79	-0.1089		0.0	63.580	-6.927		Vel = 8.69		
202	33.44	1.101		0.0	16.000	34.097				
to		150.0		0.0	0.0	0.0				
203	7.65	0.0115		0.0	16.000	0.184		Vel = 2.58		
203	32.35	1.101	V	5.0	9.330	34.281				
to		150.0		0.0	5.000	0.0				
201	40.0	0.2453		0.0	14.330	3.515		Vel = 13.48		
	0.0									
	40.00					37.796		K Factor = 6.51		
201	40.00	1.101	V	5.0	10.000	37.796				
to		150.0		0.0	5.000	4.331				
101	40.0	0.2453		0.0	15.000	3.679		Vel = 13.48		
	0.0									
	40.00					45.806		K Factor = 5.91		
200	25.79	1.101	V	5.0	10.000	41.024				
to		150.0		0.0	5.000	4.331				
100	25.79	0.1089		0.0	15.000	1.634		Vel = 8.69		
	0.0									
	25.79					46.989		K Factor = 3.76		
101	40.00	2.003		0.0	88.920	45.806				
to		150.0		0.0	0.0	0.0				
100	40.0	0.0133		0.0	88.920	1.183		Vel = 4.07		
100	25.79	2.003		0.0	30.420	46.989				
to		150.0		0.0	0.0	0.0				
102	65.79	0.0334		0.0	30.420	1.016		Vel = 6.70		
102	0.0	2.003	5U	45.0	16.500	48.005				
to		150.0		0.0	45.000	3.573				
TR	65.79	0.0334		0.0	61.500	2.054		Vel = 6.70		

# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Unit C2 - Common - DA 1.1

Page 7  
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 65.79						53.632		K Factor = 8.98	
TR to BR	65.79	2.003 150.0 0.0335	Z	6.482 0.0	8.250 6.482	53.632 1.732			Vel = 6.70	
BR to UG1	0.0 65.79	4.28 140.0 0.0009	L	10.75 0.0	4.000 10.750	55.857 0.0			Vel = 1.47	
	0.0 65.79						55.871		K Factor = 8.80	
UG1 to BFD1	65.79	4.24 150.0 0.0009	2L	23.335 0.0	32.580 23.335	55.871 -2.166			Vel = 1.49	
BFD1 to BFS1	0.0 65.79	4.026 120.0 0.0017	Zai	0.0 0.0	10.000 0.0	53.754 9.950			* * Fixed Loss = 9.95 Vel = 1.66	
BFS1 to DD1	86.00 151.79	4.24 150.0 0.0040		0.0 0.0	13.000 0.0	63.721 2.166			Qa = 86.00 Vel = 3.45	
DD1 to M3	0.0 151.79	4.24 150.0 0.0041	G T	3.889 38.891	40.250 42.780	65.939 0.0			Vel = 3.45	
	0.0 151.79						66.277		K Factor = 18.64	
M1 to M2	-89.75	7.98 150.0		0.0 0.0	31.580 0.0	66.295 0.0			Vel = 0.58	
M2 to M3	-89.75	-0.0001		0.0	31.580	-0.003			Vel = 0.58	
M2 to M3	0.0	7.98 150.0	2F	27.183 0.0	193.580 27.182	66.292 0.0			Vel = 0.58	
M3 to M4	-89.75 151.79	-0.0001 7.98 150.0		0.0 0.0	220.762 0.0	-0.015 0.0			Vel = 0.40	
M3 to M4	151.79	7.98 150.0	F	13.591 0.0	287.750 13.592	66.277 0.0			Vel = 0.40	
M4 to M5	62.04	0.0		0.0	301.342	0.011			Vel = 0.40	
M4 to M5	0.0	7.98 150.0	T	52.855 0.0	76.670 52.855	66.288 0.0			Vel = 0.40	
M5 to M1	62.04	0.0		0.0	129.525	0.004			Vel = 0.40	
M5 to M1	0.0	11.68 150.0	F	17.661 0.0	422.000 17.661	66.292 0.0			Vel = 0.19	
M1 to CC1	62.04	0.0		0.0	439.661	0.003			Vel = 0.19	
M1 to CC1	89.75	11.68 150.0	T G	81.513 8.151	372.830 89.664	66.295 3.032			Vel = 0.45	
CC1 to CC2	151.79	0.0		0.0	462.494	0.013			Vel = 0.45	
CC1 to CC2	0.0	19.76 150.0		0.0 0.0	321.000 0.0	69.340 0.0			Vel = 0.16	
CC2 to TEST	151.79	0.0		0.0	321.000	0.001			Vel = 0.16	
CC2 to TEST	0.0	6.08 140.0	G L	4.038 12.115	65.000 16.153	69.341 -2.166			Vel = 1.68	
TEST	151.79	0.0008		0.0	81.153	0.065			Vel = 1.68	

# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Unit C2 - Common - DA 1.1

Page 8  
 Date 4-5-2024

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 151.79				67.240			K Factor = 18.51	



## Hydraulic Calculations

Wayne Automatic  
Fire Sprinklers, Inc.  
4370 Motorsport Drive  
Concord, NC 28027  
704-782-3032

Job Name : Juniper Village- Building 100 - 3rd Floor - Corridor - DA 1.2  
Sheet Number : FP1.2  
Location : Building 100  
Design Area : Design Area 1.2  
Contract : 102001  
Data File : Building 100- 3rd Floor - Corridor - DA 1.2.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Juniper Villiage  
**Location:** Building 100  
**Drawing no:** FP1.2  
**Date:** 4-5-2024

**Design**

**Remote area number:** Design Area 1.2  
**Remote area location:** Building 100 - 3rd Floor - Corridor  
**Occupancy classification:** NFPA 13R  
**Density:** .10 - Gpm/SqFt  
**Area of application:** 4 Sprinklers - SqFt  
**Coverage per sprinkler:** 122 - SqFt  
**Type of sprinklers calculated:** Reliable Mod F3QR Dry HSW  
**No. of sprinklers calculated:** 4  
**In-rack demand:** - GPM  
**Hose streams:** - GPM  
**Total water required (including hose streams):** 158.3 - GPM @ 65.2 - Psi  
**Type of system:** Wet Residential NFPA 13R  
**Volume of dry or preaction system:** - Gal

**Water supply information**

**Date:** 3-20-2024  
**Location:** North Main Street (Hydrant 224)  
**Source:** Lillington Fire Department

**Name of contractor:** Wayne Automatic Fire Sprinklers  
**Address:** 4370 Motorsport Drive / Concord, NC  
**Phone number:** 407-877-5514  
**Name of designer:** Donald Hawkins  
**Authority having jurisdiction:** Town of Lillington

**Notes: (Include peaking information for gridded systems here.)**

- (1) The Finished Floor Elevation is 169'. For clarity the Finished Floor elevation on the hydraulic calculations is shown as 0'-0"
- (2) A domestic demand of 86 was added at node point DD1 as required by NFPA 13R Section 9.6.


# Water Supply Curve C

Wayne Automatic  
Juniper Village- Building 100 - 3rd Floor - Corridor - DA 1.2

Page 2  
Date 4-5-2024

City Water Supply:  
C1 - Static Pressure : 80  
C2 - Residual Pressure: 68  
C2 - Residual Flow : 1060

Demand:  
D1 - Elevation : 14.076  
D2 - System Flow : 158.267  
D2 - System Pressure : 65.249  
Hose ( Demand ) :  
D3 - System Demand : 158.267  
Safety Margin : 14.395



# Fittings Used Summary

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Corridor - DA 1.2

Page 3  
 Date 4-5-2024

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 Tee Branch	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
U*	CPVC 90' Elbow Tyco	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
V*	CPVC Tee Branch Tyco	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units           Inches  
 Length Units             Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Corridor - DA 1.2

Page 4  
 Date 4-5-2024

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
K1	27.5	5.6	7.0	na	14.82	0.1	122	7.0
K2	27.5	5.6	8.11	na	15.94	0.1	122	7.0
K3	27.5	5.6	11.53	na	19.01	0.1	122	7.0
K4	27.5	5.6	16.13	na	22.49	0.1	122	7.0
21	19.25		13.01	na				
25	19.25		14.03	na				
26	19.25		15.17	na				
33	19.25		15.64	na				
22	19.25		13.37	na				
27	19.25		16.22	na				
23	19.25		17.44	na				
28	19.25		21.41	na				
24	19.25		22.63	na				
29	19.25		27.32	na				
200	19.25		38.4	na				
202	19.25		31.16	na				
203	19.25		29.33	na				
201	19.25		33.86	na				
101	9.25		42.92	na				
100	9.25		44.44	na				
102	9.25		45.65	na				
TR	1.0		51.67	na				
BR	-3.0		53.99	na				
UG1	-3.0		54.0	na				
BFD1	2.0		51.9	na				
BFS1	2.0		61.69	na	86.0			
DD1	-3.0		63.91	na				
M1	-3.0		64.3	na				
M2	-3.0		64.3	na				
M3	-3.0		64.28	na				
M4	-3.0		64.29	na				
M5	-3.0		64.29	na				
CC1	-10.0		67.34	na				
CC2	-10.0		67.34	na				
TEST	-5.0		65.25	na				

The maximum velocity is 26.62 and it occurs in the pipe between nodes 28 and 203



# Final Calculations - Hazen-Williams

Wayne Automatic  
Juniper Village- Building 100 - 3rd Floor - Corridor - DA 1.2

Page 5  
Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
K1 to 21	14.82	0.874 150.0 0.1202	U 4.0 V 3.0 0.0	13.250 7.000 20.250	7.000 3.573 2.435		K Factor = 5.60 Vel = 7.93		
	0.0 14.82					13.008	K Factor = 4.11		
K2 to 22	15.94	0.874 150.0 0.1377	U 4.0 0.0 0.0	8.250 4.000 12.250	8.107 3.573 1.687		K Factor = 5.60 Vel = 8.52		
	0.0 15.94					13.367	K Factor = 4.36		
K3 to 23	19.01	0.874 150.0 0.1908	U 4.0 0.0 0.0	8.250 4.000 12.250	11.529 3.573 2.337		K Factor = 5.60 Vel = 10.17		
	0.0 19.01					17.439	K Factor = 4.55		
K4 to 24	22.49	0.874 150.0 0.2603	V 3.0 0.0 0.0	8.250 3.000 11.250	16.131 3.573 2.928		K Factor = 5.60 Vel = 12.03		
	0.0 22.49					22.632	K Factor = 4.73		
21 to 25	14.82	0.874 150.0 0.1202	U 4.0 0.0 0.0	4.500 4.000 8.500	13.008 0.0 1.022		Vel = 7.93		
25 to 26	0.0	0.874 150.0 0.1202	V 3.0 0.0 0.0	6.500 3.000 9.500	14.030 0.0 1.142		Vel = 7.93		
26 to 33	0.0	0.874 150.0 0.1204	0.0 0.0 0.0	3.920 0.0 3.920	15.172 0.0 0.472		Vel = 7.93		
33 to 27	0.0	0.874 150.0 0.1203	0.0 0.0 0.0	4.830 0.0 4.830	15.644 0.0 0.581		Vel = 7.93		
	0.0 14.82					16.225	K Factor = 3.68		
22 to 27	15.94	0.874 150.0 0.1377	U 4.0 2V 6.0 0.0	10.750 10.000 20.750	13.367 0.0 2.858		Vel = 8.52		
27 to 28	14.82	0.874 150.0 0.4645	0.0 0.0 0.0	11.170 0.0 11.170	16.225 0.0 5.188		Vel = 16.45		
	0.0 30.76					21.413	K Factor = 6.65		
23 to 28	19.01	0.874 150.0 0.1908	U 4.0 2V 6.0 0.0	10.830 10.000 20.830	17.439 0.0 3.974		Vel = 10.17		
28 to 203	30.77	0.874 150.0 1.1316	V 3.0 0.0 0.0	4.000 3.000 7.000	21.413 0.0 7.921		Vel = 26.62		

# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Corridor - DA 1.2

Page 6  
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 49.78						29.334		K Factor = 9.19	
24 to 29	22.49	0.874 150.0	U V	4.0 3.0 0.0	11.000 7.000 18.000	22.632 0.0 4.685			Vel = 12.03	
29 to 203	0.0 22.49	0.874 150.0 0.2603	V	3.0 0.0 0.0	4.750 3.000 7.750	27.317 0.0 2.017			Vel = 12.03	
	0.0 22.49						29.334		K Factor = 4.15	
200 to 202	-26.43	1.101 150.0		0.0 0.0 0.0	63.580 0.0 63.580	38.403 0.0 -7.245			Vel = 8.91	
202 to 203	0.0 -26.43	1.101 150.0 -0.1140		0.0 0.0 0.0	16.000 0.0 16.000	31.158 0.0 -1.824			Vel = 8.91	
203 to 201	72.27 45.84	1.101 150.0 0.3156	V	5.0 0.0 0.0	9.330 5.000 14.330	29.334 0.0 4.522			Vel = 15.45	
	0.0 45.84						33.856		K Factor = 7.88	
201 to 101	45.84	1.101 150.0	V	5.0 0.0 0.0	10.000 5.000 15.000	33.856 4.331 4.734			Vel = 15.45	
	0.0 45.84						42.921		K Factor = 7.00	
200 to 100	26.43	1.101 150.0	V	5.0 0.0 0.0	10.000 5.000 15.000	38.403 4.331 1.709			Vel = 8.91	
	0.0 26.43						44.443		K Factor = 3.96	
101 to 100	45.84	2.003 150.0		0.0 0.0 0.0	88.920 0.0 88.920	42.921 0.0 1.522			Vel = 4.67	
100 to 102	26.43	2.003 150.0		0.0 0.0 0.0	30.420 0.0 30.420	44.443 0.0 1.209			Vel = 7.36	
102 to TR	0.0 72.27	2.003 150.0 0.0397	5U	45.0 0.0 0.0	16.500 45.000 61.500	45.652 3.573 2.444			Vel = 7.36	
	0.0 72.27						51.669		K Factor = 10.05	
TR to BR	72.27	2.003 150.0	Z	6.482 0.0 0.0	8.250 6.482 14.732	51.669 1.732 0.586			Vel = 7.36	
BR to UG1	0.0 72.27	4.28 140.0 0.0012	L	10.75 0.0 0.0	4.000 10.750 14.750	53.987 0.0 0.017			Vel = 1.61	

# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 3rd Floor - Corridor - DA 1.2

Page 7  
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 72.27						54.004		K Factor = 9.83	
UG1 to BFD1	72.27	4.24 150.0	2L	23.335 0.0	32.580 23.335	54.004 -2.166				
BFD1 to BFS1	72.27	0.0010		0.0	55.915	0.058			Vel = 1.64	
BFD1 to BFS1	0.0	4.026 120.0	Zai	0.0 0.0	10.000 0.0	51.896 9.775			** Fixed Loss = 9.775	
BFS1 to DD1	72.27	0.0020		0.0	10.000	0.020			Vel = 1.82	
BFS1 to DD1	86.00	4.24 150.0		0.0 0.0	13.000 0.0	61.691 2.166			Qa = 86.00	
DD1 to M3	158.27	0.0043		0.0	13.000	0.056			Vel = 3.60	
DD1 to M3	0.0	4.24 150.0	G T	3.889 38.891	40.250 42.780	63.913 0.0				Vel = 3.60
	0.0 158.27						64.278		K Factor = 19.74	
M1 to M2	-93.58	7.98 150.0		0.0 0.0	31.580 0.0	64.298 0.0				
M2 to M3	-93.58	-0.0001		0.0	31.580	-0.003			Vel = 0.60	
M2 to M3	0.0	7.98 150.0	2F	27.183 0.0	193.580 27.182	64.295 0.0				
M3 to M4	-93.58	-0.0001		0.0	220.762	-0.017			Vel = 0.60	
M3 to M4	158.27	7.98 150.0	F	13.591 0.0	287.750 13.592	64.278 0.0				
M4 to M5	64.69	0.0		0.0	301.342	0.012			Vel = 0.41	
M4 to M5	0.0	7.98 150.0	T	52.855 0.0	76.670 52.855	64.290 0.0				
M5 to M1	64.69	0.0		0.0	129.525	0.005			Vel = 0.41	
M5 to M1	0.0	11.68 150.0	F	17.661 0.0	422.000 17.661	64.295 0.0				
M1 to CC1	64.69	0.0		0.0	439.661	0.003			Vel = 0.19	
M1 to CC1	93.58	11.68 150.0	T G	81.513 8.151	372.830 89.664	64.298 3.032				
CC1 to CC2	158.27	0.0		0.0	462.494	0.014			Vel = 0.47	
CC1 to CC2	0.0	19.76 150.0		0.0 0.0	321.000 0.0	67.344 0.0				
CC2 to TEST	158.27	0.0		0.0	321.000	0.001			Vel = 0.17	
CC2 to TEST	0.0	6.08 140.0	G L	4.038 12.115	65.000 16.153	67.345 -2.166				
TEST	158.27	0.0009		0.0	81.153	0.070			Vel = 1.75	
	0.0 158.27						65.249		K Factor = 19.59	



## Hydraulic Calculations

Wayne Automatic  
Fire Sprinklers, Inc.  
4370 Motorsport Drive  
Concord, NC 28027  
704-782-3032

Job Name : Juniper Village- Building 100 - 2nd Floor - Unit C2 - Common - DA 1.3  
Sheet Number : FP1.2  
Location : Building 100  
Design Area : Design Area 1.3  
Contract : 102001  
Data File : Building 100- 2nd Floor - Unit C2 - Common DA 1.3.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**Project name:** Juniper Villiage  
**Location:** Building 100  
**Drawing no:** FP1.2  
**Date:** 4-5-2024

**Design**

**Remote area number:** Design Area 1.3  
**Remote area location:** Building 100 - 2nd Floor - Unit C2 Common Area  
**Occupancy classification:** NFPA 13R  
**Density:** .05 - Gpm/SqFt  
**Area of application:** 3 Sprinklers - SqFt  
**Coverage per sprinkler:** 256, 400 - SqFt  
**Type of sprinklers calculated:** Reliable Mod. F1Res 49 Residential Pendants  
**No. of sprinklers calculated:** 3  
**In-rack demand:** - GPM  
**Hose streams:** - GPM  
**Total water required (including hose streams):** 136.4 - GPM @ 50.6 - Psi  
**Type of system:** Wet Residential NFPA 13R  
**Volume of dry or preaction system:** - Gal

**Water supply information**

**Date:** 3-20-2024  
**Location:** North Main Street (Hydrant 224)  
**Source:** Lillington Fire Department

**Name of contractor:** Wayne Automatic Fire Sprinklers  
**Address:** 4370 Motorsport Drive / Concord, NC  
**Phone number:** 407-877-5514  
**Name of designer:** Donald Hawkins  
**Authority having jurisdiction:** Town of Lillington

**Notes: (Include peaking information for gridded systems here.)**

- (1) The Finished Floor Elevation is 169'. For clarity the Finished Floor elevation on the hydraulic calculations is shown as 0'-0"
- (2) A domestic demand of 86 was added at node point DD1 as required by NFPA 13R Section 9.6.


# Water Supply Curve C

Wayne Automatic  
Juniper Village- Building 100 - 2nd Floor - Unit C2 - Common - DA 1.3

Page 2  
Date 4-5-2024

City Water Supply:  
C1 - Static Pressure : 80  
C2 - Residual Pressure: 68  
C2 - Residual Flow : 1060

Demand:  
D1 - Elevation : 9.853  
D2 - System Flow : 136.415  
D2 - System Pressure : 50.580  
Hose ( Demand ) :  
D3 - System Demand : 136.415  
Safety Margin : 29.150



# Fittings Used Summary

Wayne Automatic  
 Juniper Village- Building 100 - 2nd Floor - Unit C2 - Common - DA 1.3

Page 3  
 Date 4-5-2024

## Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 Tee Branch	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
U*	CPVC 90' Elbow Tyco	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
V*	CPVC Tee Branch Tyco	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units                   Inches  
 Length Units                    Feet  
 Flow Units                        US Gallons per Minute  
 Pressure Units                  Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Wayne Automatic  
 Juniper Village- Building 100 - 2nd Floor - Unit C2 - Common - DA 1.3

Page 4  
 Date 4-5-2024

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
L1	17.75	4.9	8.83	na	14.56	0.05	256	7.0
L2	17.75	4.9	10.43	na	15.83	0.05	256	7.0
L3	17.75	4.9	16.7	na	20.02	0.05	400	16.7
31	19.25		8.82	na				
15	19.25		9.12	na				
32	19.25		10.4	na				
16	19.25		11.91	na				
33	19.25		17.2	na				
27	19.25		18.22	na				
28	19.25		20.56	na				
200	19.25		26.05	na				
202	19.25		21.71	na				
203	19.25		22.03	na				
201	19.25		24.15	na				
101	9.25		30.69	na				
100	9.25		31.4	na				
102	9.25		32.02	na				
TR	1.0		36.85	na				
BR	-3.0		38.89	na				
UG1	-3.0		38.89	na				
BFD1	2.0		36.76	na				
BFS1	2.0		47.18	na				
DD1	-3.0		49.36	na	86.0			
M1	-3.0		49.65	na				
M2	-3.0		49.65	na				
M3	-3.0		49.63	na				
M4	-3.0		49.64	na				
M5	-3.0		49.65	na				
CC1	-10.0		52.69	na				
CC2	-10.0		52.69	na				
TEST	-5.0		50.58	na				

The maximum velocity is 16.25 and it occurs in the pipe between nodes 32 and 16



# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 2nd Floor - Unit C2 - Common - DA 1.3

Page 5  
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
L1 to 31	14.56 14.56	0.874 150.0 0.1165	U	4.0 0.0 0.0	1.500 4.000 5.500	8.833 -0.650 0.641			K Factor = 4.90	
	0.0 14.56						8.824		K Factor = 4.90	
L2 to 32	15.83 15.83	0.874 150.0 0.1360	V	3.0 0.0 0.0	1.500 3.000 4.500	10.434 -0.650 0.612			K Factor = 4.90	
	0.0 15.83						10.396		K Factor = 4.91	
L3 to 33	20.02 20.02	0.874 150.0 0.2100	U	4.0 0.0 0.0	1.500 4.000 5.500	16.700 -0.650 1.155			K Factor = 4.90	
	0.0 20.02						17.205		K Factor = 4.83	
31 to 15	14.56 14.56	0.874 150.0 0.1163		0.0 0.0 0.0	2.580 0.0 2.580	8.824 0.0 0.300				Vel = 7.79
15 to 32	0.0 14.56	0.874 150.0 0.1165		0.0 0.0 0.0	10.920 0.0 10.920	9.124 0.0 1.272				Vel = 7.79
32 to 16	15.83 30.39	0.874 150.0 0.4544		0.0 0.0 0.0	3.330 0.0 3.330	10.396 0.0 1.513				Vel = 16.25
16 to 202	0.0 30.39	0.874 150.0 0.4542	V	3.0 0.0 0.0	18.580 3.000 21.580	11.909 0.0 9.802				Vel = 16.25
	0.0 30.39						21.711		K Factor = 6.52	
33 to 27	20.02 20.02	0.874 150.0 0.2099		0.0 0.0 0.0	4.830 0.0 4.830	17.205 0.0 1.014				Vel = 10.71
27 to 28	0.0 20.02	0.874 150.0 0.2099		0.0 0.0 0.0	11.170 0.0 11.170	18.219 0.0 2.345				Vel = 10.71
28 to 203	0.0 20.02	0.874 150.0 0.2100	V	3.0 0.0 0.0	4.000 3.000 7.000	20.564 0.0 1.470				Vel = 10.71
	0.0 20.02						22.034		K Factor = 4.26	
200 to 202	-20.03 -20.03	1.101 150.0 -0.0682		0.0 0.0 0.0	63.580 0.0 63.580	26.048 0.0 -4.337				Vel = 6.75
202 to 203	30.39 10.36	1.101 150.0 0.0202		0.0 0.0 0.0	16.000 0.0 16.000	21.711 0.0 0.323				Vel = 3.49
203 to 201	20.03 30.39	1.101 150.0 0.1475	V	5.0 0.0 0.0	9.330 5.000 14.330	22.034 0.0 2.113				Vel = 10.24

# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 2nd Floor - Unit C2 - Common - DA 1.3

Page 6  
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 30.39					24.147		K Factor = 6.18	
201 to 101	30.39	1.101 150.0 0.1475	V 5.0 0.0 0.0	10.000 5.000 15.000	24.147 4.331 2.213			Vel = 10.24	
	0.0 30.39					30.691		K Factor = 5.49	
200 to 100	20.03	1.101 150.0 0.0682	V 5.0 0.0 0.0	10.000 5.000 15.000	26.048 4.331 1.023			Vel = 6.75	
	0.0 20.03					31.402		K Factor = 3.57	
101 to 100	30.39	2.003 150.0 0.0080	0.0 0.0 0.0	88.920 0.0 88.920	30.691 0.0 0.711			Vel = 3.09	
100 to 102	20.02	2.003 150.0 0.0204	0.0 0.0 0.0	30.420 0.0 30.420	31.402 0.0 0.622			Vel = 5.13	
102 to TR	0.0 50.41	2.003 150.0 0.0204	5U 45.0 0.0 0.0	16.500 45.000 61.500	32.024 3.573 1.255			Vel = 5.13	
	0.0 50.41					36.852		K Factor = 8.30	
TR to BR	50.41	2.003 150.0 0.0204	Z 6.482 0.0 0.0	8.250 6.482 14.732	36.852 1.732 0.301			Vel = 5.13	
BR to UG1	0.0 50.41	4.28 140.0 0.0006	L 10.75 0.0 0.0	4.000 10.750 14.750	38.885 0.0 0.009			Vel = 1.12	
	0.0 50.41					38.894		K Factor = 8.08	
UG1 to BFD1	50.41	4.24 150.0 0.0005	2L 23.335 0.0 0.0	32.580 23.335 55.915	38.894 -2.166 0.030			Vel = 1.15	
BFD1 to BFS1	0.0 50.41	4.026 120.0 0.0010	Zai 0.0 0.0 0.0	10.000 0.0 10.000	36.758 10.417 0.010			** Fixed Loss = 10.417 Vel = 1.27	
BFS1 to DD1	0.0 50.41	4.24 150.0 0.0005	0.0 0.0 0.0	13.000 0.0 13.000	47.185 2.166 0.006			Vel = 1.15	
DD1 to M3	86.01 136.42	4.24 150.0 0.0033	G 3.889 T 38.891 0.0	40.250 42.780 83.030	49.357 0.0 0.277			Qa = 86.00 Vel = 3.10	
	0.0 136.42					49.634		K Factor = 19.36	
M1 to M2	-80.66 -80.66	7.98 150.0 -0.0001	0.0 0.0 0.0	31.580 0.0 31.580	49.649 0.0 -0.002			Vel = 0.52	

# Final Calculations - Hazen-Williams

Wayne Automatic  
 Juniper Village- Building 100 - 2nd Floor - Unit C2 - Common - DA 1.3

Page 7  
 Date 4-5-2024

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
M2 to M3	0.0 -80.66	7.98 150.0 -0.0001	2F	27.183 0.0 0.0	193.580 27.182 220.762	49.647 0.0 -0.013		Vel = 0.52	
M3 to M4	136.42 55.76	7.98 150.0 0.0	F	13.591 0.0 0.0	287.750 13.592 301.342	49.634 0.0 0.009		Vel = 0.36	
M4 to M5	0.0 55.76	7.98 150.0 0.0	T	52.855 0.0 0.0	76.670 52.855 129.525	49.643 0.0 0.004		Vel = 0.36	
M5 to M1	0.0 55.76	11.68 150.0 0.0	F	17.661 0.0 0.0	422.000 17.661 439.661	49.647 0.0 0.002		Vel = 0.17	
M1 to CC1	80.66 136.42	11.68 150.0 0.0	T G	81.513 8.151 0.0	372.830 89.664 462.494	49.649 3.032 0.011		Vel = 0.41	
CC1 to CC2	0.0 136.42	19.76 150.0 0.0		0.0 0.0 0.0	321.000 0.0 321.000	52.692 0.0 0.0		Vel = 0.14	
CC2 to TEST	0.0 136.42	6.08 140.0 0.0007	G L	4.038 12.115 0.0	65.000 16.153 81.153	52.692 -2.166 0.054		Vel = 1.51	
	0.0 136.42					50.580		K Factor = 19.18	