

	P2		SK-PS10 Battery Calculation							
	Secondary Power Source Requirements									
	Standby Current (amps)			Secondary Alarm Current (amps)						
Device Type	Qty	X	Current Draw	=	Total	Qty	X	Current Draw	=	Total
SK-PS10 Power Module	1	X	0.1560	=	0.1560	1	X	0.1850	=	0.1850
NAC / Output # 1			0.0000	=	0.0000			0.8470	=	0.8470
NAC / Output # 2			0.0000	=	0.0000			1.8600	=	1.8600
NAC / Output # 3			0.0000	=	0.0000			1.6440	=	1.6440
NAC / Output # 4			0.0000	=	0.0000			1.2920	=	1.2920
NAC / Output # 5			0.0000	=	0.0000			0.8470	=	0.8470
NAC / Output # 6			0.0000	=	0.0000			0.8470	=	0.8470
NAC / Output # 7			0.0000	=	0.0000			0.0000	=	0.0000
Total Standby Load					0.1560	Total Alarm Load				
						7.5220				

	P2		SK-PS10 Battery Calculation							
	Note 1: You are fully responsible for verifying these calculations.									
	Note 2: You only need to make entries in the yellow cells									
Calculation in Total Sheet										
						Required Standby Time in Hours				
						24 Hours				
Standby Load Current (Amps)				0.1560 Amps		X	24	=	3.744 AH	
						Required Alarm Time in Hours				
						5 Minutes				
Alarm Load Current (Amps)				7.5220 Amps		X	0.084	=	0.632 AH	
						Total Current Load				
						4.38 AH				
*Multiply by the Derating Factor						1.2		=	x 1.20	
						Total Ampere Hours Required				
						5.25 AH				

Recommended Batteries: **BAT-1270 - 7AH Batteries**

* Derating Factor required to compensate for the non-linear discharge characteristic of a battery.

	P2		SK-PS10 Circuit Detail								
	NAC / Output # 1										
	Device	Qty	X	Non-Alarm Draw	=	Total	Qty	X	Alarm Draw	=	Total
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000	
HWL-LF	7	x	0.000000	=	0.000000	7	x	0.108000	=	0.756000	
		x	0.000000	=			x	0.000000	=		
		x	0.000000	=			x	0.000000	=		
		x	0.000000	=			x	0.000000	=		
		x	0.000000	=			x	0.000000	=		
		x	0.000000	=			x	0.000000	=		
		x	0.000000	=			x	0.000000	=		
		x	0.000000	=			x	0.000000	=		
		x	0.000000	=			x	0.000000	=		
Total Standby Load					0.000000	Total Alarm Load					
						0.847000					

NAC / Output # 2										
Device	Qty	X	Non-Alarm Draw	=	Total	Qty	X	Alarm Draw	=	Total
P2WH-LF @ 185 Candela	3	x	0.000000	=	0.000000	3	x	0.417000	=	1.251000
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000
SWL @ 15 Candela	2	x	0.000000	=	0.000000	2	x	0.043000	=	0.086000
HWL-LF	4	x	0.000000	=	0.000000	4	x	0.108000	=	0.432000
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load					0.000000	Total Alarm Load				
						1.860000				

NAC / Output # 3										
Device	Qty	X	Non-Alarm Draw	=	Total	Qty	X	Alarm Draw	=	Total
P2WH-LF @ 185 Candela	3	x	0.000000	=	0.000000	3	x	0.417000	=	1.251000
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000
SWL @ 15 Candela	2	x	0.000000	=	0.000000	2	x	0.043000	=	0.086000
HWL-LF	2	x	0.000000	=	0.000000	2	x	0.108000	=	0.216000
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	


	x	0.000000	=		x	0.000000	=		
	x	0.000000	=		x	0.000000	=		
Total Standby Load				0.000000	Total Alarm Load				1.644000

NAC / Output # 4										
Device	Qty	x	Non-Alarm Draw	=	Total	Qty	x	Alarm Draw	=	Total
P2WH-LF @ 185 Candela	2	x	0.000000	=	0.000000	2	x	0.417000	=	0.834000
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000
SWL @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.043000	=	0.043000
HWL-LF	3	x	0.000000	=	0.000000	3	x	0.108000	=	0.324000
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load				0.000000	Total Alarm Load				1.292000	

NAC / Output # 5										
Device	Qty	x	Non-Alarm Draw	=	Total	Qty	x	Alarm Draw	=	Total
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000
HWL-LF	7	x	0.000000	=	0.000000	7	x	0.108000	=	0.756000
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load				0.000000	Total Alarm Load				0.847000	

NAC / Output # 6										
Device	Qty	x	Non-Alarm Draw	=	Total	Qty	x	Alarm Draw	=	Total
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000
HWL-LF	7	x	0.000000	=	0.000000	7	x	0.108000	=	0.756000
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load				0.000000	Total Alarm Load				0.847000	

NAC / Output # 7										
Device	Qty	x	Non-Alarm Draw	=	Total	Qty	x	Alarm Draw	=	Total
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load				0.000000	Total Alarm Load				0.000000	

	P2	SK-PS10 EOL Voltage Drop					
	Starting Voltage	20.4 Volts					
	Minimum Voltage @ EOL	16 Volts					
Voltage Drop Warning %	10.00%						
Circuit Name	Current Draw Amps	Wire Type AWG	Resistance Ohms/1000 ft.	Length Feet (One Way)	Actual Resistance Ohms	Voltage @ EOL Volts	Percent Drop Percent
NAC / Output # 1	0.847	#14 Solid	3.07	100	0.61	19.88	2.55%
NAC / Output # 2	1.860	#14 Solid	3.07	100	0.61	19.26	5.60%
NAC / Output # 3	1.644	#14 Solid	3.07	100	0.61	19.39	4.95%
NAC / Output # 4	1.292	#14 Solid	3.07	100	0.61	19.61	3.89%
NAC / Output # 5	0.847	#14 Solid	3.07	125	0.77	19.75	3.19%
NAC / Output # 6	0.847	#14 Solid	3.07	125	0.77	19.75	3.19%
NAC / Output # 7	0.000	#14 Solid	3.07	0	0.00	20.40	0.00%


	x	0.000000	=		x	0.000000	=		
	x	0.000000	=		x	0.000000	=		
Total Standby Load				0.000000	Total Alarm Load				0.847000

NAC / Output # 4										
Device	Qty		Non-Alarm Draw	Total	Qty		Alarm Draw	Total		
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000
HWL-LF	7	x	0.000000	=	0.000000	7	x	0.108000	=	0.756000
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load				0.000000	Total Alarm Load				0.847000	

NAC / Output # 5										
Device	Qty		Non-Alarm Draw	Total	Qty		Alarm Draw	Total		
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000
HWL-LF	5	x	0.000000	=	0.000000	5	x	0.108000	=	0.540000
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load				0.000000	Total Alarm Load				0.631000	

NAC / Output # 6										
Device	Qty		Non-Alarm Draw	Total	Qty		Alarm Draw	Total		
P2WK @ 15 Candela	1	x	0.000000	=	0.000000	1	x	0.091000	=	0.091000
HWL-LF	5	x	0.000000	=	0.000000	5	x	0.108000	=	0.540000
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load				0.000000	Total Alarm Load				0.631000	

NAC / Output # 7										
Device	Qty		Non-Alarm Draw	Total	Qty		Alarm Draw	Total		
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
		x	0.000000	=			x	0.000000	=	
Total Standby Load				0.000000	Total Alarm Load				0.000000	

	P3	SK-PS10 EOL Voltage Drop						
	Starting Voltage	20.4 Volts						
	Minimum Voltage @ EOL	16 Volts						
	Voltage Drop Warning %	10.00%						
	Current Draw	Wire Type	Resistance	Length	Qual Resist	Voltage @ EOL	Percent Drop	
Circuit Name	Amps	AWG	Ohms/1000 ft.	Feet (One Way)	Ohms	Volts	Percent	
NAC / Output # 1	0.631	#14 Solid	3.07	125	0.77	19.92	2.37%	
NAC / Output # 2	0.631	#14 Solid	3.07	125	0.77	19.92	2.37%	
NAC / Output # 3	0.847	#14 Solid	3.07	150	0.92	19.62	3.82%	
NAC / Output # 4	0.847	#14 Solid	3.07	150	0.92	19.62	3.82%	
NAC / Output # 5	0.631	#14 Solid	3.07	150	0.92	19.82	2.85%	
NAC / Output # 6	0.631	#14 Solid	3.07	150	0.92	19.82	2.85%	
NAC / Output # 7	0.000	#14 Solid	3.07	0	0.00	20.40	0.00%	