

JUNIPER VILLAGE BUILDING 300

1208 North Main Steet
Lillington, North Carolina

Hydraulic Calculations

Wayne Automatic Fire Sprinklers Job Number: 1020001



Wayne Automatic Fire Sprinklers, Inc.
4370 Motorsport Drive, Concord NC 28027 - 8977

LOCATION: JUNIPER VILLAGE APTS
PARKER LANE & NORTH MAIN ST

DATE: 3-20-24

TEST MADE BY: P JAMES

TIME: 8:30 AM

REPRESENTATIVE OF: LILLINGTON FIRE DEPT.

WITNESS: JAMES Jammy Re

STATE PURPOSE OF TEST:

CONSUMPTION RATE DURING TEST:

IF PUMPS AFFECT TEST, INDICATE PUMPS OPERATING:

FLOW HYDRANTS: #224 A1 A2 #225 FLOW A3 A4

Size Nozzle: 2.5"

Pilot Reading: 40 psi

Discharge Coefficient: .9 Total GPM

GPM: 1060

STATIC P 80 psi RESIDUAL B 68 psi

PROJECTED RESULTS: At 20 psi Residual gpm, or At psi Residual gpm

REMARKS:

LOCATION MAP: Show line sizes and distance to next cross connected line. Show valves and Hydrant branch size. Indicate North. Show flowing hydrants - Label A1, A2, A3, A4. Show location of Static and Residual - Label B.

Indicate B. Hydrant: Sprinkler: Other (Identify):



Hydraulic Calculations

Wayne Automatic
Fire Sprinklers, Inc.
4370 Motorsport Drive
Concord, NC 28027
704-782-3032

Job Name : Juniper Village- Building 300 - 3rd Floor - Unit C - Common - DA 3.1
Sheet Number : FP3.3
Location : Building 300
Design Area : Design Area 3.1
Contract : 102001
Data File : Building 300- 3rd Floor - Unit C - Common DA 3.1.WXF

HYDRAULIC CALCULATIONS
for

Project name: Juniper Villiage
Location: Building 300
Drawing no: FP3.3
Date: 4-5-2024

Design

Remote area number: Design Area 3.1
Remote area location: Building 300 - 3rd Floor - Unit C Common Area
Occupancy classification: NFPA 13R
Density: .05 - Gpm/SqFt
Area of application: 4 Sprinklers - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: Reliable Mod. F1 Res 44 Residential HSW
No. of sprinklers calculated: 4
In-rack demand: - GPM
Hose streams: - GPM
Total water required (including hose streams): 212.8 - GPM @ 72.1 - Psi
Type of system: Wet Residential NFPA 13R
Volume of dry or preaction system: - Gal

Water supply information

Date: 3-20-2024
Location: Parker Lane and North Main Street - Hydrant #224
Source: Lillington Fire Department

Name of contractor: Wayne Automatic Fire Sprinklers
Address: 4370 Motorsport Drive / Concord, NC
Phone number: 407-877-5514
Name of designer: Donald Hawkins
Authority having jurisdiction: Town of Lillington

Notes: (Include peaking information for gridded systems here.)
(1) The Finished Floor Elevation is 169'. For clarity the Finished Floor elevation on the hydraulic calculations is shown as 0'-0"
(2) A domestic demand of 147 was added at node point DD3 as required by NFPA 13R Section 9.6.

Water Supply Curve C

Wayne Automatic
Juniper Village- Building 300 - 3rd Floor - Unit C - Common - DA 3.1


Page 2
Date 4-5-2024

City Water Supply:

C1 - Static Pressure : 80
C2 - Residual Pressure: 68
C2 - Residual Flow : 1060

Demand:

D1 - Elevation : 14.076
D2 - System Flow : 212.751
D2 - System Pressure : 72.096
Hose (Demand) :
D3 - System Demand : 212.751
Safety Margin : 7.289



Fittings Used Summary

Wayne Automatic
 Juniper Village- Building 300 - 3rd Floor - Unit C - Common - DA 3.1

Page 3
 Date 4-5-2024

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 Tee Branch	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
U*	CPVC 90' Elbow Tyco	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
V*	CPVC Tee Branch Tyco	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Wayne Automatic
 Juniper Village- Building 300 - 3rd Floor - Unit C - Common - DA 3.1

Page 4
 Date 4-5-2024

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
C1	27.5	4.4	13.3	na	16.05	0.05	256	13.3
C2	27.5	4.4	15.19	na	17.15	0.05	256	13.3
C3	27.5	4.4	13.9	na	16.41	0.05	256	13.3
C4	27.5	4.4	13.47	na	16.15	0.05	256	13.3
31	19.25		18.58	na				
36	19.25		20.14	na				
72	19.25		21.66	na				
32	19.25		20.69	na				
37	19.25		22.12	na				
33	19.25		19.26	na				
34	19.25		18.77	na				
46	19.25		19.48	na				
38	19.25		20.82	na				
73	19.25		22.66	na				
47	19.25		25.16	na				
48	19.25		30.92	na				
203	19.25		33.66	na				
204	19.25		34.53	na				
202	19.25		37.52	na				
102	9.25		44.97	na				
101	9.25		45.32	na				
100	9.25		48.0	na				
103	9.25		52.49	na				
TR	1.0		58.3	na				
BR	-3.0		60.53	na				
UG3	-3.0		60.54	na				
BFS3	2.0		58.44	na				
BFD3	2.0		68.41	na	147.0			
DD3	-3.0		70.65	na				
M1	-3.0		71.08	na				
M2	-3.0		71.07	na				
M3	-3.0		71.08	na				
M4	-3.0		71.08	na				
M5	-3.0		71.08	na				
CC1	-10.0		74.14	na				
CC2	-10.0		74.14	na				
TEST	-5.0		72.1	na				

The maximum velocity is 17.75 and it occurs in the pipe between nodes 37 and 203

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Village- Building 300 - 3rd Floor - Unit C - Common - DA 3.1

Page 5
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
C1 to 31	16.05 16.05	0.874 150.0 0.1393	U	4.0 0.0 0.0	8.250 4.000 12.250	13.300 3.573 1.707			K Factor = 4.40 Vel = 8.58	
	0.0 16.05						18.580		K Factor = 3.72	
C2 to 32	17.15 17.15	0.874 150.0 0.1576	U	4.0 0.0 0.0	8.250 4.000 12.250	15.189 3.573 1.930			K Factor = 4.40 Vel = 9.17	
	0.0 17.15						20.692		K Factor = 3.77	
C3 to 33	16.41 16.41	0.874 150.0 0.1452	U	4.0 0.0 0.0	8.250 4.000 12.250	13.904 3.573 1.779			K Factor = 4.40 Vel = 8.78	
	0.0 16.41						19.256		K Factor = 3.74	
C4 to 34	16.15 16.15	0.874 150.0 0.1410	U	4.0 0.0 0.0	8.250 4.000 12.250	13.472 3.573 1.727			K Factor = 4.40 Vel = 8.64	
	0.0 16.15						18.772		K Factor = 3.73	
31 to 36	16.05 16.05	0.874 150.0 0.1394	V	3.0 0.0 0.0	8.170 3.000 11.170	18.580 0.0 1.557			Vel = 8.58	
36 to 72	0.0 16.05	0.874 150.0 0.1394		0.0 0.0 0.0	10.920 0.0 10.920	20.137 0.0 1.522			Vel = 8.58	
72 to 37	0.0 16.05	0.874 150.0 0.1393		0.0 0.0 0.0	3.330 0.0 3.330	21.659 0.0 0.464			Vel = 8.58	
	0.0 16.05						22.123		K Factor = 3.41	
32 to 37	17.15 17.15	0.874 150.0 0.1576	U V	4.0 3.0 0.0	2.080 7.000 9.080	20.692 0.0 1.431			Vel = 9.17	
37 to 203	16.04 33.19	0.874 150.0 0.5348	V	3.0 0.0 0.0	18.580 3.000 21.580	22.123 0.0 11.541			Vel = 17.75	
	0.0 33.19						33.664		K Factor = 5.72	
33 to 38	16.41 16.41	0.874 150.0 0.1452	U V	4.0 3.0 0.0	3.750 7.000 10.750	19.256 0.0 1.561			Vel = 8.78	
	0.0 16.41						20.817		K Factor = 3.60	
34 to 46	16.15 16.15	0.874 150.0 0.1412	V	3.0 0.0 0.0	2.000 3.000 5.000	18.772 0.0 0.706			Vel = 8.64	

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Village- Building 300 - 3rd Floor - Unit C - Common - DA 3.1

Page 6
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
46 to 38	0.0 16.15	0.874 150.0 0.1409	V	3.0 0.0 0.0	6.500 3.000 9.500	19.478 0.0 1.339			Vel = 8.64	
38 to 73	16.41 32.56	0.874 150.0 0.5159		0.0 0.0 0.0	3.580 0.0 3.580	20.817 0.0 1.847			Vel = 17.41	
73 to 47	0.0 32.56	0.874 150.0 0.5159		0.0 0.0 0.0	4.830 0.0 4.830	22.664 0.0 2.492			Vel = 17.41	
47 to 48	0.0 32.56	0.874 150.0 0.5159		0.0 0.0 0.0	11.170 0.0 11.170	25.156 0.0 5.763			Vel = 17.41	
48 to 204	0.0 32.56	0.874 150.0 0.5160	V	3.0 0.0 0.0	4.000 3.000 7.000	30.919 0.0 3.612			Vel = 17.41	
	0.0 32.56					34.531			K Factor = 5.54	
203 to 204	33.19 33.19	1.394 150.0 0.0550		0.0 0.0 0.0	15.750 0.0 15.750	33.664 0.0 0.867			Vel = 6.98	
204 to 202	32.56 65.75	1.394 150.0 0.1949	U	6.0 0.0 0.0	9.330 6.000 15.330	34.531 0.0 2.988			Vel = 13.82	
	0.0 65.75					37.519			K Factor = 10.73	
202 to 102	65.75 65.75	1.394 150.0 0.1950	V	6.0 0.0 0.0	10.000 6.000 16.000	37.519 4.331 3.120			Vel = 13.82	
	0.0 65.75					44.970			K Factor = 9.80	
102 to 101	65.75 65.75	2.003 150.0 0.0334		0.0 0.0 0.0	10.580 0.0 10.580	44.970 0.0 0.353			Vel = 6.69	
101 to 100	0.0 65.75	2.003 150.0 0.0334		0.0 0.0 0.0	80.250 0.0 80.250	45.323 0.0 2.677			Vel = 6.69	
100 to 103	0.0 65.75	2.003 150.0 0.0334		0.0 0.0 0.0	134.500 0.0 134.500	48.000 0.0 4.488			Vel = 6.69	
103 to TR	0.0 65.75	2.003 150.0 0.0334	5U	45.0 0.0 0.0	22.170 45.000 67.170	52.488 3.573 2.241			Vel = 6.69	
	0.0 65.75					58.302			K Factor = 8.61	
TR to BR	65.75 65.75	2.003 150.0 0.0334	Z	6.482 0.0 0.0	8.250 6.482 14.732	58.302 1.732 0.492			Vel = 6.69	
BR to UG3	0.0 65.75	4.28 140.0 0.0009	L	10.75 0.0 0.0	4.000 10.750 14.750	60.526 0.0 0.014			Vel = 1.47	

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Village- Building 300 - 3rd Floor - Unit C - Common - DA 3.1

Page 7
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 65.75						60.540		K Factor = 8.45	
UG3 to BFS3	65.75	4.24 150.0	2L	23.335 0.0	54.000 23.335	60.540 -2.166				
BFS3 to BFD3	65.75 0.0	0.0009 4.026		0.0	77.335	0.068		Vel = 1.49		
BFS3 to BFD3	0.0	4.026 120.0	Zai	0.0	10.000	58.442			** Fixed Loss = 9.95	
BFD3 to DD3	65.75	0.0016		0.0	10.000	0.016		Vel = 1.66		
BFD3 to DD3	147.00	4.24 150.0		0.0	9.420	68.408			Qa = 147.00	
DD3 to M2	212.75	0.0075		0.0	9.420	0.071		Vel = 4.83		
DD3 to M2	0.0	4.24 150.0	G T	3.889 38.891	13.670 42.780	70.645 0.0				
	212.75	0.0076		0.0	56.450	0.429		Vel = 4.83		
	0.0 212.75						71.074		K Factor = 25.24	
M1 to M2	-179.62	7.98 150.0		0.0	31.580	71.082				
M2 to M3	-179.62	-0.0003		0.0	31.580	-0.008		Vel = 1.15		
M2 to M3	212.75	7.98 150.0	2F	27.183 0.0	193.580 27.182	71.074 0.0				
M3 to M4	33.13	0.0		0.0	220.762	0.003		Vel = 0.21		
M3 to M4	0.0	7.98 150.0	F	13.591 0.0	287.750 13.592	71.077 0.0				
M4 to M5	33.13	0.0		0.0	301.342	0.003		Vel = 0.21		
M4 to M5	0.0	7.98 150.0	T	52.855 0.0	76.670 52.855	71.080 0.0				
M5 to M1	33.13	0.0		0.0	129.525	0.002		Vel = 0.21		
M5 to M1	0.0	11.68 150.0	F	17.661 0.0	422.000 17.661	71.082 0.0				
M1 to CC1	33.13	0.0		0.0	439.661	0.0		Vel = 0.10		
M1 to CC1	179.62	11.68 150.0	T G	81.513 8.151	372.830 89.664	71.082 3.032				
CC1 to CC2	212.75	0.0001		0.0	462.494	0.025		Vel = 0.64		
CC1 to CC2	0.0	19.76 150.0		0.0	321.000	74.139				
CC2 to TEST	212.75	0.0		0.0	321.000	0.002		Vel = 0.22		
CC2 to TEST	0.0	6.08 140.0	G L	4.038 12.115	65.000 16.153	74.141 -2.166				
TEST	212.75	0.0015		0.0	81.153	0.121		Vel = 2.35		
	0.0 212.75						72.096		K Factor = 25.06	



Hydraulic Calculations

Wayne Automatic
Fire Sprinklers, Inc.
4370 Motorsport Drive
Concord, NC 28027
704-782-3032

Job Name : Juniper Villiage - Building 300 - 3rd Floor - Corridor - DA 3.2
Sheet Number : FP3.3
Location : Building 300
Design Area : Design Area 3.2
Contract : 102001
Data File : Building 300 - 3rd Floor - Corridor - DA 3.2.WXF

HYDRAULIC CALCULATIONS
for

Project name: Juniper Villiage
Location: Building 300
Drawing no: FP3.3
Date: 4-5-2024

Design

Remote area number: Design Area 3.2
Remote area location: Building 300 - 3rd Floor - Corridor
Occupancy classification: NFPA 13R
Density: .10 - Gpm/SqFt
Area of application: 4 Sprinklers - SqFt
Coverage per sprinkler: 122 - SqFt
Type of sprinklers calculated: Reliable Mod. F3QR Quick Response Dry HSW
No. of sprinklers calculated: 4
In-rack demand: - GPM
Hose streams: - GPM
Total water required (including hose streams): 209.3 - GPM @ 49.3 - Psi
Type of system: Wet Residential NFPA 13R
Volume of dry or preaction system: - Gal

Water supply information

Date: 3-20-2024
Location: Parker Lane and North Main Steet - Hydrant #224
Source: Lillington Fire Department

Name of contractor: Wayne Automatic Fire Sprinklers
Address: 4370 Motorsport Drive / Concord, NC
Phone number: 407-877-5514
Name of designer: Donald Hawkins
Authority having jurisdiction: Town of Lillington

Notes: (Include peaking information for gridded systems here.)

- (1) The Finished Floor elevation is 169'. For clarity the finished floor elevation on the hydraulic calculations is shown as 0'-0"
- (2) A domestic demand of 147 was added at node point DD3 as required by NFPA 13R Section 9.6.

Water Supply Curve C

Wayne Automatic
Juniper Villiage - Building 300 - 3rd Floor - Corridor - DA 3.2


Page 2
Date 4-5-2024

City Water Supply:

C1 - Static Pressure : 80
C2 - Residual Pressure: 68
C2 - Residual Flow : 1060

Demand:

D1 - Elevation : 14.076
D2 - System Flow : 209.298
D2 - System Pressure : 49.283
Hose (Demand) :
D3 - System Demand : 209.298
Safety Margin : 30.120



Fittings Used Summary

Wayne Automatic
Juniper Villiage - Building 300 - 3rd Floor - Corridor - DA 3.2

Page 3
Date 4-5-2024

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 Tee Branch	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
U*	CPVC 90' Elbow Tyco	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
V*	CPVC Tee Branch Tyco	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Corridor - DA 3.2

Page 4
 Date 4-5-2024

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
D1	27.5	5.6	7.0	na	14.82	0.1	122	7.0
D2	27.5	5.6	8.07	na	15.91	0.1	122	7.0
D3	27.5	5.6	7.72	na	15.56	0.1	122	7.0
D4	27.5	5.6	8.18	na	16.01	0.1	122	7.0
41	19.25		12.67	na				
57	19.25		14.1	na				
45	19.25		14.7	na				
42	19.25		13.32	na				
47	19.25		15.64	na				
43	19.25		12.91	na				
44	19.25		13.45	na				
48	19.25		16.35	na				
204	19.25		18.82	na				
201	19.25		19.63	na				
205	19.25		18.52	na				
206	19.25		18.96	na				
207	19.25		19.51	na				
200	19.25		21.33	na				
202	19.25		19.38	na				
102	9.25		24.29	na				
101	9.25		24.36	na				
100	9.25		25.85	na				
103	9.25		29.91	na				
TR	1.0		35.51	na				
BR	-3.0		37.69	na				
UG3	-3.0		37.7	na				
BFS3	2.0		35.59	na				
BFD3	2.0		45.68	na				
DD3	-3.0		47.85	na	147.0			
M1	-3.0		48.27	na				
M2	-3.0		48.27	na				
M3	-3.0		48.27	na				
M4	-3.0		48.27	na				
M5	-3.0		48.27	na				
CC1	-10.0		51.33	na				
CC2	-10.0		51.33	na				
TEST	-5.0		49.28	na				

The maximum velocity is 14.18 and it occurs in the pipe between nodes 48 and 204

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Corridor - DA 3.2

Page 5
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D1 to 41	14.82 14.82	0.874 150.0 0.1203	U V	4.0 3.0 0.0	10.420 7.000 17.420	7.000 3.573 2.095			K Factor = 5.60	
	0.0 14.82						12.668		K Factor = 4.16	
D2 to 42	15.91 15.91	0.874 150.0 0.1371	U	4.0 0.0 0.0	8.250 4.000 12.250	8.069 3.573 1.680			K Factor = 5.60	
	0.0 15.91						13.322		K Factor = 4.36	
D3 to 43	15.56 15.56	0.874 150.0 0.1318	U	4.0 0.0 0.0	8.250 4.000 12.250	7.723 3.573 1.614			K Factor = 5.60	
	0.0 15.56						12.910		K Factor = 4.33	
D4 to 44	16.01 16.01	0.874 150.0 0.1388	U	4.0 0.0 0.0	8.250 4.000 12.250	8.175 3.573 1.700			K Factor = 5.60	
	0.0 16.01						13.448		K Factor = 4.37	
41 to 57	14.82 14.82	0.874 150.0 0.1202	U	4.0 0.0 0.0	7.920 4.000 11.920	12.668 0.0 1.433				Vel = 7.93
57 to 45	0.0 14.82	0.874 150.0 0.1202	V	3.0 0.0 0.0	2.000 3.000 5.000	14.101 0.0 0.601				Vel = 7.93
45 to 205	0.0 14.82	0.874 150.0 0.1203	V	3.0 0.0 0.0	28.750 3.000 31.750	14.702 0.0 3.818				Vel = 7.93
	0.0 14.82						18.520		K Factor = 3.44	
42 to 47	15.91 15.91	0.874 150.0 0.1372	U V	4.0 3.0 0.0	9.920 7.000 16.920	13.322 0.0 2.321				Vel = 8.51
47 to 205	5.06 20.97	0.874 150.0 0.2287	V	3.0 0.0 0.0	9.580 3.000 12.580	15.643 0.0 2.877				Vel = 11.21
	0.0 20.97						18.520		K Factor = 4.87	
43 to 47	15.56 15.56	0.874 150.0 0.1317	U 2V	4.0 6.0 0.0	10.750 10.000 20.750	12.910 0.0 2.733				Vel = 8.32
47 to 48	-5.06 10.5	0.874 150.0 0.0635		0.0 0.0 0.0	11.170 0.0 11.170	15.643 0.0 0.709				Vel = 5.62
	0.0 10.50						16.352		K Factor = 2.60	

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Corridor - DA 3.2

Page 6
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
44 to 48	16.01	0.874 150.0 0.1388	U 2V	4.0 6.0 0.0	10.920 10.000 20.920	13.448 0.0 2.904			Vel = 8.56	
48 to 204	10.50 26.51	0.874 150.0 0.3527	V	3.0 0.0 0.0	4.000 3.000 7.000	16.352 0.0 2.469			Vel = 14.18	
	0.0 26.51					18.821			K Factor = 6.11	
204 to 202	26.51	1.394 150.0 0.0363	U	6.0 0.0 0.0	9.330 6.000 15.330	18.821 0.0 0.557			Vel = 5.57	
	0.0 26.51					19.378			K Factor = 6.02	
201 to 205	-21.41	1.101 150.0 -0.0772	U	5.0 0.0 0.0	9.420 5.000 14.420	19.633 0.0 -1.113			Vel = 7.21	
205 to 206	35.79 14.38	1.101 150.0 0.0370		0.0 0.0 0.0	12.000 0.0 12.000	18.520 0.0 0.444			Vel = 4.85	
206 to 207	0.0 14.38	1.101 150.0 0.0369		0.0 0.0 0.0	14.750 0.0 14.750	18.964 0.0 0.545			Vel = 4.85	
207 to 200	0.0 14.38	1.101 150.0 0.0370	U	5.0 0.0 0.0	44.250 5.000 49.250	19.509 0.0 1.820			Vel = 4.85	
	0.0 14.38					21.329			K Factor = 3.11	
200 to 100	14.38	1.394 150.0 0.0117	V	6.0 0.0 0.0	10.000 6.000 16.000	21.329 4.331 0.187			Vel = 3.02	
	0.0 14.38					25.847			K Factor = 2.83	
201 to 101	21.41	1.394 150.0 0.0245	V	6.0 0.0 0.0	10.000 6.000 16.000	19.633 4.331 0.392			Vel = 4.50	
	0.0 21.41					24.356			K Factor = 4.34	
202 to 102	26.51	1.394 150.0 0.0363	V	6.0 0.0 0.0	10.000 6.000 16.000	19.378 4.331 0.581			Vel = 5.57	
	0.0 26.51					24.290			K Factor = 5.38	
102 to 101	26.51	2.003 150.0 0.0062		0.0 0.0 0.0	10.580 0.0 10.580	24.290 0.0 0.066			Vel = 2.70	
101 to 100	21.41 47.92	2.003 150.0 0.0186		0.0 0.0 0.0	80.250 0.0 80.250	24.356 0.0 1.491			Vel = 4.88	

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Corridor - DA 3.2

Page 7
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
100	14.38	2.003		134.500	25.847				
to		150.0		0.0	0.0				
103	62.3	0.0302		134.500	4.061		Vel = 6.34		
103	0.0	2.003	5U 45.0	22.170	29.908				
to		150.0		45.000	3.573				
TR	62.3	0.0302		67.170	2.029		Vel = 6.34		
	0.0								
	62.30				35.510		K Factor = 10.45		
TR	62.30	2.003	Z 6.482	8.250	35.510				
to		150.0		6.482	1.732				
BR	62.3	0.0302		14.732	0.445		Vel = 6.34		
BR	0.0	4.28	L 10.75	4.000	37.687				
to		140.0		10.750	0.0				
UG3	62.3	0.0009		14.750	0.013		Vel = 1.39		
	0.0								
	62.30				37.700		K Factor = 10.15		
UG3	62.30	4.24	2L 23.335	54.000	37.700				
to		150.0		23.335	-2.166				
BFS3	62.3	0.0008		77.335	0.061		Vel = 1.42		
BFS3	0.0	4.026	Zai 0.0	10.000	35.595				
to		120.0		0.0	10.067		** Fixed Loss = 10.067		
BFD3	62.3	0.0015		10.000	0.015		Vel = 1.57		
BFD3	0.0	4.24		9.420	45.677				
to		150.0		0.0	2.166				
DD3	62.3	0.0007		9.420	0.007		Vel = 1.42		
DD3	147.00	4.24	G 3.889	13.670	47.850		Qa = 147.00		
to		150.0	T 38.891	42.780	0.0				
M2	209.3	0.0074		56.450	0.416		Vel = 4.76		
	0.0								
	209.30				48.266		K Factor = 30.13		
M1	-176.71	7.98		31.580	48.274				
to		150.0		0.0	0.0				
M2	-176.71	-0.0003		31.580	-0.008		Vel = 1.13		
M2	209.30	7.98	2F 27.183	193.580	48.266				
to		150.0		27.182	0.0				
M3	32.59	0.0		220.762	0.002		Vel = 0.21		
M3	0.0	7.98	F 13.591	287.750	48.268				
to		150.0		13.592	0.0				
M4	32.59	0.0		301.342	0.003		Vel = 0.21		
M4	0.0	7.98	T 52.855	76.670	48.271				
to		150.0		52.855	0.0				
M5	32.59	0.0		129.525	0.002		Vel = 0.21		
M5	0.0	11.68	F 17.661	422.000	48.273				
to		150.0		17.661	0.0				
M1	32.59	0.0		439.661	0.001		Vel = 0.10		
M1	176.71	11.68	T 81.513	372.830	48.274				
to		150.0	G 8.151	89.664	3.032				
CC1	209.3	0.0001		462.494	0.024		Vel = 0.63		

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Corridor - DA 3.2

Page 8
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
CC1 to CC2	0.0 209.3	19.76 150.0 0.0	0.0	321.000 0.0 321.000	51.330 0.0 0.001		Vel = 0.22		
CC2 to TEST	0.0 209.3	6.08 140.0 0.0015	G 4.038 L 12.115 0.0	65.000 16.153 81.153	51.331 -2.166 0.118		Vel = 2.31		
	0.0 209.30				49.283		K Factor = 29.81		



Hydraulic Calculations

Wayne Automatic
Fire Sprinklers, Inc.
4370 Motorsport Drive
Concord, NC 28027
704-782-3032

Job Name : Juniper Villiage - Building 300 - 3rd Floor - Unit B - Common - DA 3.3
Sheet Number : FP3.3
Location : Building 300
Design Area : Design Area 3.3
Contract : 102001
Data File : Building 300- 3rd Floor - Unit B - Common DA 3.3.WXF

HYDRAULIC CALCULATIONS
for

Project name: Juniper Village
Location: Building 300
Drawing no: FP3.3
Date: 4-5-2024

Design

Remote area number: Design Area 3.3
Remote area location: Building 300 - 3rd Floor - Unit B Common Area
Occupancy classification: NFPA 13R
Density: .05 - Gpm/SqFt
Area of application: 4 Sprinklers - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: Reliable Mod. F1 Res 44 Residential HSW
No. of sprinklers calculated: 4
In-rack demand: - GPM
Hose streams: - GPM
Total water required (including hose streams): 218.2 - GPM @ 69.8 - Psi
Type of system: Wet Residential NFPA 13R
Volume of dry or preaction system: - Gal

Water supply information

Date: 3-20-2024
Location: North Main Street (Hydrant 224)
Source: Lillington Fire Department

Name of contractor: Wayne Automatic Fire Sprinklers
Address: 4370 Motorsport Drive / Concord, NC
Phone number: 407-877-5514
Name of designer: Donald Hawkins
Authority having jurisdiction: Town of Lillington

Notes: (Include peaking information for gridded systems here.)

- (1) The Finished Floor Elevation is 169'. For clarity the Finished Floor elevation on the hydraulic calculations is shown as 0'-0"
- (2) A domestic demand of 147 was added at node point DD3 as required by NFPA 13R Section 9.6.


Water Supply Curve C

Wayne Automatic
Juniper Villiage - Building 300 - 3rd Floor - Unit B - Common - DA 3.3

Page 2
Date 4-5-2024

City Water Supply:
C1 - Static Pressure : 80
C2 - Residual Pressure: 68
C2 - Residual Flow : 1060

Demand:
D1 - Elevation : 14.076
D2 - System Flow : 218.219
D2 - System Pressure : 69.810
Hose (Demand) :
D3 - System Demand : 218.219
Safety Margin : 9.545



Fittings Used Summary

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Unit B - Common - DA 3.3

Page 3
 Date 4-5-2024

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 Tee Branch	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
U*	CPVC 90' Elbow Tyco	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
V*	CPVC Tee Branch Tyco	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Unit B - Common - DA 3.3

Page 4
 Date 4-5-2024

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
E1	27.5	4.4	19.16	na	19.26	0.05	256	13.3
E2	27.5	4.4	13.3	na	16.05	0.05	256	13.3
E3	27.5	4.4	15.37	na	17.25	0.05	256	13.3
E4	27.5	4.4	17.99	na	18.66	0.05	256	13.3
51	19.25		25.13	na				
55	19.25		27.2	na				
52	19.25		18.58	na				
53	19.25		20.89	na				
56	19.25		21.81	na				
54	19.25		23.82	na				
57	19.25		24.96	na				
45	19.25		25.88	na				
201	19.25		35.42	na				
205	19.25		31.73	na				
206	19.25		30.73	na				
207	19.25		31.05	na				
200	19.25		38.21	na				
102	9.25		43.61	na				
101	9.25		43.61	na				
100	9.25		44.73	na				
103	9.25		49.93	na				
TR	1.0		56.1	na				
BR	-3.0		58.4	na				
UG3	-3.0		58.42	na				
BFS3	2.0		56.33	na				
BFD3	2.0		66.16	na				
DD3	-3.0		68.33	na	147.0			
M1	-3.0		68.79	na				
M2	-3.0		68.78	na				
M3	-3.0		68.78	na				
M4	-3.0		68.79	na				
M5	-3.0		68.79	na				
CC1	-10.0		71.85	na				
CC2	-10.0		71.85	na				
TEST	-5.0		69.81	na				

The maximum velocity is 17.81 and it occurs in the pipe between nodes 56 and 206

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Unit B - Common - DA 3.3

Page 5
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
E1 to 51	19.26 19.26	0.874 150.0 0.1953	U	4.0 0.0 0.0	8.250 4.000 12.250	19.162 3.573 2.393			K Factor = 4.40 Vel = 10.30	
	0.0 19.26						25.128		K Factor = 3.84	
E2 to 52	16.05 16.05	0.874 150.0 0.1393	U	4.0 0.0 0.0	8.250 4.000 12.250	13.300 3.573 1.707			K Factor = 4.40 Vel = 8.58	
	0.0 16.05						18.580		K Factor = 3.72	
E3 to 53	17.25 17.25	0.874 150.0 0.1593	U	4.0 0.0 0.0	8.250 4.000 12.250	15.369 3.573 1.951			K Factor = 4.40 Vel = 9.22	
	0.0 17.25						20.893		K Factor = 3.77	
E4 to 54	18.66 18.66	0.874 150.0 0.1843	U	4.0 0.0 0.0	8.250 4.000 12.250	17.991 3.573 2.258			K Factor = 4.40 Vel = 9.98	
	0.0 18.66						23.822		K Factor = 3.82	
51 to 55	19.26 19.26	0.874 150.0 0.1954	V	3.0 0.0 0.0	7.580 3.000 10.580	25.128 0.0 2.067			Vel = 10.30	
55 to 207	0.0 19.26	0.874 150.0 0.1954	V	3.0 0.0 0.0	16.750 3.000 19.750	27.195 0.0 3.859			Vel = 10.30	
	0.0 19.26						31.054		K Factor = 3.46	
52 to 56	16.05 16.05	0.874 150.0 0.1394		0.0 0.0 0.0	23.170 0.0 23.170	18.580 0.0 3.229			Vel = 8.58	
	0.0 16.05						21.809		K Factor = 3.44	
53 to 56	17.25 17.25	0.874 150.0 0.1593	V	3.0 0.0 0.0	2.750 3.000 5.750	20.893 0.0 0.916			Vel = 9.22	
56 to 206	16.05 33.3	0.874 150.0 0.5378	V	3.0 0.0 0.0	13.580 3.000 16.580	21.809 0.0 8.917			Vel = 17.81	
	0.0 33.30						30.726		K Factor = 6.01	
54 to 57	18.66 18.66	0.874 150.0 0.1843	V	3.0 0.0 0.0	3.170 3.000 6.170	23.822 0.0 1.137			Vel = 9.98	
57 to 45	0.0 18.66	0.874 150.0 0.1842	V	3.0 0.0 0.0	2.000 3.000 5.000	24.959 0.0 0.921			Vel = 9.98	

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Unit B - Common - DA 3.3

Page 6
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
45 to 205	0.0 18.66	0.874 150.0 0.1843	V	3.0 0.0 0.0	28.750 3.000 31.750	25.880 0.0 5.852				Vel = 9.98
	0.0 18.66					31.732				K Factor = 3.31
201 to 205	-41.04 -41.04	1.101 150.0 -0.2572	U	5.0 0.0 0.0	9.330 5.000 14.330	35.418 0.0 -3.686				Vel = 13.83
205 to 206	18.66 -22.38	1.101 150.0 -0.0838		0.0 0.0 0.0	12.000 0.0 12.000	31.732 0.0 -1.006				Vel = 7.54
206 to 207	33.29 10.91	1.101 150.0 0.0222		0.0 0.0 0.0	14.750 0.0 14.750	30.726 0.0 0.328				Vel = 3.68
207 to 200	19.26 30.17	1.101 150.0 0.1456	U	5.0 0.0 0.0	44.170 5.000 49.170	31.054 0.0 7.159				Vel = 10.17
	0.0 30.17					38.213				K Factor = 4.88
201 to 101	41.04 41.04	1.101 150.0 0.2573	V	5.0 0.0 0.0	10.000 5.000 15.000	35.418 4.331 3.860				Vel = 13.83
	0.0 41.04					43.609				K Factor = 6.21
200 to 100	30.17 30.17	1.101 150.0 0.1456	V	5.0 0.0 0.0	10.000 5.000 15.000	38.213 4.331 2.184				Vel = 10.17
	0.0 30.17					44.728				K Factor = 4.51
102 to 101	0.0 0.0	2.003 150.0 0.0		0.0 0.0 0.0	10.580 0.0 10.580	43.609 0.0 0.0				Vel = 0
101 to 100	41.04 41.04	2.003 150.0 0.0139		0.0 0.0 0.0	80.250 0.0 80.250	43.609 0.0 1.119				Vel = 4.18
100 to 103	30.18 71.22	2.003 150.0 0.0387		0.0 0.0 0.0	134.500 0.0 134.500	44.728 0.0 5.203				Vel = 7.25
103 to TR	0.0 71.22	2.003 150.0 0.0387	5U	45.0 0.0 0.0	22.170 45.000 67.170	49.931 3.573 2.598				Vel = 7.25
	0.0 71.22					56.102				K Factor = 9.51
TR to BR	71.22 71.22	2.003 150.0 0.0387	Z	6.482 0.0 0.0	8.250 6.482 14.732	56.102 1.732 0.570				Vel = 7.25
BR to UG3	0.0 71.22	4.28 140.0 0.0011	L	10.75 0.0 0.0	4.000 10.750 14.750	58.404 0.0 0.016				Vel = 1.59

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Villiage - Building 300 - 3rd Floor - Unit B - Common - DA 3.3

Page 7
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 71.22						58.420		K Factor = 9.32	
UG3 to BFS3	71.22	4.24 150.0 0.0010	2L	23.335 0.0 0.0	54.000 23.335 77.335	58.420 -2.166 0.079			Vel = 1.62	
BFS3 to BFD3	0.0 71.22	4.026 120.0 0.0019	Zai	0.0 0.0 0.0	10.000 0.0 10.000	56.333 9.804 0.019			** Fixed Loss = 9.804 Vel = 1.79	
BFD3 to DD3	0.0 71.22	4.24 150.0 0.0010		0.0 0.0 0.0	9.420 0.0 9.420	66.156 2.166 0.009			Vel = 1.62	
DD3 to M2	147.00 218.22	4.24 150.0 0.0080	G T	3.889 38.891 0.0	13.670 42.780 56.450	68.331 0.0 0.450			Qa = 147.00 Vel = 4.96	
	0.0 218.22						68.781		K Factor = 26.31	
M1 to M2	-184.24	7.98 150.0 -0.0003		0.0 0.0 0.0	31.580 0.0 31.580	68.789 0.0 -0.008			Vel = 1.18	
M2 to M3	218.22 33.98	7.98 150.0 0.0	2F	27.183 0.0 0.0	193.580 27.182 220.762	68.781 0.0 0.002			Vel = 0.22	
M3 to M4	0.0 33.98	7.98 150.0 0.0	F	13.591 0.0 0.0	287.750 13.592 301.342	68.783 0.0 0.004			Vel = 0.22	
M4 to M5	0.0 33.98	7.98 150.0 0.0	T	52.855 0.0 0.0	76.670 52.855 129.525	68.787 0.0 0.001			Vel = 0.22	
M5 to M1	0.0 33.98	11.68 150.0 0.0	F	17.661 0.0 0.0	422.000 17.661 439.661	68.788 0.0 0.001			Vel = 0.10	
M1 to CC1	184.24 218.22	11.68 150.0 0.0001	T G	81.513 8.151 0.0	372.830 89.664 462.494	68.789 3.032 0.026			Vel = 0.65	
CC1 to CC2	0.0 218.22	19.76 150.0 0.0		0.0 0.0 0.0	321.000 0.0 321.000	71.847 0.0 0.002			Vel = 0.23	
CC2 to TEST	0.0 218.22	6.08 140.0 0.0016	G L	4.038 12.115 0.0	65.000 16.153 81.153	71.849 -2.166 0.127			Vel = 2.41	
	0.0 218.22						69.810		K Factor = 26.12	



Hydraulic Calculations

Wayne Automatic
Fire Sprinklers, Inc.
4370 Motorsport Drive
Concord, NC 28027
704-782-3032

Job Name : Juniper Village- Building 300 - 2nd Floor - Unit C - Common - DA 3.4
Sheet Number : FP3.3
Location : Building 300
Design Area : Design Area 3.4
Contract : 102001
Data File : Building 300- 2nd Floor - Unit C - Common DA 3.4.WXF

HYDRAULIC CALCULATIONS
for

Project name: Juniper Villiage
Location: Building 300
Drawing no: FP3.3
Date: 4-5-2024

Design

Remote area number: Design Area 3.4
Remote area location: Building 300 - 2nd Floor - Unit C Common Area
Occupancy classification: NFPA 13R
Density: .05 - Gpm/SqFt
Area of application: 3 Sprinklers - SqFt
Coverage per sprinkler: 256 - SqFt
Type of sprinklers calculated: Reliable Mod. F1FR Res Pendants
No. of sprinklers calculated: 3
In-rack demand: - GPM
Hose streams: - GPM
Total water required (including hose streams): 197.1 - GPM @ 57.7 - Psi
Type of system: Wet Residential NFPA 13R
Volume of dry or preaction system: - Gal

Water supply information

Date: 3-20-2024
Location: Parker Lane and North Main Street - Hydrant #224
Source: Lillington Fire Department

Name of contractor: Wayne Automatic Fire Sprinklers
Address: 4370 Motorsport Drive / Concord, NC
Phone number: 407-877-5514
Name of designer: Donald Hawkins
Authority having jurisdiction: Town of Lillington

Notes: (Include peaking information for gridded systems here.)

- (1) The Finished Floor Elevation is 169'. For clarity the Finished Floor elevation on the hydraulic calculations is shown as 0'-0"
- (2) A domestic demand of 147 was added at node point DD3 as required by NFPA 13R Section 9.6.

Water Supply Curve C

Wayne Automatic
Juniper Village- Building 300 - 2nd Floor - Unit C - Common - DA 3.4


Page 2
Date 4-5-2024

City Water Supply:

C1 - Static Pressure : 80
C2 - Residual Pressure: 68
C2 - Residual Flow : 1060

Demand:

D1 - Elevation : 14.076
D2 - System Flow : 197.081
D2 - System Pressure : 57.690
Hose (Demand) :
D3 - System Demand : 197.081
Safety Margin : 21.776



Fittings Used Summary

Wayne Automatic
 Juniper Village- Building 300 - 2nd Floor - Unit C - Common - DA 3.4

Page 3
 Date 4-5-2024

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	NFPA 13 Tee Branch	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
U*	CPVC 90' Elbow Tyco	0	4	5	6	7	9	12	13	0	0	0	0	0	0	0	0	0	0	0	0
V*	CPVC Tee Branch Tyco	0	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zai	Ames 4000SS	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Wayne Automatic
 Juniper Village- Building 300 - 2nd Floor - Unit C - Common - DA 3.4

Page 4
 Date 4-5-2024

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
G1	27.5	4.9	8.69	na	14.45	0.05	256	7.0
G2	27.5	4.9	10.15	na	15.61	0.05	256	7.0
G3	27.5	4.9	16.7	na	20.02	0.05	400	16.7
71	19.25		12.9	na				
36	19.25		13.2	na				
72	19.25		14.45	na				
37	19.25		15.93	na				
73	19.25		21.43	na				
47	19.25		22.44	na				
48	19.25		24.79	na				
203	19.25		25.53	na				
204	19.25		26.26	na				
202	19.25		28.06	na				
102	9.25		34.28	na				
101	9.25		34.49	na				
100	9.25		36.11	na				
103	9.25		38.82	na				
TR	1.0		43.75	na				
BR	-3.0		45.78	na				
UG3	-3.0		45.79	na				
BFS3	2.0		43.66	na				
BFD3	2.0		54.09	na	147.0			
DD3	-3.0		56.32	na				
M1	-3.0		56.7	na				
M2	-3.0		56.69	na				
M3	-3.0		56.69	na				
M4	-3.0		56.69	na				
M5	-3.0		56.7	na				
CC1	-10.0		59.75	na				
CC2	-10.0		59.75	na				
TEST	-5.0		57.69	na				

The maximum velocity is 16.08 and it occurs in the pipe between nodes 72 and 37

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Village- Building 300 - 2nd Floor - Unit C - Common - DA 3.4

Page 5
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
G1 to 71	14.45 14.45	0.874 150.0 0.1149	U	4.0 0.0 0.0	1.500 4.000 5.500	8.694 3.573 0.632			K Factor = 4.90	
	0.0 14.45						12.899		K Factor = 4.02	
G2 to 72	15.61 15.61	0.874 150.0 0.1324	U	4.0 0.0 0.0	1.500 4.000 5.500	10.147 3.573 0.728			K Factor = 4.90	
	0.0 15.61						14.448		K Factor = 4.11	
G3 to 73	20.02 20.02	0.874 150.0 0.2100	U	4.0 0.0 0.0	1.500 4.000 5.500	16.700 3.573 1.155			K Factor = 4.90	
	0.0 20.02						21.428		K Factor = 4.32	
71 to 36	14.45 14.45	0.874 150.0 0.1147		0.0 0.0 0.0	2.580 0.0 2.580	12.899 0.0 0.296				Vel = 7.73
36 to 72	0.0 14.45	0.874 150.0 0.1147		0.0 0.0 0.0	10.920 0.0 10.920	13.195 0.0 1.253				Vel = 7.73
72 to 37	15.61 30.06	0.874 150.0 0.4450		0.0 0.0 0.0	3.330 0.0 3.330	14.448 0.0 1.482				Vel = 16.08
37 to 203	0.0 30.06	0.874 150.0 0.4451	V	3.0 0.0 0.0	18.580 3.000 21.580	15.930 0.0 9.605				Vel = 16.08
	0.0 30.06						25.535		K Factor = 5.95	
73 to 47	20.02 20.02	0.874 150.0 0.2099		0.0 0.0 0.0	4.830 0.0 4.830	21.428 0.0 1.014				Vel = 10.71
47 to 48	0.0 20.02	0.874 150.0 0.2099		0.0 0.0 0.0	11.170 0.0 11.170	22.442 0.0 2.345				Vel = 10.71
48 to 204	0.0 20.02	0.874 150.0 0.2099	V	3.0 0.0 0.0	4.000 3.000 7.000	24.787 0.0 1.469				Vel = 10.71
	0.0 20.02						26.256		K Factor = 3.91	
203 to 204	30.06 30.06	1.394 150.0 0.0458		0.0 0.0 0.0	15.750 0.0 15.750	25.535 0.0 0.721				Vel = 6.32
204 to 202	20.02 50.08	1.394 150.0 0.1178	U	6.0 0.0 0.0	9.330 6.000 15.330	26.256 0.0 1.806				Vel = 10.53
	0.0 50.08						28.062		K Factor = 9.45	

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Village- Building 300 - 2nd Floor - Unit C - Common - DA 3.4

Page 6
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
202 to 102	50.08	1.394 150.0	V	6.0 0.0	10.000 6.000	28.062 4.331				
	50.08	0.1178		0.0	16.000	1.885			Vel = 10.53	
	0.0 50.08						34.278		K Factor = 8.55	
102 to 101	50.08	2.003 150.0		0.0 0.0	10.580 0.0	34.278 0.0				
	50.08	0.0202		0.0	10.580	0.214			Vel = 5.10	
101 to 100	0.0	2.003 150.0		0.0 0.0	80.250 0.0	34.492 0.0				
	50.08	0.0202		0.0	80.250	1.618			Vel = 5.10	
100 to 103	0.0	2.003 150.0		0.0 0.0	134.500 0.0	36.110 0.0				
	50.08	0.0202		0.0	134.500	2.712			Vel = 5.10	
103 to TR	0.0	2.003 150.0	5U	45.0 0.0	22.170 45.000	38.822 3.573				
	50.08	0.0202		0.0	67.170	1.355			Vel = 5.10	
	0.0 50.08						43.750		K Factor = 7.57	
TR to BR	50.08	2.003 150.0	Z	6.482 0.0	8.250 6.482	43.750 1.732				
	50.08	0.0202		0.0	14.732	0.297			Vel = 5.10	
BR to UG3	0.0	4.28 140.0	L	10.75 0.0	4.000 10.750	45.779 0.0				
	50.08	0.0005		0.0	14.750	0.008			Vel = 1.12	
	0.0 50.08						45.787		K Factor = 7.40	
UG3 to BFS3	50.08	4.24 150.0	2L	23.335 0.0	54.000 23.335	45.787 -2.166				
	50.08	0.0005		0.0	77.335	0.041			Vel = 1.14	
BFS3 to BFD3	0.0	4.026 120.0	Zai	0.0 0.0	10.000 0.0	43.662 10.417			* * Fixed Loss = 10.417	
	50.08	0.0010		0.0	10.000	0.010			Vel = 1.26	
BFD3 to DD3	147.00	4.24 150.0		0.0 0.0	9.420 0.0	54.089 2.166			Qa = 147.00	
	197.08	0.0066		0.0	9.420	0.062			Vel = 4.48	
DD3 to M2	0.0	4.24 150.0	G T	3.889 38.891	13.670 42.780	56.317 0.0				
	197.08	0.0066		0.0	56.450	0.372			Vel = 4.48	
	0.0 197.08						56.689		K Factor = 26.18	
M1 to M2	-166.39	7.98 150.0		0.0 0.0	31.580 0.0	56.696 0.0				
	-166.39	-0.0002		0.0	31.580	-0.007			Vel = 1.07	
M2 to M3	197.08	7.98 150.0	2F	27.183 0.0	193.580 27.182	56.689 0.0				
	30.69	0.0		0.0	220.762	0.002			Vel = 0.20	

Final Calculations - Hazen-Williams

Wayne Automatic
 Juniper Village- Building 300 - 2nd Floor - Unit C - Common - DA 3.4

Page 7
 Date 4-5-2024

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
M3 to M4	0.0 30.69	7.98 150.0 0.0	F	13.591 0.0 0.0	287.750 13.592 301.342	56.691 0.0 0.003		Vel = 0.20	
M4 to M5	0.0 30.69	7.98 150.0 0.0	T	52.855 0.0 0.0	76.670 52.855 129.525	56.694 0.0 0.001		Vel = 0.20	
M5 to M1	0.0 30.69	11.68 150.0 0.0	F	17.661 0.0 0.0	422.000 17.661 439.661	56.695 0.0 0.001		Vel = 0.09	
M1 to CC1	166.39 197.08	11.68 150.0 0.0	T G	81.513 8.151 0.0	372.830 89.664 462.494	56.696 3.032 0.022		Vel = 0.59	
CC1 to CC2	0.0 197.08	19.76 150.0 0.0		0.0 0.0 0.0	321.000 0.0 321.000	59.750 0.0 0.001		Vel = 0.21	
CC2 to TEST	0.0 197.08	6.08 140.0 0.0013	G L	4.038 12.115 0.0	65.000 16.153 81.153	59.751 -2.166 0.105		Vel = 2.18	
	0.0 197.08					57.690		K Factor = 25.95	