



## Hydraulic Calculations by HydraCALC

ABL Fire Protection  
300 Hoke Street  
Raleigh, NC 27601  
919-291-7460

Job Name : ILC Dover- Clean Rooms  
Drawing :  
Location : Lillington, NC  
Remote Area : 2  
Contract :  
Data File : ILC Dover Calcs- Clean Rooms.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**JOB NAME** ILC Dover  
**Location** Lillington, NC  
**Drawing #**  
**Contract #**  
**Date**

**DESIGN**

**Remote area #** 2  
**Remote area location** Clean Rooms  
**Occupancy classification** Ordinary Hazard  
**Density** .10 - Gpm/SqFt  
**Area of application** 900 - SqFt  
**Coverage/sprinkler** 130 - SqFt  
**Type of sprinkler calculated** Quick Response Pendent  
**# Sprinklers calculated** 12  
**In-rack demand** - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 493.918 - GPM @ 68.41 - Psi  
**Type of system**  
**Volume of system (dry or pre-action)** - Gal

**WATER SUPPLY INFORMATION**

**Test date** 12-16-24  
**Location** Closest Private Hydrant  
**Source of info** Andrew King Engineering

**CONTRACTOR INFO** ABL Fire Protection

**Address** 300 Hoke St.; Raleigh. NC 27601

**Phone #** 919-291-7460

**Name of designer** Art Lamson

**Authority having jurisdiction** Harnett County

**NOTES:**

text1(35) - invisible


# Water Supply Curve

ABL Fire Protection  
ILC Dover- Clean Rooms

Page 2  
Date 12/18/24

City Water Supply:  
C1 - Static Pressure : 93  
C2 - Residual Pressure: 53  
C2 - Residual Flow : 1234

Demand:  
D1 - Elevation : 6.063  
D2 - System Flow : 243.918  
D2 - System Pressure : 68.410  
Hose ( Demand ) : 250  
D3 - System Demand : 493.918  
Safety Margin : 17.239



# Fittings Used Summary

ABL Fire Protection  
 ILC Dover- Clean Rooms

Page 3  
 Date 12/18/24

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
A	Alarm Rel E1 & E3							7.7	21.5		17		27	29								
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Zwc	Watts 709	Fitting generates a Fixed Loss Based on Flow																				

## Units Summary

Diameter Units           Inches  
 Length Units            Feet  
 Flow Units               US Gallons per Minute  
 Pressure Units          Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL Fire Protection  
ILC Dover- Clean Rooms

Page 4  
Date 12/18/24

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	93.0	53	1234.0	85.648	493.92	68.41

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S2	9.0	5.6	12.13	19.5	0.15 130
S5	9.0	5.6	12.13	19.5	0.15 130
21	10.0	4.71	19.46	20.76	K=K @ EQ2
22	10.0	4.71	19.6	20.83	K=K @ EQ2
23	10.0	4.71	20.23	21.16	K=K @ EQ2
24	10.0	4.71	21.57	21.85	K=K @ EQ2
25	10.0	4.71	17.17	19.5	K=K @ EQ2
26	10.0	4.71	17.3	19.57	K=K @ EQ2
27	10.0	4.71	17.85	19.88	K=K @ EQ2
28	10.0	4.71	19.05	20.54	K=K @ EQ2
29	10.0		25.69		
30	10.0	4.71	17.32	19.58	K=K @ EQ2
31	10.0	4.71	17.44	19.65	K=K @ EQ2
32	10.0	4.71	18.0	19.97	K=K @ EQ2
33	10.0	4.71	19.2	20.62	K=K @ EQ2
C1	10.0		31.58		
C2	10.0		31.58		
C3	10.0		31.58		
C4	10.0		31.58		
C5	10.0		31.91		
A1	19.0		51.53		
A2	19.0		51.53		
A3	19.0		51.54		
A4	19.0		51.57		
A5	19.0		51.61		
A6	19.0		51.68		
A7	19.0		51.77		
A8	19.0		51.89		
A9	19.0		52.04		
TOR	2.0		59.59		
BOR	2.0		60.63		
BASE	0.0		65.3	250.0	
TEST	-4.0		68.41		
B1	19.0		37.89		
B2	19.0		37.89		
B3	19.0		37.88		
B4	19.0		37.85		
B5	19.0		37.81		
B6	19.0		37.75		
CON1	19.0		37.72		

# Flow Summary - NFPA

ABL Fire Protection  
ILC Dover- Clean Rooms

Page 5  
Date 12/18/24

---

## *NODE ANALYSIS (cont.)*

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
B7	19.0		37.73		
B8	19.0		37.74		

# Final Calculations : Hazen-Williams

ABL Fire Protection  
ILC Dover- Clean Rooms

Page 6  
Date 12/18/24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S2 to EQ1	9 0	5.60	19.50 19.5	1 1.049	T	5.0	1.000 5.000 6.000	120 0.1242	12.125 3.898 0.745			Vel = 7.24
EQ1			0.0 19.50						16.768		K Factor = 4.76	
S5 to EQ2	9 0	5.60	19.50 19.5	1 1.049	E T	2.0 5.0	2.250 7.000 9.250	120 0.1242	12.125 3.898 1.149			Vel = 7.24
EQ2			0.0 19.50						17.172		K Factor = 4.71	
21 to 22	10 10	4.71	20.76 20.76	1.5 1.61			8.000 8.000	120 0.0174	19.461 0.0 0.139		K = K @ EQ2	Vel = 3.27
22 to 23	10 10	4.71	20.83 41.59	1.5 1.61			10.000 10.000	120 0.0626	19.600 0.0 0.626		K = K @ EQ2	Vel = 6.55
23 to 24	10 10	4.71	21.17 62.76	1.5 1.61			10.000 10.000	120 0.1340	20.226 0.0 1.340		K = K @ EQ2	Vel = 9.89
24 to C4	10 10	4.71	21.85 84.61	1.5 1.61	T	8.0	35.000 8.000 43.000	120 0.2329	21.566 0.0 10.013		K = K @ EQ2	Vel = 13.33
C4			0.0 84.61						31.579		K Factor = 15.06	
25 to 26	10 10	4.71	19.50 19.5	1.5 1.61			8.000 8.000	120 0.0154	17.172 0.0 0.123		K = K @ EQ2	Vel = 3.07
26 to 27	10 10	4.71	19.57 39.07	1.5 1.61			10.000 10.000	120 0.0558	17.295 0.0 0.558		K = K @ EQ2	Vel = 6.16
27 to 28	10 10	4.71	19.88 58.95	1.5 1.61			10.000 10.000	120 0.1193	17.853 0.0 1.193		K = K @ EQ2	Vel = 9.29
28 to 29	10 10	4.71	20.54 79.49	1.5 1.61	E T	4.0 8.0	20.000 12.000 32.000	120 0.2075	19.046 0.0 6.640		K = K @ EQ2	Vel = 12.53
29 to C5	10 10		79.82 159.31	2 2.067	T	10.0	18.000 10.000 28.000	120 0.2224	25.686 0.0 6.226			Vel = 15.23
C5			0.0 159.31						31.912		K Factor = 28.20	
30 to 31	10 10	4.71	19.58 19.58	1.5 1.61			8.000 8.000	120 0.0156	17.315 0.0 0.125		K = K @ EQ2	Vel = 3.09
31 to 32	10 10	4.71	19.65 39.23	1.5 1.61			10.000 10.000	120 0.0562	17.440 0.0 0.562		K = K @ EQ2	Vel = 6.18

# Final Calculations : Hazen-Williams

ABL Fire Protection  
ILC Dover- Clean Rooms

Page 7  
Date 12/18/24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
32 to 33	10 10	4.71	19.97	1.5			10.000	120	18.002 0.0		K = K @ EQ2	
			59.2	1.61			10.000	0.1202	1.202		Vel = 9.33	
33 to 29	10 10	4.71	20.62	1.5	E T	4.0 8.0	19.000 12.000 31.000	120	19.204 0.0		K = K @ EQ2	
			79.82	1.61				0.2091	6.482		Vel = 12.58	
			0.0 79.82						25.686		K Factor = 15.75	
C1 to C2	10 10		0.0	2			3.000	120	31.579 0.0			
			0.0	2.157			3.000	0	0.0		Vel = 0	
C2 to C3	10 10		0.0	2			12.000	120	31.579 0.0			
			0.0	2.157			12.000	0	0.0		Vel = 0	
C3 to C4	10 10		0.0	2			5.000	120	31.579 0.0			
			0.0	2.157			5.000	0	0.0		Vel = 0	
C4 to C5	10 10		84.61	2.5			15.750	120	31.579 0.0			
			84.61	2.635			15.750	0.0211	0.333		Vel = 4.98	
C5 to CON1	10 19		159.31	2.5	E T	8.237 16.474	40.000 24.711 64.711	120	31.912 -3.898			
			243.92	2.635				0.1499	9.702		Vel = 14.35	
			0.0 243.92						37.716		K Factor = 39.72	
A1 to A2	19 19		26.85	4			13.330	120	51.529 0.0			
			26.85	4.26			13.330	0.0002	0.003		Vel = 0.60	
A2 to A3	19 19		26.86	4			13.330	120	51.532 0.0			
			53.71	4.26			13.330	0.0009	0.012		Vel = 1.21	
A3 to A4	19 19		26.88	4			13.330	120	51.544 0.0			
			80.59	4.26			13.330	0.0019	0.025		Vel = 1.81	
A4 to A5	19 19		26.94	4			13.330	120	51.569 0.0			
			107.53	4.26			13.330	0.0032	0.042		Vel = 2.42	
A5 to A6	19 19		27.03	4			13.330	120	51.611 0.0			
			134.56	4.26			13.330	0.0048	0.064		Vel = 3.03	
A6 to A7	19 19		27.16	4			13.330	120	51.675 0.0			
			161.72	4.26			13.330	0.0068	0.090		Vel = 3.64	
A7 to A8	19 19		27.27	4			13.330	120	51.765 0.0			
			188.99	4.26			13.330	0.0090	0.120		Vel = 4.25	



# Final Calculations : Hazen-Williams

ABL Fire Protection  
ILC Dover- Clean Rooms

Page 8  
Date 12/18/24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A8 to A9	19 19		27.39 216.38	4 4.26			13.330 13.330	120 0.0116	51.885 0.0 0.155			Vel = 4.87
A9 to TOR	19 2		27.54 243.92	4 4.26			13.330 13.330	120 0.0144	52.040 7.363 0.192			Vel = 5.49
TOR to BOR	2 2		0.0 243.92	4 4.26	A G T	22.384 2.633 26.334	20.000 51.351 71.351	120 0.0144	59.595 0.0 1.031			Vel = 5.49
BOR to BASE	2 0		0.0 243.92	6 6.357	Zwc E	0.0 17.603	6.000 17.603	120 0.0021	60.626 4.622 0.049		** Fixed Loss = 3.756	Vel = 2.47
BASE to TEST	0 -4	H250	250.00 493.92	6 6.16	3E T G	60.252 43.037 4.304	100.000 107.593 207.593	140 0.0067	65.297 1.732 1.381			Vel = 5.32
TEST			0.0 493.92						68.410			K Factor = 59.72
B1 to B2	19 19		-26.85 -26.85	4 4.26			13.330 13.330	120 -0.0002	37.894 0.0 -0.003			Vel = 0.60
B2 to B3	19 19		-26.86 -53.71	4 4.26			13.330 13.330	120 -0.0009	37.891 0.0 -0.012			Vel = 1.21
B3 to B4	19 19		-26.88 -80.59	4 4.26			13.330 13.330	120 -0.0019	37.879 0.0 -0.025			Vel = 1.81
B4 to B5	19 19		-26.94 -107.53	4 4.26			13.330 13.330	120 -0.0032	37.854 0.0 -0.042			Vel = 2.42
B5 to B6	19 19		-27.03 -134.56	4 4.26			13.330 13.330	120 -0.0048	37.812 0.0 -0.064			Vel = 3.03
B6 to CON1	19 19		-27.16 -161.72	4 4.26			4.750 4.750	120 -0.0067	37.748 0.0 -0.032			Vel = 3.64
CON1 to B7	19 19		243.92 82.2	4 4.26			8.580 8.580	120 0.0019	37.716 0.0 0.016			Vel = 1.85
B7 to B8	19 19		-27.27 54.93	4 4.26			13.330 13.330	120 0.0010	37.732 0.0 0.013			Vel = 1.24
B8 to B9	19 0		-27.39 27.54	4 4.26			13.330 13.330	120 0.0002	37.745 8.229 0.003			Vel = 0.62
B9			0.0 27.54						45.977			K Factor = 4.06
A1 to B1	19 19		-26.85 -26.85	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0590	51.529 0.0 -13.635			Vel = 5.76

# Final Calculations : Hazen-Williams

ABL Fire Protection  
ILC Dover- Clean Rooms

Page 9  
Date 12/18/24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
B1			0.0 -26.85						37.894		K Factor = -4.36	
A2 to B2	19 19		-26.86	1.25	4T	24.0	207.000 24.000 231.000	120	51.532 0.0		Vel = 5.76	
B2			0.0 -26.86						37.891		K Factor = -4.36	
A3 to B3	19 19		-26.88	1.25	4T	24.0	207.000 24.000 231.000	120	51.544 0.0		Vel = 5.77	
B3			0.0 -26.88						37.879		K Factor = -4.37	
A4 to B4	19 19		-26.94	1.25	4T	24.0	207.000 24.000 231.000	120	51.569 0.0		Vel = 5.78	
B4			0.0 -26.94						37.854		K Factor = -4.38	
A5 to B5	19 19		-27.03	1.25	4T	24.0	207.000 24.000 231.000	120	51.611 0.0		Vel = 5.80	
B5			0.0 -27.03						37.812		K Factor = -4.40	
A6 to B6	19 19		-27.16	1.25	4T	24.0	207.000 24.000 231.000	120	51.675 0.0		Vel = 5.83	
B6			0.0 -27.16						37.748		K Factor = -4.42	
A7 to B7	19 19		-27.27	1.25	4T	24.0	207.000 24.000 231.000	120	51.765 0.0		Vel = 5.85	
B7			0.0 -27.27						37.732		K Factor = -4.44	
A8 to B8	19 19		-27.39	1.25	4T	24.0	207.000 24.000 231.000	120	51.885 0.0		Vel = 5.88	
B8			0.0 -27.39						37.745		K Factor = -4.46	
A9 to B9	19 0		-27.54	1.25	4T	24.0	207.000 24.000 231.000	120	52.040 8.229		Vel = 5.91	
B9			0.0 -27.54						45.977		K Factor = -4.06	