



## Hydraulic Calculations by HydraCALC

ABL Fire Protection  
300 Hoke Street  
Raleigh, NC 27601  
919-291-7460

Job Name : ILC Dover- Interior Renovation and Addition  
Drawing :  
Location : Lillington, NC  
Remote Area : 1  
Contract :  
Data File : ILC Dover Calcs.WXF

---

**HYDRAULIC CALCULATIONS**  
**for**

**JOB NAME** ILC Dover  
**Location** Lillington, NC  
**Drawing #**  
**Contract #**  
**Date**

**DESIGN**

**Remote area #** 1  
**Remote area location** Corridor  
**Occupancy classification** Light Hazard  
**Density** .10 - Gpm/SqFt  
**Area of application** 900 - SqFt  
**Coverage/sprinkler** 130 - SqFt  
**Type of sprinkler calculated** Quick Response Pendent  
**# Sprinklers calculated** 12  
**In-rack demand** - GPM  
**Hose streams** 100 - GPM  
**Total water required (including hose streams)** 362.743 - GPM @ 70574 - Psi  
**Type of system**  
**Volume of system (dry or pre-action)** - Gal

**WATER SUPPLY INFORMATION**

**Test date** 12-16-24  
**Location** Closest Private Hydrant  
**Source of info** Andrew King Engineering

**CONTRACTOR INFO** ABL Fire Protection  
**Address** 300 Hoke St.; Raleigh. NC 27601  
**Phone #** 919-291-7460  
**Name of designer** Art Lamson  
**Authority having jurisdiction** Harnett County  
**NOTES:**

text1(35) - invisible

# Water Supply Curve

ABL Fire Protection  
ILC Dover- Interior Renovation and Addition


Page 2  
Date 12/18/24

## City Water Supply:

C1 - Static Pressure : 93  
C2 - Residual Pressure: 53  
C2 - Residual Flow : 1234

## Demand:

D1 - Elevation : 6.063  
D2 - System Flow : 262.743  
D2 - System Pressure : 70.574  
Hose ( Demand ) : 100  
D3 - System Demand : 362.743  
Safety Margin : 18.273



# Fittings Used Summary

ABL Fire Protection  
 ILC Dover- Interior Renovation and Addition

Page 3  
 Date 12/18/24

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24	
A	Alarm Rel E1 & E3							7.7	21.5		17		27	29								
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Zwc	Watts 709	Fitting generates a Fixed Loss Based on Flow																				

## Units Summary

Diameter Units           Inches  
 Length Units            Feet  
 Flow Units                US Gallons per Minute  
 Pressure Units           Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Flow Summary - NFPA

ABL Fire Protection  
 ILC Dover- Interior Renovation and Addition

Page 4  
 Date 12/18/24

## SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	93.0	53	1234.0	88.847	362.74	70.574

## NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
S2	9.0	5.6	7.0	14.82	0.1 130
S5	9.0	5.6	7.0	14.82	0.1 130
1	10.0	4.4	14.48	16.74	K=K @ EQ1
2	10.0	4.4	15.42	17.27	K=K @ EQ1
3	10.0	4.4	18.98	19.16	K=K @ EQ1
4	10.0	4.4	17.84	18.58	K=K @ EQ1
5	10.0	4.35	17.9	18.41	K=K @ EQ2
6	10.0	4.35	19.02	18.98	K=K @ EQ2
7	10.0	4.35	22.33	20.57	K=K @ EQ2
8	10.0	4.35	22.22	20.51	K=K @ EQ2
9	9.0	5.6	11.0	18.57	0.1 130
10	10.0	4.35	11.59	14.82	K=K @ EQ2
11	10.0	4.35	17.38	18.15	K=K @ EQ2
12	10.0	4.35	19.35	19.15	K=K @ EQ2
13	10.0	4.35	22.18	20.5	K=K @ EQ2
14	10.0	4.35	24.03	21.34	K=K @ EQ2
C1	10.0		23.8		
C2	10.0		23.92		
C3	10.0		25.87		
C4	10.0		28.15		
C5	10.0		30.86		
A1	19.0		53.94		
A2	19.0		53.94		
A3	19.0		53.96		
A4	19.0		53.99		
A5	19.0		54.03		
A6	19.0		54.11		
A7	19.0		54.21		
A8	19.0		54.35		
A9	19.0		54.53		
TOR	2.0		62.11		
BOR	2.0		63.29		
BASE	0.0		68.06	100.0	
TEST	-4.0		70.57		
B1	19.0		38.29		
B2	19.0		38.29		
B3	19.0		38.28		
B4	19.0		38.25		
B5	19.0		38.2		
B6	19.0		38.13		
CON1	19.0		38.09		
B7	19.0		38.11		

# Flow Summary - NFPA

ABL Fire Protection  
ILC Dover- Interior Renovation and Addition

Page 5  
Date 12/18/24

---

## *NODE ANALYSIS (cont.)*

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
B8	19.0		38.12		

# Final Calculations : Hazen-Williams

ABL Fire Protection  
ILC Dover- Interior Renovation and Addition

Page 6  
Date 12/18/24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
S2 to EQ1	9 0	5.60	14.82 14.82	1 1.049	T 5.0	1.000 5.000 6.000	120 0.0747	7.000 3.898 0.448		Vel = 5.50	
EQ1			0.0 14.82					11.346		K Factor = 4.40	
S5 to EQ2	9 0	5.60	14.82 14.82	1 1.049	E T 5.0	2.250 7.000 9.250	120 0.0747	7.000 3.898 0.691		Vel = 5.50	
EQ2			0.0 14.82					11.589		K Factor = 4.35	
1 to 2	10 10	4.4	16.74 16.74	1 1.049		10.000 10.000	120 0.0936	14.481 0.0 0.936		K = K @ EQ1 Vel = 6.21	
2 to 3	10 10	4.4	17.27 34.01	1 1.049	T 5.0	5.250 5.000 10.250	120 0.3475	15.417 0.0 3.562		K = K @ EQ1 Vel = 12.63	
3 to C1	10 10	4.4	37.74 71.75	1.25 1.38	E T 6.0	4.250 9.000 13.250	120 0.3637	18.979 0.0 4.819		K = K @ EQ1 Vel = 15.39	
C1			0.0 71.75					23.798		K Factor = 14.71	
4 to 3	10 10	4.4	18.58 18.58	1 1.049	T 5.0	5.000 5.000 10.000	120 0.1136	17.843 0.0 1.136		K = K @ EQ1 Vel = 6.90	
3			0.0 18.58					18.979		K Factor = 4.26	
5 to 6	10 10	4.35	18.41 18.41	1 1.049		10.000 10.000	120 0.1117	17.899 0.0 1.117		K = K @ EQ2 Vel = 6.83	
6 to 7	10 10	4.35	18.98 37.39	1 1.049		8.000 8.000	120 0.4141	19.016 0.0 3.313		K = K @ EQ2 Vel = 13.88	
7 to C2	10 10	4.35	20.57 57.96	1.25 1.38	T 6.0	0.500 6.000 6.500	120 0.2451	22.329 0.0 1.593		K = K @ EQ2 Vel = 12.43	
C2			0.0 57.96					23.922		K Factor = 11.85	
8 to C2	10 10	4.35	20.51 20.51	1 1.049	T 5.0	7.500 5.000 12.500	120 0.1364	22.217 0.0 1.705		K = K @ EQ2 Vel = 7.61	
C2			0.0 20.51					23.922		K Factor = 4.19	
9 to 10	9 10	5.60	18.57 18.57	1 1.049	E 2.0	7.000 2.000 9.000	120 0.1134	11.001 -0.433 1.021		Vel = 6.89	
10 to 11	10 10	4.35	14.82 33.39	1 1.049	E 2.0	15.250 2.000 17.250	120 0.3359	11.589 0.0 5.794		K = K @ EQ2 Vel = 12.40	

# Final Calculations : Hazen-Williams

ABL Fire Protection  
ILC Dover- Interior Renovation and Addition

Page 7  
Date 12/18/24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
11 to 12	10 10	4.35	18.15	1.25			10.000	120	17.383 0.0		K = K @ EQ2	
			51.54	1.38			10.000	0.1971	1.971		Vel = 11.06	
12 to 13	10 10	4.35	19.14	1.25			8.000	120	19.354 0.0		K = K @ EQ2	
			70.68	1.38			8.000	0.3538	2.830		Vel = 15.16	
13 to C3	10 10	4.35	20.50	1.25	T	6.0	0.500 6.000 6.500	120	22.184 0.0 3.683		K = K @ EQ2	
			91.18	1.38				0.5666			Vel = 19.56	
C3			0.0 91.18						25.867		K Factor = 17.93	
14 to C3	10 10	4.35	21.34	1	T	5.0	7.500 5.000 12.500	120	24.034 0.0 1.833		K = K @ EQ2	
			21.34	1.049				0.1466			Vel = 7.92	
C3			0.0 21.34						25.867		K Factor = 4.20	
C1 to C2	10 10		71.75	2			3.000	120	23.798 0.0			
			71.75	2.157			3.000	0.0413	0.124		Vel = 6.30	
C2 to C3	10 10		78.47	2			12.000	120	23.922 0.0			
			150.22	2.157			12.000	0.1621	1.945		Vel = 13.19	
C3 to C4	10 10		112.52	2			5.000	120	25.867 0.0			
			262.74	2.157			5.000	0.4560	2.280		Vel = 23.07	
C4 to C5	10 10		0.0	2.5			15.750	120	28.147 0.0			
			262.74	2.635			15.750	0.1720	2.709		Vel = 15.46	
C5 to CON1	10 19		0.0	2.5	E T	8.237 16.474	40.000 24.711 64.711	120	30.856 -3.898 11.132		Vel = 15.46	
CON1			0.0 262.74						38.090		K Factor = 42.57	
A1 to A2	19 19		28.92	4			13.330	120	53.940 0.0			
			28.92	4.26			13.330	0.0003	0.004		Vel = 0.65	
A2 to A3	19 19		28.94	4			13.330	120	53.944 0.0			
			57.86	4.26			13.330	0.0010	0.013		Vel = 1.30	
A3 to A4	19 19		28.95	4			13.330	120	53.957 0.0			
			86.81	4.26			13.330	0.0021	0.028		Vel = 1.95	
A4 to A5	19 19		29.02	4			13.330	120	53.985 0.0			
			115.83	4.26			13.330	0.0037	0.049		Vel = 2.61	
A5 to A6	19 19		29.11	4			13.330	120	54.034 0.0			
			144.94	4.26			13.330	0.0056	0.074		Vel = 3.26	



# Final Calculations : Hazen-Williams

ABL Fire Protection  
 ILC Dover- Interior Renovation and Addition

Page 8  
 Date 12/18/24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
A6 to A7	19 19		29.26 174.2	4 4.26			13.330 13.330	120 0.0077	54.108 0.0 0.103			Vel = 3.92
A7 to A8	19 19		29.38 203.58	4 4.26			13.330 13.330	120 0.0104	54.211 0.0 0.138			Vel = 4.58
A8 to A9	19 19		29.49 233.07	4 4.26			13.330 13.330	120 0.0133	54.349 0.0 0.177			Vel = 5.25
A9 to TOR	19 2		29.67 262.74	4 4.26			13.330 13.330	120 0.0165	54.526 7.363 0.220			Vel = 5.91
TOR to BOR	2 2		0.0 262.74	4 4.26	A G T	22.384 2.633 26.334	20.000 51.351 71.351	120 0.0166	62.109 0.0 1.183			Vel = 5.91
BOR to BASE	2 0		0.0 262.74	6 6.357	Zwc E	0.0 17.603	6.000 17.603 23.603	120 0.0024	63.292 4.714 0.056		** Fixed Loss = 3.848	Vel = 2.66
BASE to TEST	0 -4	H100	100.00 362.74	6 6.16	3E T G	60.252 43.037 4.304	100.000 107.593 207.593	140 0.0038	68.062 1.732 0.780			Vel = 3.91
TEST			0.0 362.74						70.574			K Factor = 43.18
B1 to B2	19 19		-28.92 -28.92	4 4.26			13.330 13.330	120 -0.0003	38.295 0.0 -0.004			Vel = 0.65
B2 to B3	19 19		-28.94 -57.86	4 4.26			13.330 13.330	120 -0.0011	38.291 0.0 -0.014			Vel = 1.30
B3 to B4	19 19		-28.95 -86.81	4 4.26			13.330 13.330	120 -0.0021	38.277 0.0 -0.028			Vel = 1.95
B4 to B5	19 19		-29.02 -115.83	4 4.26			13.330 13.330	120 -0.0037	38.249 0.0 -0.049			Vel = 2.61
B5 to B6	19 19		-29.11 -144.94	4 4.26			13.330 13.330	120 -0.0055	38.200 0.0 -0.073			Vel = 3.26
B6 to CON1	19 19		-29.26 -174.2	4 4.26			4.750 4.750	120 -0.0078	38.127 0.0 -0.037			Vel = 3.92
CON1 to B7	19 19		262.75 88.55	4 4.26			8.580 8.580	120 0.0022	38.090 0.0 0.019			Vel = 1.99
B7 to B8	19 19		-29.38 59.17	4 4.26			13.330 13.330	120 0.0011	38.109 0.0 0.014			Vel = 1.33
B8 to B9	19 0		-29.50 29.67	4 4.26			13.330 13.330	120 0.0003	38.123 8.229 0.004			Vel = 0.67

# Final Calculations : Hazen-Williams

ABL Fire Protection  
ILC Dover- Interior Renovation and Addition

Page 9  
Date 12/18/24

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
B9			0.0 29.67						46.356		K Factor = 4.36	
A1 to B1	19 19		-28.92 -28.92	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0677	53.940 0.0 -15.645		Vel = 6.20	
B1			0.0 -28.92						38.295		K Factor = -4.67	
A2 to B2	19 19		-28.93 -28.93	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0678	53.944 0.0 -15.653		Vel = 6.21	
B2			0.0 -28.93						38.291		K Factor = -4.68	
A3 to B3	19 19		-28.96 -28.96	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0679	53.957 0.0 -15.680		Vel = 6.21	
B3			0.0 -28.96						38.277		K Factor = -4.68	
A4 to B4	19 19		-29.02 -29.02	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0681	53.985 0.0 -15.736		Vel = 6.22	
B4			0.0 -29.02						38.249		K Factor = -4.69	
A5 to B5	19 19		-29.11 -29.11	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0685	54.034 0.0 -15.834		Vel = 6.24	
B5			0.0 -29.11						38.200		K Factor = -4.71	
A6 to B6	19 19		-29.26 -29.26	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0692	54.108 0.0 -15.981		Vel = 6.28	
B6			0.0 -29.26						38.127		K Factor = -4.74	
A7 to B7	19 19		-29.38 -29.38	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0697	54.211 0.0 -16.102		Vel = 6.30	
B7			0.0 -29.38						38.109		K Factor = -4.76	
A8 to B8	19 19		-29.50 -29.5	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0702	54.349 0.0 -16.226		Vel = 6.33	
B8			0.0 -29.50						38.123		K Factor = -4.78	
A9 to B9	19 0		-29.67 -29.67	1.25 1.38	4T	24.0	207.000 24.000 231.000	120 -0.0710	54.526 8.229 -16.399		Vel = 6.36	
B9			0.0 -29.67						46.356		K Factor = -4.36	

# Final Calculations : Hazen-Williams

ABL Fire Protection  
ILC Dover- Interior Renovation and Addition

Page 10  
Date 12/18/24

---

Node1	Elev1	K	Qa	Nom	Fitting		Pipe	CFact	Pt			
to					or		Ftngs		Pe	*****	Notes	*****
Node2	Elev2	Fact	Qt	Act	Equiv	Len	Total	Pf/Ft	Pf			

---