



Application for Plan Review

Reviewed for Fire Code Compliance



Leslie Jackson

11/25/2025 8:10:09 AM

Application # _____

Date Received: _____

Received By: _____

Name of Project: _____

McDonald's #10721

Physical Address of Project: _____

*102 West Cornelius Harnett Blvd
Lillington, NC 27546-7853
BFPE International*

Plans Submitted By: _____

Project Phone: _____

Contact Person/Address: _____

*BECKY O'BRIEN @ BFPE
115 Best Wood Dr.
Clayton, NC 27520*

Contact Email: _____

BOBRIEN@BFPE.COM

Contact Phone: _____

(919) 550 2699x119 () -

Contractor's Name/Info: _____

Stanwell Construction

Kelly Thomas SC Supt

Dillon Brophy SC PM (727) 372-0781


Contractor's Phone: _____

(864) 621-6994


- Plans that are submitted will be reviewed as quickly as possible with an average time of review between 7-10 working days.
- Status checks may be conducted on plan reviews by visiting the website <http://hteweb.harnett.org/Click2GovBP/Index.jsp> or by calling the Harnett County Central Permitting Office (910-893-7525, Option #2), or the Harnett County Fire Marshal's Office (910-893-7580).
- Approved plans must be picked up from the Central Permitting Office and all fees paid before any required inspections can be conducted.

ANSUL R-102 DETAILS

- DETECTOR TEMP PER ANSUL MANUAL PAGE 3-11 REV 11, 4-71 TO 4-72 REV 11
- ALL PIPING 3/8" SCH. 40 BLACK STEEL PER ANSUL MANUAL PAGE 4-67 TO 4-69, REV 11
- ALL FITTINGS 3/8" # BLACK STEEL PER ANSUL MANUAL PAGE 4-67 TO 4-69, REV 11
- PULL STATION IN AISLE OF EGRESS. SEE SHEET K10 FOR EXACT LOCATION.
- PULL STATIONS AND HOODS TO BE LABELED WITH CORRESPONDING LABELS.
- GAS & ELECTRIC APPLIANCES WITH AUTOMATIC SHUT-OFF
- MICRO SWITCH FOR SHUT DOWNS AND/OR ALARM TIE IN



SECTION 4 - SYSTEM DESIGN			
UL EX970 ILC EX970 REV. 13 2022-NOV-14			
PAGE 4-4			
ANSUL R-102 Restaurant Fire Suppression Manual (Part No. 418087)			
NOZZLE PLACEMENT REQUIREMENTS (Continued)			
Transition Protection			
Transition protection is required at a point in the transition where the perimeter or the diameter is equal to or less than the maximum nozzle size that is being protected. The nozzle must be so positioned that the area at the point of transition is no greater than 10 in. (254 mm) from the nozzle. If the nozzle is mounted closer than 10 in. (254 mm) to precipitator placement, the nozzle may be mounted closer than 10 in. (254 mm). See Figure 4-5.			
Note: Ducts with a transition that is more than 4 ft (1.2 m) in height require nozzle placement 2 in. (51 mm) to 20 in. (508 mm) from the point of transition using the same nozzle placement requirements as for a transition.			
If physically impossible to do so, the nozzle may be mounted closer than 10 in. (254 mm).			
FIGURE 4-5			
Electrostatic Precipitator Protection			
Some restaurant ventilating ducts have an electrostatic precipitator installed at or near the base. These precipitators are generally used to remove dust and other particles from the exhaust air.			
Ducts with precipitators located at or near the base can be protected using duct nozzles above the precipitator and 1/2N nozzles for the precipitator. One 1/2N nozzle must be used for each 1/2N nozzle for the precipitator. See Figure 4-6, indicating that it is a 1/2-flow nozzle and must be counted as 1/2 the nozzle size.			
When protecting ducts equipped with precipitators, the duct nozzles must be installed above the precipitator and aimed at the precipitator. If the precipitator is located in a duct, the nozzles must be positioned according to duct protection guidelines. If the area above the precipitator is a transition, the transition guidelines must be followed.			
FIGURE 4-6			
Note: For protection of Pollution Control Units (PCUs) or scrubbers with or without precipitators, contact Technical Service for a non-UL listed recommended application.			



SECTION 4 - SYSTEM DESIGN			
UL EX970 ILC EX970 REV. 13 2022-NOV-14			
PAGE 4-4			
ANSUL R-102 Restaurant Fire Suppression Manual (Part No. 418087)			
APPLIANCE PROTECTION (Continued)			
Fryer - Single Nozzle Protection (Continued)			
TABLE 4-2: MAXIMUM AREA DIMENSIONS - SINGLE NOZZLE FRYER PROTECTION			
Max. Size Overall With Dripboard			
Full Frypot Only	Max. Size Overall With Dripboard	Type of Nozzle	Nozzle Height Above Top of Frypot
14 in. x 15 in. (356 mm x 381 mm)	230	27 in. to 47 in. (686 mm to 1,193 mm)	See Figure 4-15 and Figure 4-16
Full Frypot	245	20 in. to 27 in. (508 mm to 685 mm)	See Figure 4-15 and Figure 4-16
14 in. x 15 in. (356 mm x 381 mm)	290	13 in. to 16 in. (330 mm to 406 mm)	See Figure 4-17
Full Frypot	3N	10 in. to 16 in. (254 mm to 406 mm)	See Figure 4-18
14 in. x 15 in. (356 mm x 381 mm)	Full or Split Vat	14 1/2 in. x 26 1/2 in. (368 mm x 673 mm)	See Figure 4-17
14 1/2 in. x 14 in. (368 mm x 358 mm)	290	10 in. to 27 in. (254 mm to 685 mm)	See Figure 4-17
FIGURE 4-7			
FIGURE 4-8			
FIGURE 4-9			
FIGURE 4-10			
FIGURE 4-11			
FIGURE 4-12			
FIGURE 4-13			
FIGURE 4-14			
FIGURE 4-15			
FIGURE 4-16			
FIGURE 4-17			
FIGURE 4-18			
FIGURE 4-19			
FIGURE 4-20			

SECTION 4 - SYSTEM DESIGN			
UL EX970 ILC EX970 REV. 13 2022-NOV-14			
PAGE 4-4			
ANSUL R-102 Restaurant Fire Suppression Manual (Part No. 418087)			
APPLIANCE PROTECTION (Continued)			
Fryer - Single Nozzle Protection (Continued)			
TABLE 4-2: MAXIMUM AREA DIMENSIONS - SINGLE NOZZLE FRYER PROTECTION (Continued)			
Max. Size Overall With Dripboard	Max. Size Overall With Dripboard	Type of Nozzle	Nozzle Height Above Top of Frypot
Full Frypot	14 1/2 in. x 26 1/2 in. (368 mm x 673 mm)	Full Vat	16 in. to 21 in. (406 mm to 533 mm)
14 1/2 in. x 21 in. (368 mm x 533 mm)	290	13 in. to 16 in. (330 mm to 406 mm)	See Figure 4-17
14 in. x 21 in. (356 mm x 533 mm)	3N	10 in. to 16 in. (254 mm to 406 mm)	See Figure 4-18
14 1/2 in. x 14 in. (368 mm x 358 mm)	Full Vat	14 1/2 in. x 26 1/2 in. (368 mm x 673 mm)	See Figure 4-17
14 1/2 in. x 14 in. (368 mm x 358 mm)	290	10 in. to 27 in. (254 mm to 685 mm)	See Figure 4-17
FIGURE 4-17			
FIGURE 4-18			
FIGURE 4-19			
FIGURE 4-20			

SECTION 4 - SYSTEM DESIGN			
UL EX970 ILC EX970 REV. 13 2022-NOV-14			
PAGE 4-4			
ANSUL R-102 Restaurant Fire Suppression Manual (Part No. 418087)			
APPLIANCE PROTECTION (Continued)			
Fryer - Single Nozzle Protection (Continued)			
TABLE 4-2: MAXIMUM AREA DIMENSIONS - SINGLE NOZZLE FRYER PROTECTION (Continued)			
Max. Size Overall With Dripboard	Max. Size Overall With Dripboard	Type of Nozzle	Nozzle Height Above Top of Frypot
Full Frypot	14 1/2 in. x 26 1/2 in. (368 mm x 673 mm)	Full Vat	16 in. to 21 in. (406 mm to 533 mm)
14 1/2 in. x 21 in. (368 mm x 533 mm)	290	13 in. to 16 in. (330 mm to 406 mm)	See Figure 4-17
14 in. x 21 in. (356 mm x 533 mm)	3N	10 in. to 16 in. (254 mm to 406 mm)	See Figure 4-18
14 1/2 in. x 14 in. (368 mm x 358 mm)	Full Vat	14 1/2 in. x 26 1/2 in. (368 mm x 673 mm)	See Figure 4-17
14 1/2 in. x 14 in. (368 mm x 358 mm)	290	10 in. to 27 in. (254 mm to 685 mm)	See Figure 4-17
FIGURE 4-17			
FIGURE 4-18			
FIGURE 4-19			
FIGURE 4-20			






SECTION 4 - SYSTEM DESIGN			
UL EX970 ILC EX970 REV. 13 2022-NOV-14			
PAGE 4-4			
ANSUL R-102 Restaurant Fire Suppression Manual (Part No. 418087)			
APPLIANCE PROTECTION (Continued)			
Fryer - Single Nozzle Protection (Continued)			
TABLE 4-2: MAXIMUM AREA DIMENSIONS - SINGLE NOZZLE FRYER PROTECTION (Continued)			
Max. Size Overall With Dripboard	Max. Size Overall With Dripboard	Type of Nozzle	Nozzle Height Above Top of Frypot
Full Frypot	14 1/2 in. x 26 1/2 in. (368 mm x 673 mm)	Full Vat	16 in. to 21 in. (406 mm to 533 mm)
14 1/2 in. x 21 in. (368 mm x 533 mm)	290	13 in. to 16 in. (330 mm to 406 mm)	See Figure 4-17
14 in. x 21 in. (356 mm x 533 mm)	3N	10 in. to 16 in. (254 mm to 406 mm)	See Figure 4-18
14 1/2 in. x 14 in. (368 mm x 358 mm)	Full Vat	14 1/2 in. x 26 1/2 in. (368 mm x 673 mm)	See Figure 4-17
14 1/2 in. x 14 in. (368 mm x 358 mm)	290	10 in. to 27 in. (254 mm to 685 mm)	See Figure 4-17
FIGURE 4-17			
FIGURE 4-18			
FIGURE 4-19			
FIGURE 4-20			

SECTION 4 - SYSTEM DESIGN			

<tbl_r cells="1" ix="


ANSUL R-102 DETAILS

- * DETECTOR TEMP PER ANSUL MANUAL PAGE 3-11 REV 11, 4-71 TO 4-72 REV 11
- * ALL PIPING 3/8" SCH. 40 BLACK STEEL PER ANSUL MANUAL PAGE 4-67 TO 4-69, REV 11
- * ALL FITTINGS 3/8" BLACK STEEL PER ANSUL MANUAL PAGE 4-67 TO 4-69, REV 11
- * PULL STATION IN AISLE OF EGRESS. SEE SHEET K1.0 FOR EXACT LOCATION.
- * PULL STATIONS AND HOODS TO BE LABELED WITH CORRESPONDING LABELS.
- * ELECTRIC APPLIANCES WITH AUTOMATIC SHUT-OFF
- * MICRO SWITCH FOR SHUT DOWNS AND/OR ALARM TIE IN



Seal

ANSUL



2 Duct nozzle positioned
at point in transition 100° perimeter max.
per attached ANSUL R-102 Manual
Page 4-4

UL 300
11 flow points available
7 flow points utilized







2W

3-G

1N




ANSUL R-102 DETAILS

- * DETECTOR TEMP PER ANSUL MANUAL PAGE 3-11 REV 11, 4-71 TO 4-72 REV 11
- * ALL PIPING 3/8" SCH. 40 BLACK STEEL PER ANSUL MANUAL PAGE 4-67 TO 4-69, REV 11
- * ALL FITINGS 3/8" 150# BLACK STEEL PER ANSUL MANUAL PAGE 4-67 TO 4-69, REV 11
- * PULL STATION IN AISLE OF EGRESS. SEE SHEET K1.0 FOR EXACT LOCATION.
- * PULL STATIONS AND HOODS TO BE LABELED WITH CORRESPONDING LABELS.
- * GAS APPLIANCES WITH AUTOMATIC SHUT-OFF
- * MICRO SWITCH FOR SHUT DOWNS AND/OR ALARM TIE IN



McDonald's #10721
1102 West Cornelius Harnett Blvd
Lillington, NC 27546

ontents:
ul R-102 Fire System
Fryer Station



McDonald's #10721
102 West Cornelius Harnett Blvd
Lillington, NC 27546



DRAWN BY: MWE
CHECKED BY:
SCALE: N.T.S.
SHEET NO. 4 OF 4 SHEETS
DATE: NOVEMBER 6, 2025
PROJECT NO: N/A

Sheet Contents:
Factory Provided Sheets

DRAWING NO.:
FS400

NOTICE - THIS DRAWING, DATA AND DESIGNS THEREON SHALL NOT BE DUPLICATED, USED, OR DISCLOSED TO OTHERS FOR PROCUREMENT OR OTHER PURPOSES, EXCEPT AS OTHERWISE AUTHORIZED BY CONTRACT, WITHOUT WRITTEN PERMISSION OF BFPE INTERNATIONAL.

DATE: _____
BY: _____
REVISION: _____
WORK: _____
Seal _____
Seal _____
Seal _____
Seal _____