

# **William H. Clark, Jr, PE Consulting Engineer**

27 March 2025


Nick Sykes  
Wilkinson Design  
1033 Wade Avenue, Ste 100  
Raleigh, NC 27605

Re: Changes to Permitted Plans  
Celtic Crawlers Off-Road Garage  
214 Fish Drive  
Angier, NC 27504

Per the request of the inspection authority, I provide this letter expressing my agreement with the following changes:

- 1) Please reuse the (2) combination exit sign/egress light fixtures at the entry doors. That would replace (2) new exit signs and (2) new egress lights I showed.
- 2) I accept deleting the floor outlet and providing a wall receptacle behind the workstation.
- 3) I accept the new exterior wall locations for the exhaust fan and outside air louvers rather than on the roof.
- 4) I accept the new locations for the HVAC equipment and the routing of all drainage out to the Plan East side of the drawing. Please use a fire-rated access panel/door.
- 5) I accept the American Standard equipment as a substitution for the specified Goodman equipment.
- 6) I accept reducing the quantity of diffusers and the increased duct sizes on the remaining ones.

Based on a satisfactory electrical inspection, I recommend approval by the local authority having jurisdiction. If you have any more questions, please contact me.



William H. Clark, Jr., PE  
NC PE License 010985

