



2983 ARROWHEAD RD DUNN, NC 28334, City of Dunn, NC

Latest location update: 8/25/2025, 9:31 AM

Category

Commercial building

Work type

New

SHOW MAP 

HIDE FULL DATA 

-  [Show messages](#)
-  Email notifications

✓ YES

PIN

1515-06-6718.000

Permit number

COM-NEW-2025-026

Secondary ID

Minimal Flood Risk

Municipal ID

49309

Zoning

UNCLASSIFIED (000) INDUSTRIAL (000) (00000)

[BACK TO DASHBOARD](#)

MORE ACTIONS 

Ward

Submitted

8/18/2025, 5:05 PM

 **APPLICATION** >  **WORK & CONSTRUCTION**

CURRENT STEP: CHANGES REQUESTED
1 / 1

Building Review

REVIEW RESULT

1. Design wind speed must be minimum 120 mph.
 2. Engineer seal and signature must be on each page of the structural plans.

Review date: 9/10/2025, 7:36 AM
Reviewer: Michael Johnson [Direct message](#) 

MARK AS DONE

3 **PARTIES TO THE APPLICATION** [Open](#) 

5 **APPLICATION FORMS** [Open](#) 

ATTACHMENTS

Open ▾

4 REVIEWS

Close ▲

Review	Status	Latest review comment	Reviewer	Review done
General Application Review	Reviewed		Lisa Musmeci	8/19/2025, 2:12 PM
Planning & Zoning review	Reviewed	Site-25-07 reviewed by Planning department. Follow the approved plans.	Debra Creighton	8/20/2025, 8:35 AM
Building Review	Changes requested	Design wind speed must be minimum 120 mph. Engineer seal and signature must be on each pag... Show more	Michael Johnson	
Fire Review	Unreviewed		Matthew Starling	

Back to top 

release/250910 (6cefcc3cdd7074bcfa925b78b17253ac2d9d269f) 2025-09-12T06:59:44.202Z (3)