HA ETT COUNTY HEALTH DEPART NT
VIRONMENTAL HEALTH SECT

№ 14724

OPERATIONS PERMIT

Name: (owner) Medlens Custom Home Bldrs

☑ New Installation ☑ Septic Tank

Property Location: SR# 1443 Lafayette Rd

☐ Repairs ☑ Nitrification Line

Subdivision Victoria Hills Lot # 6

TAX ID# _____ Quadrant # _____

Contractor: Dennis Medlen Registration # _____

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☐ Well ☑ Public ☐ Community

Distance From Well: 50' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☑ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field: No. of ditches 3; exact length of each ditch 100 ft.; width of ditches 3 ft.; depth of ditches 16-18 in.

French Drain: — Linear feet

Date: 7-14-00

PERMIT NO. 13699

Inspected by: James C Marshall
Environmental Health Specialist