

IMPROVEMENT PERM

01/22/00

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Res Prop. Joyce Scott [X] New Installation [X] Septic Tank
Property Location: SR# NC 27 [] Repairs [X] Nitrification Line

Subdivision Longleaf Acres Lot # 3

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (28x70) Lot Size: 1/2 AC


Basement with Plumbing: [] Garage: [] MUST USE filter and
Water Supply: [] Well [X] Public [] Community Septic tank marker
Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: [X] Conventional [] Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface Drainage Field No. of ditches 1 exact length of each ditch 350 ft. width of ditches 3 ft. depth of ditches 18 in.
French Drain Required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 02-02-2000
Signed: Joe Weston Environmental Health Specialist



MUST meet onsite Must maintain all set backs Do not DRIVE OR Pack on septic system

AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 13728. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Res. Prop. Joyce Scott

Name: _____ Telephone # 910-822-4540

Address: _____

Property Location: SR # NC 27 Road Name _____

New Installation Repair _____ Septic Tank Nitrification Lines

Subdivision Longleaf Ac. Lot # 3

Number of Bedrooms Proposed: 3 (28x70) Lot size: 1/2 AC

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well _____ Public Minimum Well Setback: _____ ft.

Type of System: Conventional Other _____

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 1 Length of lines 350

Width of ditches 3 ft. Depth of ditches 18 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: [Signature] Date: 02-02-2000