

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES								
		1	2	3	4	5	6	7	8	9
LANDSCAPE POSITION	.1940									
SLOPE (%)	.1940									
HORIZON 1 DEPTH		0-18	0-26	0-28	0-34	0-20	0-34			
Texture Group	.1941(A)(1)	SL	SL	LS	LS	LS	LS			
Consistence	.1941	VF	VF	VF	VF	VF	VF			
Structure	.1941(A)(2)	G	G	C	G	G	C			
Mineralogy	.1941(A)(3)	NFX	NXP	NEV	NEV	NEV	NEX			
HORIZON 2 DEPTH		18-24			24-26	20-26	18-26			
Texture Group	.1941(A)(1)	SL			SL	SL	SL			
Consistence	.1941	F			F	F	F			
Structure	.1941(A)(2)	SBR			SBC	SBC	SBA			
Mineralogy	.1941(A)(3)	SXP			SXP	SXP	SXA			
HORIZON 3 DEPTH		24								
Texture Group	.1941(A)(1)	Loak								
Consistence	.1941									
Structure	.1941(A)(2)									
Mineralogy	.1941(A)(3)									
HORIZON 4 DEPTH										
Texture Group	.1941(A)(1)									
Consistence	.1941									
Structure	.1941(A)(2)									
Mineralogy	.1941(A)(3)									
SOIL WETNESS	.1942									
RESTRICTIVE HORIZON	.1944									
SAPROLITE	.1943/1956									
CLASSIFICATION	.1948		S	S	PS	PS	PS			
LONG TERM ACCEPTANCE RATE	.1955		.8	.8	.6	.4	.4			

□

(3)

(5)


(1)

(6)

Southeastern Soil & Environmental Associates, Inc.

P.O. Box 9321
 Fayetteville, NC 28311-7696
 Phone/Fax (910) 822-4540

THE GLEN Lot 7
 PROPOSED SEPTIC




SOIL NOTES (INITIAL AREA)

- 0-36" LSAND (VF, M(L))
- LTAR 0.8 gpd/ft²
- cr 2 > 36"
- French Drain Recommended (on clay layer)
- * to serve lots 7 & 8

SOIL/SITE EVALUATION • SOIL PHYSICAL ANALYSIS • WETLANDS MAPPING • LAND USE/SUBDIVISION PLANNING
 GROUNDWATER DRAINAGE/MOUNDING • SURFACE/SUBSURFACE WASTE TREATMENT SYSTEMS, EVALUATION & DESIGN

1" = 50'



300'
18-24
Lines on contour