

HARNETT COUNTY HEALTH DEPARTMENT

L7122

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) R.L. Properties, LLC

New Installation  Septic Tank

Property Location: SR# 1006 OID STAG-CR ROAD

Repairs  Nitrification Line

Subdivision Wynnridge Lot # 14

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: .50

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 5 exact length of each ditch 60 ft. width of ditches 3 ft. depth of ditches 18-22 in.


French Drain Required: - Linear feet

Date: 5-1-00

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Manhat Environmental Health Specialist

\* Maintain all setbacks  
\* Home placement had to be changed, moved to left 15'. TAKE NOTE!



HARNETT COUNTY HEALTH DEPARTMENT  
**AUTHORIZATION TO CONSTRUCT**

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 17122. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent \_\_\_\_\_

Name: R.L. Properties Telephone # 639-4295

Address: 4590 Old Buis Creek Road Angier N.C. 27501

Property Location: SR # 1006 Road Name OLD STAGE

New Installation  Repair  Septic Tank  Nitrification Lines

Subdivision Wynw ridge Lot # 14

Number of Bedrooms Proposed: 3 Lot size: .5

Basement  With Plumbing  Without Plumbing

Water Supply: Well  Public  Minimum Well Setback: \_\_\_\_\_ ft.

Type of System: Conventional  Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber 10 gallons

Nitrification Field Specifications

Number of fields 2 Number of Lines per Field 5 Length of lines 60

Width of ditches 3 ft. Depth of ditches 18-22 inches

French Drain: Linear feet required  Depth of gravel

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: James E. Markant Date: 5-2-00