

HARNETT COUNTY HEALTH DEPARTMENT

No 17462

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Sue Anderson New Installation Septic Tank
Property Location: SR# 401N Repairs Nitrification Line

Subdivision Bobby Anderson Lot # 1

Tax ID # _____ Quadrant # _____ # 00-400

Number of Bedrooms Proposed: 2 Lot Size: 11 acres

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 125 ft. width of ditches 3 ft. depth of ditches 16-18 in. ^{max}

French Drain Required: - Linear feet


Date: 7-18-00

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Mantel Environmental Health Specialist

* Maintain all setbacks!

* Contractor to meet on site prior to installation



US 401 N ->

HARNETT COUNTY HEALTH DEPARTMENT AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 17462. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Keith Anderson

Name: Sue Anderson Telephone # 893-5061

Address: RT2 BOX 100 F.V. N.C. 27524

Property Location: SR # 401 Road Name 401

New Installation Repair Septic Tank Nitrification Lines

Subdivision Bobby Anderson Lot # 1

Number of Bedrooms Proposed: 2 Lot size: 11 acres

Basement With Plumbing Without Plumbing

Water Supply: Well Public Minimum Well Setback: 50' ft.

Type of System: Conventional Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber gallons

Nitrification Field Specifications

Number of fields 2 Number of Lines per Field 2 Length of lines 125

Width of ditches 3 ft. Depth of ditches 18-20 inches

French Drain: Linear feet required - Depth of gravel -

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: James E. Markert RUS. Date: 7-18-00