



HARNETT COUNTY HEALTH DEPARTMENT  
AUTORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 17769. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent \_\_\_\_\_

Name: C & R Builders Inc Telephone # 919-721-0764

Address: P.O. Box 1405 Dunn, NC 28325

Property Location: SR # 1943 Road Name Lafayette

New Installation  Repair  Septic Tank  Nitrification Lines

Subdivision Victoria Hills Lot # 30

Number of Bedrooms Proposed: 3 Lot size: \_\_\_\_\_

Basement  With Plumbing  Without Plumbing

Water Supply: Well  Public  Minimum Well Setback: 50 ft.

Type of System: Conventional  Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber \_\_\_\_\_ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 4 Length of lines 75 ft

Width of ditches 3 ft. Depth of ditches 12 inches MAX

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Ray M Lewis R.S. Date: 5/2/2000