

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Bryan K Howell

New Installation  Septic Tank

Property Location: SR# 1412 Christian Light

Repairs  Nitrification Line

Subdivision Mel's Meadows Lot # 44

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: 43,008 sq ft

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_

Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 15-22 in.


French Drain Required: — Linear feet

Date: 5-15-00

**This permit is subject to revocation if site plans or intended use change.**

Signed: James C. Mahan, Jr., S.  
Environmental Health Specialist

TAKE NOTE  
\* Home Placement HAS BEEN CHANGED!  
\* Maintain all setbacks!



MEL'S MEADOW DR.

HARNETT COUNTY HEALTH DEPARTMENT  
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 17136. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent BRYAN - TEE LLC

Name: Bryan K Howell Telephone # (919) 552-5115

Address: 6777 Christia Light Rd F.V. N.C. 27526

Property Location: SR # 1412 Road Name Christia Light

New Installation  Repair  Septic Tank  Nitrification Lines

Subdivision Mel's Meadow Lot # 44

Number of Bedrooms Proposed: 3 Lot size: 43,008 sq ft

Basement  With Plumbing  Without Plumbing

Water Supply: Well  Public  Minimum Well Setback: 50' ft.

Type of System: Conventional  Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber \_\_\_\_\_ gallons

Nitrification Field Specifications

Number of fields 2 Number of Lines per Field 2 Length of lines 150

Width of ditches 3 ft. Depth of ditches 18-22 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: James E. Marshall RES. Date: 5-15-00