

00-40000507

H WETT COUNTY HEALTH DEPAR
ENVIRONMENTAL HEALTH SEC. ENT

No 13886

OPERATIONS PERMIT

Name: (owner) Harold Pardin ☒ New Installation ☒ Septic Tank
Property Location: SR# 1505 ☐ Repairs ☐ Nitrification Line
Subdivision _____ Lot # _____
TAX ID# _____ Quadrant # _____
Contractor: Randy Jones Registration # _____
Basement with Plumbing: ☐ Garage: ☐
Water Supply: ☐ Well ☒ Public ☐ Community
Distance From Well: 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☒ Conventional ☐ Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface No. of exact length width of depth of
Drainage Field ditches 3 of each ditch 80 ft. ditches 3 ft. ditches 18-24 in.
French Drain: _____ Linear feet

PERMIT NO. 17792

Date: 6/28/2000
Inspected by: Bryan McSwain L.S.
Environmental Health Specialist

