HA ETT COUNTY HEALTH DEPART NT
IRONMENTAL HEALTH SECT

№ 10225

OPERATIONS PERMIT

Name: (owner) Floyd Construction ☑ New Installation ☑ Septic Tank

Property Location: SR# 1120 ☐ Repairs ☑ Nitrification Line

Subdivision Whisper Creek Lot # 9A

TAX ID# _____ Quadrant # _____

Contractor: Ottis Strickland Registration # _____

Basement with Plumbing: ☐ Garage: ☑

Water Supply: ☐ Well ☐ Public ☐ Community

Distance From Well: 50 ft. + any existing

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: ☑ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field: No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18-24 in.

French Drain: _____ Linear feet

Date: 04-04-01

PERMIT NO. 17310

Inspected by: [signature] R.S
Environmental Health Specialist