


APPLICANT NAME _____

DATE _____

FACTORS		PROFILES								
		1	2	3	4	5	6	7	8	9
LANDSCAPE POSITION	.1940									
SLOPE (%)	.1940									
HORIZON 1 DEPTH		0-6	0-18	0-14	0-10	0-10	0-8	0-10	0-10	0-12
Texture Group	.1941(A)(1)	SL	U/S	U/S	U/S	U/S	U/S	U/S	U/S	U/S
Consistence	.1941									
Structure	.1941(A)(2)									
Mineralogy	.1941(A)(3)									
HORIZON 2 DEPTH		6-24	18-28	14-30	10-20	10-24	8-24	10-24	10-22	12-24
Texture Group	.1941(A)(1)	U/S	SL	SL	SL		SL	SL	SL	SL
Consistence	.1941			Fi					Fi	Fi
Structure	.1941(A)(2)			S/S					S/S	S/S
Mineralogy	.1941(A)(3)			S/S					S/S	S/S
HORIZON 3 DEPTH			28-32						12-30	
Texture Group	.1941(A)(1)		U/S						U/S	
Consistence	.1941		CLAY							
Structure	.1941(A)(2)									
Mineralogy	.1941(A)(3)									
HORIZON 4 DEPTH										
Texture Group	.1941(A)(1)									
Consistence	.1941									
Structure	.1941(A)(2)									
Mineralogy	.1941(A)(3)									
SOIL WETNESS	.1942	14"	28"	28"	16"	18"	18"	18"	24"	24"
RESTRICTIVE HORIZON	.1944									
SAPROLITE	.1943/1956									
CLASSIFICATION	.1948	X	PS	PS	X	X		X	PS	PS
LONG TERM ACCEPTANCE RATE	.1955	X	.4	.4	X	X		X	.4	.4

3x100'
at 12" deep
6" corr needed



⑩ 0-16 U/S

16-30 SL

24" mth

(.5)

⑪ 0-12 U/S

12-28 SL

(.4 PS)

⑫ 0-20 U/S

20-30 SL

(.5) PS

⑬ 0-12 U/S

12-30 SL

24" mth

(.4 PS)