

IMPROVEMENT PERMIT

№ 17541

Name: (owner) Robert A. Emis ☒ New Installation ☒ Septic Tank

Property Location: SR# 1521 Gregory Circle ☐ Repairs ☒ Nitrification Line

Tax ID # _____ Quadrant # _____

Basement with Plumbing: ☐ Garage: ☐

Water Supply: ☒ Well ☐ Public ☐ Community

Distance From Well: 100 ft.

Type of system: ☒ Conventional ☐ Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 90 ft. width of ditches 3 ft. depth of ditches 18.24 in.


French Drain Required: _____ Linear feet

Date: 8/17/2000

This permit is subject to revocation if site plans or intended use change.

Signed: Gregory M. Larkin, D.S.
Environmental Health Specialist

- * Maintain setbacks
- * Run ditches on contour



HAI HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 17541. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent _____

Name: Robert A Ennis Telephone # 893-3044

Address: P.O. Box 785 Boies Creek NC 27506

Property Location: SR # 1521 Road Name Gregory Circle

New Installation ☒ Repair ☐ Septic Tank ☒ Nitrification Lines ☐

Subdivision Robert A Ennis Lot # _____

Number of Bedrooms Proposed: 3 Lot size: 2.01 Ac

Basement ☐ With Plumbing ☐ Without Plumbing ☐

Water Supply: Well ☒ Public ☐ Minimum Well Setback: 50 ft.

Type of System: Conventional ☒ Other ☐

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 3 Length of lines 90 ft

Width of ditches 3 ft. Depth of ditches 18.24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Dana M. Lewis R.S. Date: 8/17/2000