



Dixie-Denning Supply Co.



705 South Wall Street

Benson, NC 27504

Ph. 919-894-3824

Fax 919-894-2871

TOP: Request for Inspection

Date: 7-18-19
Harnett County Inspections Department
108 E. Front St
Lillington, NC 27546
Fax: 910-893-7525

We have run a pressure test at 780 Hodges Chapel Rd Dunn NC.
The pressure held at 50 PSI for approximately 2 hours.

Dixie Denning supplied carbon monoxide detector _____.
Customer already had a carbon monoxide detector X.

Sincerely,

Mike Denning License # 21095
Dixie Denning LP Gas

Permit MCOM1907-0003