



Permit Inspections

Harnett County

Permit Number: MCOM2109-0002

Description: **C/O 2.0 ton hp**

Applied: **9/3/2021**

Approved: **9/3/2021**

Site Address: **1625 RAY RD**

Issued: **9/3/2021**

Finalized:

City, State Zip Code: **SPRING LAKE, NC 28390**

Status: **ISSUED**

Applicant: **TOTAL SYSTEMS HEATING & COOLIN**

Parent Permit:

Owner: **LIBERTY BAPTIST CHURCH OF SPRING LAKE**

Parent Project:

Contractor: **TOTAL SYSTEMS HEATING & COOLIN**

Details:

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
			FINAL**	Unassigned		eTRAKiT Inspection Request

Notes:

	9/9/2021 AM	9/9/2021	FINAL**	Unassigned	DISAPPROVED	eTRAKiT Inspection Request
--	-------------	----------	---------	------------	-------------	----------------------------

Notes:

9/8/2021 11:01 AM TOTAL SYSTEMS HEATING & COOLIN

Contact Name: TOTAL SYSTEMS HEATING & COOLIN

Site Address: 1625 RAY RD

Phone: 9104363450

e-Mail: service@totalsystemsnc.com

Max breaker size is exceeded that of the compressor, Label Panel at compressors to correspond with compressors, Label compressors to correspond with panel. Provide float shut off valve if required.