



Permit Inspections

Harnett County

Permit Number: MCOM2409-0005

Description: Installation of 2 HHW Boilers and 2 DHW boilers

Applied: 9/6/2024

Approved: 9/11/2024

Site Address: 260 LESLIE CAMPBELL AVE

Issued: 9/13/2024

Finalized: 6/13/2025

City, State Zip Code: LILLINGTON, NC 27546

Status: FINALED

Applicant: BRADY TRANE SERVICE INC

Parent Permit:

Owner: CAMPBELL UNIVERSITY

Parent Project:

Contractor: BRADY TRANE SERVICE INC

Details:

waiting on trade apps

LIST OF INSPECTIONS

SEQ ID	SCHEDULED DATE	COMPLETED DATE	TYPE	INSPECTOR	RESULT	REMARKS
	2/27/2025	2/27/2025	GAS PIPING	Steven Gazlay	APPROVED	eTRAKiT Inspection Request

Notes:

2/26/2025 12:33 PM Brandi Frey
AM would be great. Site contact Chris Morgan 910-602-8195
Contact Name: Brandi Frey
Site Address: 260 LESLIE CAMPBELL AVE
Phone: 9194101685
e-Mail: brandi.frey@bradyservices.com

Need code compliant test gauges.

	5/16/2025	5/19/2025	FINAL**	Steven Gazlay	DISAPPROVED	
--	-----------	-----------	---------	---------------	-------------	--

Notes:

Hydronic piping never pressure tested or inspected. Enclosure will need to be anchored. Boilers not inspected by NCDOL. Need electrical inspection.

	6/13/2025	6/13/2025	FINAL**	Steven Gazlay	APPROVED	
--	-----------	-----------	---------	---------------	----------	--

Notes:

Site contact person is Dennis Dunning at 910-305-5327.
Inspector TSG changed the inspection assignment from TSG to SPG